Acronyms (add to list as needed for your project)

bbl	barrel
CO2e	Carbon dioxide equivalents
CO	Carbon monoxide
CTG	Combustion turbine generator
dscf	Dry standard cubic feet
EPN	Emission point number
EFR	External floating roof
gr	Grain
GHG	Greenhouse gases
hr	Hour
H2S	Hydrogen sulfide
IFR	Internal floating roof
Pb	lead
MSS	Maintenance, startup, shutdown

MW	Megawatt		
MWh	Megawatt hour		
MMBtu	Million British thermal units		
NOx	Nitrogen oxides		
02	Oxygen		
DM/DM10/DM2 5	Particulate matter, including PM equal to or		
PIVI/PIVI10/PIVI2.5	less than 10 or 2.5 microns in diameter		
ppm	Parts per million		
lb	Pound		
SCR	Selective catalytic reduction		
SO2	Sulfur dioxide		
H2SO4	Sulfuric acid		
tpy	Tons per year		
VOC	Volatile organic compounds		

Facility Information

Company Name	SL Energy Power Plant I, LLC
Facility Name	SL Energy Power Plant I
Project Description (only address units requiring federal review)	SL Energy Power Plant I, LLC (SL Energy) proposes to construct and operate a power generation plant, consisting of two natural gas combined cycle gas turbines, for public and private electricity consumption in Lexington, Texas. The plant has a total nominal maximum power output of 1,240.2 MW at the International Organization for Standardization (ISO) 3977 ambient conditions of 59°F, 60% relative humidity, and sea level elevation.
	Ancillary equipment includes a dedicated lube oil system for each turbine train, one natural gas fueled auxiliary boiler, two natural gas fueled fuel water bath heaters, one diesel fueled emergency generator, one diesel fueled emergency fire pump, two lube oil tanks, two diesel tanks, 12 high voltage circuit breakers, fugitive piping equipment in natural gas service, ammonia service, and diesel service, and various maintenance activities.
Facility County	Lee
Facility Contact (Name, Phone Number)	Mr. Tommy Hodges, (512) 430-0669
Your Contact Info (Name, Phone, Email)	Mr. Huy Pham, (512) 239-1358, Huy.Pham@tceq.texas.gov
Permit Numbers (this list should match your CND header)	177380, PSDTX1650, and GHGPSDTX244
Title V Permit Number (or not yet available)	Not yet available
Permit Type (All Major & Minor permits)	New/Greenfield Facility
Projected Second Public Notice Issuance Date	March 14, 2025
Projected Final Issuance Date	June 2, 2025
SIC Code	4911
NAICS Industry Code	221112
Facility Registry System Number (or not found)	Not found
Nearest Class I Area	Wichita Mountains, OK
Distance from Facility to Nearest Class I Area	Greater than 250 km

Pollutants triggering major NSR permitting with this action

NOX	* BACT	* LAER	* MACT
VOC	* BACT	* LAER	* MACT
СО	* BACT	* LAER	* MACT

SO ₂	* BACT	* LAER	* MACT
PM	* BACT	* LAER	* MACT
PM10	* BACT	* LAER	* MACT
PM _{2.5}	* BACT	* LAER	* MACT
H_2SO_4	* BACT	* LAER	* MACT
CO ₂ e	* BACT	* LAER	* MACT

Process Description / Project Scope

SL Energy Power Plant I, LLC (SL Energy) proposes to construct and operate a power generation plant in Lee County, Texas for public and private consumption. The power plant will consist of two natural gas-fired combined cycle gas turbines (EPNs GT-1 and GT-2) in a 2x2x2 configuration (two turbine trains, each with a dedicated supplemental fired [duct burner] heat recovery steam generator [HRSG] and a dedicated steam turbine). The gas turbines are Siemens model SGT6-9000HL Advanced Class Gas Turbines. The total nominal maximum power output for the two combustion turbines when each duct burner is in service is approximately 1,240.2 MW at the International Organization for Standardization (ISO) 3977 ambient conditions of 59°F, 60% relative humidity, and sea level elevation. Each turbine and duct burner train will have a total maximum firing rate of 4,083 MMBtu/hr (Higher Heating Value [HHV]).

SL Energy has stated that electricity will be sold to the state electric grid, with about 80 MW sold to the public during ERCOT system peak periods. Electricity will continue to be sold to the public until all of the private customers have completed projects slated to accept the power being generated by these two turbines. Both gas turbines are expected to operate up to 8,076 hours per year each, which includes periods of startup and shutdown.

The following is the process description for the proposed SL Energy power plant.

Combustion Turbine and Heat Recovery Steam Generator (HRSG)

For each turbine train, filtered ambient air is drawn into the compressor section of the turbine and mixed with natural gas to be combusted in the combustor section. During periods of warm to hot ambient temperatures, evaporative cooling may be used to lower the temperature of the inlet air and increase the mass air flow through the turbine to achieve maximum turbine power output. Hot exhaust gases then enter the expansion turbine and expand across the turbine, which generates torque that causes rotation of the turbine shaft. The shaft drives the compressor section of the unit and spins the dedicated electric generator, producing electricity.

Exhaust from the combustion turbine then passes through a HRSG where boiler feed water is converted into high pressure steam. Natural gas-fired duct burners increase the temperature of the combustion turbine exhaust. A steam turbine generator receives the steam from the HRSG. The expansion of the high-pressure steam across the steam turbine causes rotation of the steam turbine shaft, producing electricity. The gas turbine and HRSG duct firing combustion emissions will vent to the atmosphere via the HRSG exhaust stack for each train (EPNs GT-1 and GT-2).

SL Energy stated that a bypass operation when the steam turbine(s) is out of service can occur. During this time, the exhaust heat from the combustion turbine still passes through the HRSG, but a 100% steam bypass is used to allow for steam generated in the HRSG to bypass the steam turbine and be routed directly to the air-cooled condenser where it is cooled, condensed, and returned to the HRSG for cooling. The exhaust gas is still treated with the ammonia SCR system to reduce NOx. The path of the gas and emissions is not affected during bypass mode, except that duct firing is not utilized since the steam turbine is not in service to generate from the additional steam, so bypass operation will still result in emissions from the same stack (EPNs GT-1 and GT-2). SL Energy states that bypass capability greatly facilitates plant startups and shutdowns, reducing the duration needed.

Ancillary Equipment and Sources

The two combustion turbines and two steam turbines will have a dedicated lube oil system for each train. The lube oil systems are used to lubricate the moving parts of the turbines. Emissions of condensed lube oil droplets from the lube oil systems will be exhausted through vapor extraction vents serving the proposed unit, and these emissions will be controlled with mist eliminators (EPNs LOV-1 and LOV-2). Two lube oil tanks (EPN LOT-1 and EPN LOT-2, respectively) will be used to provide lube oil for the two systems. Additional ancillary equipment includes one natural gas fueled auxiliary boiler (EPN AUX-1), two natural gas fueled fuel water bath heaters (EPNs FH-1 and FH-2), one diesel fueled emergency generator (EPN GEN-1), one diesel fueled emergency fire pump (EPN FP-1), two diesel tanks (EPNs EGDT-1 and EFDT-1), 12 high voltage circuit breakers (EPN CB-1), and fugitive piping equipment in natural gas service (EPN NGFUG-1), ammonia service (EPN AFUG-1), and diesel service (DFUG-1).

Steam is produced in the two heat recovery steam generators and the auxiliary waste heat boiler. The steam will be used to drive two Siemens SST6-5000 steam turbines driving two Siemens SGEN-3000W generators to produce electricity. Used steam from the turbine exhaust is condensed in an enclosed non-contact cooling system and recycled for reuse in the process.

SL Energy stated this non-contact cooling system is also characterized as a dry cooling system, which does not operate as a typical 'wet' cooling tower where process water comes in direct contact with ambient air. This dry cooling system cools and condenses the steam by passing large volumes of air over enclosed steam and condensate piping. Air Cooled Condensers (ACCs), which are finned tube heat exchangers, are used to remove the heat. The turbine exhaust is directed

via a duct to the inlet of the ACC and is forced through the finned tubes similar to a commercial HVAC condenser. Simultaneously, cool ambient air forced across the exterior of the finned tubes removes heat from the steam passing through the tubes, and condensation occurs. The condensate is then pumped back to the HSRG in a closed loop. The SL Energy Station industrial scale ACC's will be of an elevated Mechanical Indirect Dry Cooling Tower (MIDCT) A-Frame design that draws cooling air from ground level, forces it vertically through the A-Frame heat exchanger and exhausts the warmed air out the top. No steam, condensate, or water is exposed to the atmosphere during the cooling process, so no typical wet cooling tower emissions (VOC, PM, PM₁₀, or PM_{2.5}) are produced.

One Auxiliary Boiler (AUX-1) will be used to produce steam and drive the steam turbines during combined cycle turbine outages. During a normal startup of the gas turbine, the auxiliary boiler will be placed in service to pre-warm the HRSG, pre-warm the steam turbine, to set seals, and to pull vacuum on the steam turbine exhaust. The boiler will remain in service after the gas turbine is started until the HRSG is hot enough to generate saturated steam from the gas turbine, which is estimated to be 20 minutes. The boiler would then be shut down. The diesel-powered emergency engine will provide power to the site during power outages. The diesel-powered emergency fire pump will provide emergency firefighting capabilities to the site.

A maximum of 19 percent aqueous ammonia by weight will be used to control NOx in the SCR. Aqueous ammonia will be delivered to the plant by tank truck and unloaded into ammonia storage tanks. The tankers will not be pressurized and not be offloaded under pressure. During filling of the ammonia tank, all vapors will be vented back (vapor balanced) to the transport tanker as the storage tank(s) is filled. SL Energy will ensure that the ammonia supplier complies with all vapor balancing requirements. SL Energy also has in place procedures and protocols for on-site delivery, filling, and handling of aqueous ammonia per OSHA's Process Safety Management of Highly Hazardous Chemicals standard (29 CFR 1910.119) and will only accept deliveries from reputable, proven suppliers who fully comply with Federal DOT Requirements. The ammonia storage tank will be rated for 50 psia and since the tank safeties are set at 50 psi, heating of the ammonia tank due to daily cyclical heating will not be sufficient to raise the pressure of the tank to a level that will result in emissions from standing losses.

The generator circuit breakers associated with the proposed units will be insulated with SF_6 . The gas is used for electrical insulation, arc quenching, and current interruption in high-voltage electrical equipment. Fugitive emissions of SF_6 are designated as EPN CB-1.

Planned Maintenance, Startup, and Shutdown (MSS) Activities

Planned startup and shutdown of the proposed combined cycle turbines will occur at the site, which result in elevated CO, NOx, and VOC emissions and concentration limits compared to the emissions and concentration limits during routine, steady-state turbine operation. SL Energy has defined a planned startup of the combined cycle turbine(s) as the period beginning when the combustion turbine receives a "turbine start" signal, when fuel is introduced, and an initial flame detection signal is recorded by the plant's control system. **The planned startup ends when** the combustion turbine output achieves steady operation (greater than 35% capacity) in the low NOx operating mode, the SCR has achieved steady state operation, and the startup emissions have purged through the continuous emissions monitoring system (CEMS), thereby achieving emissions compliance.

SL Energy has defined a planned shutdown period as the period beginning when the combustion turbine receives a shutdown command and the combustion turbine operating level drops below its minimum sustainable load (less than 35% capacity), and the ammonia injection is no longer in service for purposes of an intended shutdown (i.e., shutdown of the ammonia system was not caused by a system failure). The planned shutdown period ends when a flame detection signal is no longer recorded in the plant's control system. Each startup and shutdown activity are expected to last for less than an hour in duration.

Planned maintenance activities (EPN MSS-1) include turbine blade washing, miscellaneous air intake filter changeouts, CEMS analyzer and other process instrument calibrations, inlet fuel line venting, repair and replacement of small equipment and fugitive components, catalyst handling, and sludge management. For turbine blade washing, VOC-containing cleaning chemicals may be used. Sludge is collected on-site and then shipped off-site.

Risk Management Plan (RMP) and Disaster Review Determination

SL Energy has stated that the aqueous ammonia planned to be stored will have a maximum 19 weight percent ammonia, which is below the 20-weight percent threshold requiring a Risk Management Plan (RMP) according to the threshold quantities specified in Tables 1 and 2 of 40 CFR 68.130. A disaster review is also not triggered for the storing and handling of aqueous ammonia.

Best Available Control Technology

The EPA accepts the TCEQ's three-tier approach to BACT as equivalent to the EPA's top-down approach to BACT for PSD review when the following are considered: recently issued/approved permits within the state of Texas, recently issued/approved permits in other states, and control technologies contained within the EPA's RBLC database for the specified source. For pollutants subject to PSD review, the Applicant conducted a search of the RACT/BACT/LAER Clearinghouse (RBLC), the TCEQ Turbine List, and recently-approved permits for combined cycle gas turbines and similar emissions sources authorized in Texas and other states. State minor BACT was evaluated for pollutants not subject to PSD review.

Source Name	EPN	Best Available Control Technology Description
Combined Cycle Gas Turbine 1	GT-1	The combustion turbines and supplemental duct burners will be fired exclusively with pipeline quality natural gas. The individual maximum
Combined Cycle Gas Turbine 2	GT-2	 firing rate for each combustion turbine is 3,758 MMBtu/hr (HHV), while the maximum specified firing rate for each duct burner is 348 MMHBtu/hr (HHV). However, no turbine train will be operated at the maximum turbine firing rate and the maximum duct burner firing rate simultaneously. Instead, the combustion turbine and supplemental duct burner for either train will have a maximum total firing rate of approximately 4,083 MMBtu/hr (HHV). The pollutant emission factors are provided by equipment suppliers and EPA's AP-42 emission factor database. Both hourly and annual emission calculations are based on the worst-case scenario from the manufacturer's performance guarantee, which occurs when the turbine is operating at 100% load, the duct burners are operating, evaporative cooling is not used, ambient temperature is -5.0°F, relative humidity is 20.0%, and barometric pressure is 14.45 psia. Annual emissions are based on up to 8,060 hours of steady-state operation each year and additional contributions from expected startup and shutdown operations. NOX: Each turbine is limited to a 2-ppmvd stack concentration at 15 percent oxygen (% O₂) on a rolling 3-hour average with or without duct burner firing. Dry Low-NOX (DLN) burners, an ammonia-based Selective catalytic reduction (SCR) system, and good combustion practices are used to achieve this concentration limit and reduce NOX emissions. CO: Each turbine is limited to a 2 ppmvd stack concentration at 15% O₂ on a rolling 3-hour average with or without duct burner firing. An oxidation catalyst and good combustion practices are used to achieve this concentration practices are used to achieve this concentration signore. VOC: Each turbine is limited to a 2 ppmvd stack concentration at 15% O₂ on a rolling 24-hour average with or without duct burner firing. An oxidation catalyst and good combustion practices are used to achieve this emission limit. SO₂ and H₂SO₄: Each turbine, including the
		 SO₂ and H₂SO₄: Each turbine, including the duct burners, is limited to firing pipeline quality natural gas with a sulfur content of up to 0.5 grains per 100 dry standard cubic feet (gr S/100 dscf). To estimate emissions of SO₂, it is assumed that there is 100% conversion of the sulfur in the fuel to SO₂. To estimate emissions of H₂SO₄, it is conservatively assumed that 100% of SO₂ produced is converted to SO₃ and then to H₂SO₄ with no additional conversion to (NH₄)₂SO₄ particulate matter. PM/PM₁₀/PM_{2.5}: Pipeline quality natural gas and good combustion practices are used to limit particulate matter emissions. Each turbine is proposed to meet 0.0046 lb/MMBtu, as guaranteed by the turbine manufacturer, Siemens Energy. This emission factor includes all filterable and condensable particulate matter that may be formed in the SCR unit from reaction of H₂SO₄ mist with ammonia in the exhaust stream. Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM. No technically feasible post-combustion control technologies are available

		 to reduce particulate matter emissions from gas turbines due to the large amount of excess air inherent to the turbine operation and would create an unacceptable amount of backpressure. HAPs: Total HAPs emissions, including formaldehyde, are estimated using the 0.000408 lb/MMBtu emission factor according to EPA AP-42 Table 3.1-3. NHa: The ammonia slip from each turbine is limited to 10.0 ppmvd stack concentration at 15% O₂ on a rolling 3-hour average. The SCR system will be operated in a manner to minimize ammonia slip. MSS: Elevated hourly CO, NOx, and VOC emissions and concentrations are expected during startup and shutdown operation compared to routine, steady-state operation. Higher NOx emissions and concentrations are produced during transition of the combustors to low NOx operating mode and the ineffectiveness of using an SCR during the transition. Higher CO and VOC emissions and concentrations occur due to more incomplete combustion as the combustion turbine transitions to the normal operating mode and the ineffectiveness of using the oxidation catalyst during the transition. Startup and shutdown emissions are estimated based on 8 startups and shutdown pervents are each expected to last less than an hour in duration, the emissions estimates for startup and shutdown provided by the manufacturer had been extrapolated into 1-hour rates to assume the activities each least a full hour. The result is a conservative estimate of a full hour in which a startup or shutdown occurs. The duration of MSS activities will be minimized, the amount of time the turbine is outside the performance mode where emissions control practices are used. GHG as CO₂: Each turbine will comply with 40 CFR NSPS TTTTa requirements and operate as base load units (annual capacity factor greater than 40%). Therefore, the gross power-output based GHG emissions for each unit are limited to 800 lb CO₂/MWh on a 12-month operating month average during
Lube Oil Vent 1	L OV-1	permits in Texas and in other states.
Lube Oil Vent 2	LOV-2	associated steam turbine. Emissions of condensed lube oil droplets from the lube oil systems will be exhausted through vapor extraction vents serving the combustion turbine and steam turbine. BACT is satisfied through use of oil mist eliminators to remove fine oil droplets from the air flow of the vapor extraction vents and minimize emissions.

		 The unloading, storage, and heated recirculation of lube oil are estimated to emit equal to or less than 0.3 gallons per day of oil lost per vent, based on the oil consumption for similar units and operations. Lube oil is assumed to be emitted as VOC, PM, PM₁₀, and PM_{2.5}. Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM. Lube oil vent emissions are estimated based on 8,060 hours of operation per year, similar to turbine operation. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Auxiliary Boiler 1	AUX-1	 The auxiliary boiler will have a maximum heat input of 84 MMBtu/hr (HHV) and be fired exclusively with pipeline quality natural gas. The auxiliary boiler provides additional steam for the steam turbines 1 and 2 (associated with HRSGs 1 and 2, respectively) during combined cycle turbine outages. The boiler also prewarms the HRSGs to appropriate temperature to generate saturated steam during startup of the gas turbines. The boiler will operate up to 2,000 hours per year. NOX: The boiler is limited to 0.01 lb NOX/MMBtu, as guaranteed by the equipment manufacturer. Dry low NOx burners and good combustion practices are used to achieve this emission limit and reduce NOx emissions. CO: The boiler is limited to 50 ppmvd CO stack concentration at 3% O₂, as guaranteed by the equipment manufacturer. Good combustion practices are used. VOC: The boiler is limited to 50 ppmvd CO stack concentration at 3% O₂, as guaranteed by the equipment manufacturer. Good combustion practices are used. SO₂: The boiler is fired exclusively with pipeline quality natural gas based on 0.5 gr S/100 dscf of natural gas supplied by the natural gas supplier. PM/PM₁₀/PM_{2.5}: The boiler is limited to 0.008 lb particulate matter/MMBtu, as guaranteed by the equipment manufacturer. Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM. HAPs: Total HAPs, including formaldehyde, are estimated using the 0.08111 lb/10⁶ scf emission factor according to EPA AP-42 Table 1.4-3. GHG as CO₂e: The boiler is limited to 117.10 lb CO₂e/MMBtu according to 40 CFR 98 Tables C-1 and C-2. Good combustion practices are used. The Aplicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Fuel Water Bath Heater 1	FH-1	The two fuel water bath heaters will heat up the natural gas fuel prior to
Fuel Water Bath Heater 2	FH-2	maximum heat input of 14 MMBtu/hr and will be fired exclusively with
Fuel Water Bath Heater Cap	FH-CAP	 pipeline quality natural gas. Only a single heater is expected to be able to heat the entire fuel gas supply for both gas turbines and boiler, while the other heater will be used as a spare. There will be a brief overlap period where both heaters are technically in service. Therefore, the annual emissions for each heater are included in an annual emissions cap (EPN FH-CAP), which is based on a total of 8,760 hours of operation per year of one heater. NOx: The heaters are limited to 0.01 lb/MMBtu, as guaranteed by the equipment manufacturer. Good combustion practices are used. CO: The heaters are limited to 50 ppmvd CO stack concentration at 3% O₂. Good combustion practices are used. VOC: The heaters' VOC emissions are estimated at 5.5 lb/10⁶ scf according to EPA AP-42 Table 1.4-2. Good combustion practices are used. SO₂: The heaters are fired exclusively with pipeline quality natural gas based on 0.5 gr S/100 dscf of natural gas supplied by the natural gas supplier.

		 PM/PM₁₀/PM_{2.5}: The heaters are limited to 0.008 lb particulate matter/MMBtu, as guaranteed by the equipment manufacturer. Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM. HAPs: Total HAPs, including formaldehyde, are estimated using the 0.08111 lb/10⁶ scf emission factor according to EPA AP-42 Table 1.4-3. GHG as CO₂e: The heaters are limited to 117.10 lb CO₂e/MMBtu according to 40 CFR 98 Tables C-1 and C-2. Good combustion practices are used. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Emergency Generator 1	GEN-1	 The Caterpillar Model 3516C 2,500 kW emergency generator is rated for 3,352.5 bhp/hr and limited to operate up to 52 hours per year for testing purposes, charging batteries, and checking critical operating parameters to ensure it is ready in case of emergencies. Ultra-low sulfur content diesel fuel and good combustion practices are used. The generator will be equipped with a non-resettable runtime meter. The emergency generator meets the requirements of 40 CFR Part 60, Subpart IIII based on the requirement in 40 CFR \$60.4200(a)(2)(i). The emergency generator engine model is 2024, the displacement is less than 10 liters per cylinder, and the emission standards found in 40 CFR \$60.4202(b)(2) apply. The manufacturer-guaranteed NOx, VOC, CO, and particulate matter emission factors are below the specified 40 CFR \$60.4202(b)(2) standards. NOx is limited to 5.32 g/bhp-hr (0.0117286 lb/bhp-hr), VOC is limited to 0.1 g/bhp-hr (0.00063934 lb/bhp-hr), CO is limited to 0.42 g/bhp-hr (0.00011023 lb/bhp-hr). Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM. SO₂ emissions are estimated using a 0.0000121 lb/bhp-hr emission factor determined from EPA AP-42 Chapter 3.4, Table 3.4-1 with a diesel sulfur content of 15 ppmw. Total HAPs, including formaldehyde, are estimated using a 0.00157398 lb/MMBtu emission factor according to EPA AP-42 Tables 3.4-3 and 3.4-4. GHG as CO₂e emissions are limited to 163.59 lb/MMBtu according to 40 CFR 98 Subpart C Table C-1. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Emergency Fire Pump 1	FP-1	 The Cummins model CFP15E-F10 Emergency Fire Pump is rated for 488 bhp/hr and limited to operate up to 52 hours per year for testing purposes, charging batteries, and checking critical operating parameters to ensure it is ready in case of emergencies. Ultra-low sulfur content diesel fuel and good combustion practices are used. The fire pump will be equipped with a non-resettable runtime meter. The emergency fire pump meets the requirements of 40 CFR Part 60, Subpart IIII based on the requirement in 40 CFR §60.4200(a)(2)(ii). The engine model is 2024, and the emission standards found in Table 4 of 40 CFR 60 Subpart IIII apply. The manufacturer-guaranteed NOx, VOC, CO, and particulate matter emission factors are below the specified Table 4 standards. NOx is limited to 2.565 g/bhp-hr (0.005654862 lb/bhp-hr), VOC is limited to 0.671 g/bhp-hr (0.0014793 lb/bhp-hr), and PM is limited to 0.078 g/bhp-hr (0.000171961 lb/bhp-hr). Emissions of PM₁₀ and PM_{2.5} are conservatively assumed to equal PM.

		 SO₂ emissions are estimated using a 0.0000121 lb/bhp-hr emission factor determined from EPA AP-42 Chapter 3.4, Table 3.4-1 with a diesel sulfur content of 15 ppmw. Total HAPs, including formaldehyde, are estimated using a 0.00157398 lb/MMBtu emission factor according to EPA AP-42 Tables 3.4-3 and 3.4-4. GHG as CO₂e emissions are limited to 163.59 lb/MMBtu according to 40 CFR 98 Subpart C Table C-1. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Lube Oil Tank 1	LOT-1	The lube oil tanks and diesel tanks will be horizontal, fixed roof tanks
Lube Oil Tank 2	LOT-2	equipped with submerged fill and have uninsulated surfaces exposed to the sun be white. Diesel and lube oil have vapor pressures less than
Emergency Generator 1 Diesel Tank	EGDT-1	0.5 psia at the maximum operating temperature. Note, the emissions from the lube oil tanks were estimated using a molecular weight of 600
Emergency Fire Pump 1 Diesel Tank	EFDT-1	 Ib/Ib-mole, which is conservative in determining the emissions estimates. Emissions from the lube oil and diesel tanks are VOCs. Lube oil will be stored in two approximately 28,000 gallon tanks, each with a maximum fill rate of 8,000 gallons per hour and annual net throughput of 8,109.5 gallons per year. A 5,000 gallon tank will be used to store diesel for the emergency generator, while a 500 gallon tank will be used to store diesel for the emergency fire pump. The estimated diesel usage for the emergency generator 1 diesel tank is 5,000 gallons per hour and 5,000 gallons per year. The estimated diesel usage for the emergency fire pump 1 diesel tank is 500 gallons per hour and 500 gallons per year. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for VOC triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states
Natural Gas, Ammonia, and Diesel Fugitives	NGFUG-1, AFUG-1, DFUG-1	 Fugitive equipment leaks may occur from piping equipment in natural gas, ammonia, and diesel service. The EPA emission factors for SOCMI facilities without ethylene are used. BACT is satisfied for ammonia fugitive leaks through use of the 28AVO leak detection and reduction (LDAR) program to reduce ammonia emissions. Inspections are performed once every four hours (three times per 12-hour shift). The uncontrolled VOC emissions from piping fugitive components at the site are less than 10 tpy. Therefore, no control is required as BACT for VOC emissions from piping fugitive components in natural gas and diesel service. However, daily audio, visual, and olfactory (AVO) inspections are required to monitor fugitive leaks in natural gas service based on BACT for GHG emissions from natural gas piping equipment supporting natural gas fired turbines. No control credit is claimed for these inspections of the natural gas fugitive piping components. GHG as CO₂e: Natural gas is assumed to have a maximum 93.6% methane by weight. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Circuit Breakers	CB-1	Circuit breakers will be insulated with SF_6 , which is a colorless, odorless, and non-flammable gas. SF_6 contributes to greenhouse gas emissions and has a global warming potential of 23,500. Potential leaks of SF_6 can occur from high-pressure electrical switchgear. Twelve high voltage circuit breakers will be installed at the facility, with each circuit breaker

		 having a capacity of 128 pounds of sulfur hexafluoride. The predicted SF₆ annual leak rate is 0.5% by weight. BACT for GHG emissions is satisfied through use of state-of-the-art enclosed pressure SF₆ gas circuit breakers equipped with low-pressure SF₆ alarms and low-pressure lockout. The alarm will alert operating personnel of any leakage in the system and the lockout prevents any operation of the breaker in the event there is a lack of "quenching and cooling" SF₆ gas. An AVO inspection program is implemented to detect and minimize leaks. Boilerplate requirements were added to the permit except that the Applicant has requested that each circuit breaker be equipped with a SF₆ leak detection system able to detect a leak of 0.5% per year instead of 1 lb. The representation of 0.5 weight percent SF₆ is lower than the 1 lb SF₆ requirement as boilerplate. Therefore, this change is more stringent than the 1 lb SF₆ requirement and is a lower leak detection threshold, and result in identifying leaks more frequently than the 1 lb SF₆ requirement. The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for GHG as CO₂e triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.
Maintenance Activities	MSS-1	 Maintenance activities proposed from the site include: A. Turbine blade washing will primarily occur with only demineralized wash water and result in emissions of PM, PM₁₀, and PM_{2.5}. A representative cleaning chemical (ZOK 27) containing VOC may be used with up to 36 gallons of cleaning chemical per year. To be conservative, all of the VOC emissions from turbine blade washing occur during the washing process and the entire VOC content of the cleaning chemical is emitted during the process. Only one washing per turbine per hour will occur. Up to 336 turbine blade washings are estimated per year. B. Any miscellaneous filter maintenance where baghouses and air intake filters for turbines need to be replaced and result in particulate matter emissions, including PM, PM₁₀, and PM_{2.5}. Four total changes per year are estimated. C. CEMS analyzer and other process instrument calibrations, inspections, repair, replacement, and testing result in emissions of CO, NOX, and VOC. This can include other sight glasses, gauges, meters, etc. Up to 375 total events per year are estimated. D. Inlet fuel line venting which results in VOC emissions. Portions of the natural gas fuel delivery system may need to be evacuated during maintenance. Venting is estimated to occur for up to 228 hours per year. E. Repair/replacement of small equipment and fugitive piping components in VOC and NH₃ service, such as pumps, compressors, valves, pipes, flanges, transport lines, and filters/screens in natural gas service, diesel oil service, lube oil service. These activities are assumed to occur for up to 10 hours per year for VOC equipment and up to 24 hours for NH₃ equipment. F. Any sludge management, which can include management by vacuum truck/dewatering of material in open pits/ponds/sumps/tanks, other closed or open vessels, or water conveyances. Material managed typically includes water and sludge materials containing miscellaneous VOCs such as diesel, lube oil, and ot

	 H. with vacuum trucks. Catalyst handling results in emissions of PM, PM₁₀, and PM_{2.5}. These activities are assumed to occur for up to five hours per year. The proposed maintenance activities are required to ensure proper operability and safety of equipment. All maintenance activities are limited through best management practices (BMP) for minimizing formation and release of air contaminants. The frequency and duration of MSS activities will be minimized to the extent practicable such that calculated emissions will be low enough to be classified as inherently low emitting (ILE) activities. Emissions estimates shall be revalidated annually for all inherently low emitting MSS activities. GHG as CO₂e emissions occur from natural gas emitted from the gaseous fuel venting maintenance activity and the small equipment repair and replacement activity. Natural gas is assumed to have a maximum 93.6% methane by weight.
	The Applicant provided RBLC searches that were reviewed, and the proposed BACT stated above for each pollutant triggering PSD review is consistent with the RBLC searches and recently issued/approved permits in Texas and in other states.