

**Texas Department of State Health Services  
Laboratory Services Section****\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76159  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511331Water Source :  
Entry Point(s) : EP005Date Collected : 01/14/2015 12:00  
Date Received : 01/15/2015RECEIVED  
OCT 05 2015  
TCEQ  
CENTRAL FILE ROOM

Sample Cond. : Acceptable

Analyte	Result	Uncertainty k=2	MDA	Unit	Yield	Method	Date Analyzed	Analyst
Gross Alpha <sup>1</sup>	<3.0		0.58	pCi/L		EPA 900.0	01/27/2015	CS
Gross Beta <sup>1</sup>	<4.0		2.7	pCi/L		EPA 900.0	01/27/2015	CS
Radium-228 <sup>1</sup>	<1.0		0.66	pCi/L	0.803	SM 7500-Ra D	02/03/2015	JG

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(\*) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

## Texas Department of State Health Services

## Laboratory Services Section

## \*RAD-GRAB

## Analysis Report

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76159  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511331

Water Source :  
Entry Point(s) : EP005

Date Collected : 01/14/2015 12:00  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/15/2015	JK
pH Check	Completed		EPA 200.2	01/16/2015	PG
Turbidity Screen	Completed		SM 2130B	01/16/2015	PG
Visible Particles	Completed			01/16/2015	PG
Uranium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/22/2015	IU

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

## Texas Department of State Health Services

## Laboratory Services Section

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76160  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511159Water Source :  
Entry Point(s) : EP002Date Collected : 01/14/2015 10:52  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Uncertainty k=2	MDA	Unit	Yield	Method	Date Analyzed	Analyst
Gross Alpha <sup>1</sup>	<3.0		0.75	pCi/L		EPA 900.0	01/27/2015	CS
Gross Beta <sup>1</sup>	<4.0		2.7	pCi/L		EPA 900.0	01/27/2015	CS
Radium-228 <sup>1</sup>	<1.0		0.60	pCi/L	0.827	SM 7500-Ra D	02/03/2015	JG

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

**Texas Department of State Health Services  
Laboratory Services Section**

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76160  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511159

Water Source :  
Entry Point(s) : EP002

Date Collected : 01/14/2015 10:52  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/15/2015	JK
pH Check	Completed		EPA 200.2	01/16/2015	PG
Turbidity Screen	Completed		SM 2130B	01/16/2015	PG
Visible Particles	Completed			01/16/2015	PG
Uranium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/22/2015	IU

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(') meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

**Texas Department of State Health Services**  
**Laboratory Services Section**  
**\*RAD-GRAB**  
**Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76161  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511347

Water Source :  
Entry Point(s) : EP006

Date Collected : 01/14/2015 12:45  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Uncertainty k=2	MDA	Unit	Yield	Method	Date Analyzed	Analyst
Gross Alpha <sup>1</sup>	<3.0		1.2	pCi/L		EPA 900.0	01/28/2015	CS
Gross Beta <sup>1</sup>	<4.0		5.6	pCi/L		EPA 900.0	01/28/2015	CS
Radium-228 <sup>1</sup>	<1.0		0.63	pCi/L	0.841	SM 7500-Ra D	02/03/2015	JG

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(') meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

**Texas Department of State Health Services  
Laboratory Services Section**

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID#: AC76161  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511347

Water Source :  
Entry Point(s) : EP006

Date Collected : 01/14/2015 12:45  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/15/2015	JK
pH Check	Completed		EPA 200.2	01/16/2015	PG
Turbidity Screen	Completed		SM 2130B	01/16/2015	PG
Visible Particles	Completed			01/16/2015	PG
Uranium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/22/2015	IU

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted<sup>(1)</sup> meet all TNI (2009 Standard) requirements.

**Authorized by Team Lead EBOYER on 03/12/2015**

## Texas Department of State Health Services

## Laboratory Services Section

## \*RAD-GRAB

## Analysis Report

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76162  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511256

Water Source :  
Entry Point(s) : EP003

Date Collected : 01/14/2015 11:26  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Uncertainty k=2	MDA	Unit	Yield	Method	Date Analyzed	Analyst
Gross Alpha <sup>1</sup>	<3.0		1.1	pCi/L		EPA 900.0	01/28/2015	CS
Gross Beta <sup>1</sup>	<4.0		3.0	pCi/L		EPA 900.0	01/28/2015	CS
Radium-228 <sup>1</sup>	<1.0		0.53	pCi/L	0.815	SM 7500-Ra D	02/03/2015	JG

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(') meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015

**Texas Department of State Health Services  
Laboratory Services Section**

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 2500012

HOLLY LAKE RANCH  
STE D101  
12725 W INDIAN SCHOOL RD  
AVONDALE, AZ 85392-9524

Date Reported: 03/12/2015

Lab Sample ID# : AC76162  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1511256

Water Source :  
Entry Point(s) : EP003

Date Collected : 01/14/2015 11:26  
Date Received : 01/15/2015

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	01/15/2015	JK
pH Check	Completed		EPA 200.2	01/16/2015	PG
Turbidity Screen	Completed		SM 2130B	01/16/2015	PG
Visible Particles	Completed			01/16/2015	PG
Uranium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	01/22/2015	IU

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(<sup>1</sup>) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/12/2015