

Excursions thru November 10, 2017

Weekly Report Control No. W-17-034

WWTP: Sims Bayou

9500 Lawndale

EPA Permit: TX0105058

TCEQ Permit: 10495-002

Master Report No	Address / Type of Structure / Location on Property	Manhole or Basin	Excursion Start Time / Duration	Observed Flow Route	Visible Potential Impacts	Volume (gallons)	Cause of Excursion	Action Taken
17-311-01	1900 EASTWOOD Manhole Open Unpaved Area	SB142037	11/7/2017 8:43 AM 5 Hrs 12 Mins	Storm Sewer	Single-Family Residence	936	Collection system grease blockage Inc. No. 273562 Public System	Chlorinated Excursion; Cleared Main Line; Cleaned and Disinfected; 3GPM
17-312-02	6210 WAL TRIP Private Cleanup Open Unpaved Area	SB093	11/8/2017 10:41 AM 2 Hrs 18 Mins	Contained On Site	Multi-Family Residence	276	Service Lateral Temporary Blockage; Main line clear. Service line stopped up. Inc. No. 273564 Private System	Presumed corrected by private owner; No chlorine spread. Made customer contact.