

**Texas Department of State Health Services  
Laboratory Services Section**

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 1260074

METROPLEX HOMESTEADS WATER SUPPLY  
WILLIFORD, TIM  
1620 GRAND AVENUE PKWY STE 140  
PFLUGERVILLE, TX 78660-2185

Date Reported: 11/29/2018

Lab Sample ID# : AE30409  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1812650

Water Source :  
Entry Point(s) : EP005

Date Collected : 06/19/2018 14:22  
Date Received : 06/20/2018

Sample Cond. : Acceptable

Analyte	Result	Uncertainty k=2	MDA	Unit	Yield	Method	Date Analyzed	Analyst
Gross Alpha <sup>1</sup>	<3.0		2.7	pCi/L		EPA 900.0	10/12/2018	AW
Gross Beta <sup>1</sup>	<4.0		3.6	pCi/L		EPA 900.0	10/12/2018	AW
Radium-228 <sup>1</sup>	<1.0		0.50	pCi/L	0.794	SM 7500-Ra D	09/17/2018	LJ

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(<sup>1</sup>) meet all TNI (2009 Standard) requirements.

**Authorized by Team Lead SGILLARD on 11/27/2018**

**Texas Department of State Health Services  
Laboratory Services Section**

**\*RAD-GRAB  
Analysis Report**

Submitter Identification Number: 1260074

METROPLEX HOMESTEADS WATER SUPPLY  
WILLIFORD, TIM  
1620 GRAND AVENUE PKWY STE 140  
PFLUGERVILLE, TX 78660-2185

Date Reported: 11/29/2018

Lab Sample ID# : AE30409  
Sample Priority : NORMAL  
TCEQ ID#(s) : 1812650

Water Source :  
Entry Point(s) : EP005

Date Collected : 06/19/2018 14:22  
Date Received : 06/20/2018

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	06/20/2018	KH
pH Check	Completed		EPA 200.2	06/21/2018	KH
Turbidity Screen	Completed		SM 2130B	06/21/2018	KH
Visible Particles	Completed			06/21/2018	KH
Uranium <sup>1</sup>	< 0.0010	mg/L	EPA 200.8	07/16/2018	IU

**Comments:**

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

**Authorized by Team Lead SGILLARD on 11/27/2018**