



0000-0000-0028-8445

Document Control Sheet

Sheet Title:	PWS - AR
Box ID:	8740
Control Sheet ID:	0000-0000-0028-8445
Record Series Name:	WS / Public Water Supply
Record Series:	PWS
Primary ID:	1840171
Secondary ID:	
Doc Type:	Analysis Chemical
Security:	Public
Date:	10/7/2015 12:00AM
Title:	Analysis Report
Tertiary ID	

PWS_1840171_AC_20151007_ANALYSIS REPORT



ENVIRONMENTAL SCIENCES BRANCH MC-1947
1100 WEST 49TH STREET
PO BOX 149347
AUSTIN, TEXAS 78714-9347
512-776-7587 - office
512-776-7757 - fax

RECEIVED

FEB 21 2019

TCEQ
CENTRAL FILE ROOM

FAX TRANSMITTAL

TO:

Name: SEAN SCAFF OR STEVEN
SWIERENGA
Organization: Public Drinking
Water Section
Phone number: 512/239-4691
Fax number: 512/239-6050

FROM:

Marie Price
Environmental Sciences Branch
PHONE: 512/776-7587
FAX: 512/776-7757

- ☒ Urgent
☐ For Review
☐ Please Comment
☐ Please Reply
☒ Laboratory Reports

Date sent: 10-7-15
Pages including coversheet: 13

MESSAGE: MCL EXCEEDED - RADIOCHEMICALS

Attached are copies of report(s) and submission form(s) for sample(s) with an analysis result that exceeds a MCL.

The information contained in this facsimile transmission is privileged, confidential, and intended only for the individual designated above. Others are hereby notified that disclosure, copying, distribution or taking action based on the content of this information is prohibited. If you received this facsimile in error please notify the sender immediately at the number provided above.

May 29, 2015

10:46 am

Checkin Receipt Worklist

TCEQ ID		Analysis Type: *RAD-GRAB			
1512156	Coll Dt/Time: 05/28/2015 12:04:07 PWS #: TX1840172 Facility: EP003 Free Cl: 0.34 Temp: 75.00	Type: RT Sample Pt: TRT-TAP Total Cl: pH: 7.90	Priority: N Loc: UNIT B - HB Collector: DARRELL WARREN	Compl?: Y	AC93593 A-B DW 05/29/2015 *RAD-GRAB 
1512113	Coll Dt/Time: 05/28/2015 11:52:51 PWS #: TX1840171 Facility: EP001 Free Cl: 0.26 Temp: 72.00	Type: RT Sample Pt: TRT-TAP Total Cl: pH: 7.80	Priority: N Loc: GST Collector: DARRELL WARREN	Compl?: Y	AC93594 A-B DW 05/29/2015 *RAD-GRAB 
1595169	Coll Dt/Time: 05/28/2015 16:03:25 PWS #: TX1840025 Facility: EP001 Free Cl: 2.50 Temp: 75.00 Orig Samp#: AC85820	Type: RT Sample Pt: TRT-TAP Total Cl: pH: 7.30	Priority: N Loc: PH Collector: DARRELL WARREN Orig Coll Date: 03/24/2015	Compl?: Y	AC93595 A-B DW 05/29/2015 *RAD-GRAB 
1510764	Coll Dt/Time: 05/26/2015 11:19:58 PWS #: TX0900001 Facility: EP002 Free Cl: 0.92 Temp: 67.00	Type: RT Sample Pt: TRT-TAP Total Cl: pH: 7.40	Priority: N Loc: GST FAUCET ONEAST SIDE Collector: NORRIS WUENSCH	Compl?: Y	AC93596 A-B DW 05/29/2015 *RAD-GRAB 
1511459	Coll Dt/Time: 05/26/2015 15:33:03 PWS #: TX0900041 Facility: EP001 Free Cl: 1.15 Temp: 65.00	Type: RT Sample Pt: TRT-TAP Total Cl: pH: 7.30	Priority: N Loc: INSIDE PS AT SINK Collector: NORRIS WUENSCH	Compl?: Y	AC93597 A-B DW 05/29/2015 *RAD-GRAB 

08:54:02 a.m.

5127767757

10-07-2015

7/13

WS Name	PWS ID	TCEQ ID	Lab ID	Collection Date	Analyte Code/Test	Test Name/Rule	Result/Value	Max Level	Units	B_WSF_STATE_ASGN_ID	B_SAMPLING_POINT
BRAXAS UTILITIES	1840034	1512145	AC93585	05/28/2015		Radium-226 + Radium-228	5.32	5.00	pCi/L	EP002	TRT-TAP
BRAXAS UTILITIES	1840034	1512145	AC93585	05/28/2015		Gross Alpha - 1	15.9	15.00	pCi/L	EP002	TRT-TAP
BRAXAS UTILITIES	1840034	1512145	AC93585	05/28/2015		Radium-226 + Radium-228	5.32	5.00	pCi/L	EP002	TRT-TAP
LAZY HORSE RANCH WATER	1840024	1512109	AC93586	05/28/2015		Radium-226 + Radium-228	5.66	5.00	pCi/L	EP001	TRT-TAP
LAZY HORSE RANCH WATER	1840024	1512109	AC93586	05/28/2015		Radium-226 + Radium-228	5.66	5.00	pCi/L	EP001	TRT-TAP
GHILAND COURT	1840171	1512113	AC93594	05/28/2015		Radium-226 + Radium-228	7.79	5.00	pCi/L	EP001	TRT-TAP
GHILAND COURT	1840171	1512113	AC93584	05/28/2015		Radium-226 + Radium-228	7.79	5.00	pCi/L	EP001	TRT-TAP
XHELLE WSC	1540004	1512097	AC94365	06/02/2015		Radium-226 + Radium-228	16.14	5.00	pCi/L	EP001	TRT-TAP
XHELLE WSC	1540004	1512097	AC94365	06/02/2015		Gross Alpha - 1	22.9	15.00	pCi/L	EP001	TRT-TAP
XHELLE WSC	1540004	1512097	AC94365	06/02/2015		Radium-226 + Radium-228	16.14	5.00	pCi/L	EP001	TRT-TAP
JN PEDRO CANYON SUBDIVISI	2330011	1512125	AC94507	08/03/2015		Radium-226 + 0.5	6.45	5.00	pCi/L	EP001	TRT-TAP
JN PEDRO CANYON SUBDIVISI	2330011	1512125	AC94507	08/03/2015		Radium-226 + 0.5	6.45	5.00	pCi/L	EP001	TRT-TAP
JL COUNTRY NORTHWEST CH-	2270173	1512147	AC94844	08/08/2015		Gross Alpha - 1	15.4	15.00	pCi/L	EP002	TRT-TAP
LFURRIAS UTILITY BOARD	0240001	1537465	AD07741	08/21/2015	1045	Selenium	0.0588	0.05	mg/L	EP004	TRT-TAP
LEMAN COUNTY SUD	0420034	1548830	AD08477	09/24/2015	2950	Total Trihalomethanes	143	80	ug/L	DS01	DBP2-02
LEMAN COUNTY SUD	0420034	1548829	AD08478	09/24/2015	2950	Total Trihalomethanes	121	80	ug/L	DS01	DBP2-01