

PWS_0460214_AC_20181203_Analysis Report



Inorganic Chemistry Group
Environmental Sciences Branch
1100 West 49th Street, L639.1
Austin, Texas 78756

Branch Office
Phone: 512/776-7587 ♦ Fax: 512/776-7757

FAX TRANSMITTAL

RECEIVED

NOV 06 2019

To:
Steven Swierenga or Kasy Stinson
TCEQ/Safe Drinking Water Test
Phone: 512/239-6045
Fax: 512/239-6050

From:
Lorraine Archer
Inorganic Chemistry Group
Environmental Sciences Branch
Direct number: 512/776-2204

TCEQ
CENTRAL FILE ROOM

- Urgent
- For Review
- Please Comment
- Please Reply
- MCL Exceeded

Date sent: 12/3/18
Pages including coversheet: 2

SDWA SAMPLE EXCEEDING MCL FOR FLUORIDE

Lab ID #: AE46940

Water Supply ID #: TX 0460214 TCEQ Sample ID #: 1827607

Water Supply Name: NA

Entry Point: 002 Date Collected: 11/27/2018 11:29:48

Fluoride: _____ mg/L Primary (>4.0 mg/L)

Fluoride: 2.08 mg/L (>2.0 mg/L AND <4.0 mg/L)

URGENT MCL EXCEEDED



The information contained in this facsimile transmission is privileged, confidential, and intended only for the individual designated above. Others are hereby notified that disclosure, copying, distribution or taking action based on the content of this information is prohibited. If you received this facsimile in error please notify the sender immediately at the number provided above.

CONFIDENTIAL REPORTS

November 28, 2018

10:07 am

Checkin Receipt Worklist

TCEQ ID	Analysis Type: *SINGLE MINERAL					
1827487	Coll Dt/Time: 11/27/2018 12:27:03	Type: RT	Priority: N	Compl?: Y	AE46939	A
PWS #: TX1010082	Facility: EP001	Sample Pt: TRT-TAP	Loc: HS DISCHARGE LINE		DW	11/28/2018
Single Type: 1024	Free Cl:	Total Cl: 0.96	pH: 7.70	Collector: DEASHIA MCGASKEY	*SINGLE MINERAL 	
	Temp: 66.00					
1827607	Coll Dt/Time: 11/27/2018 11:29:48	Type: RT	Priority: N	Compl?: Y	AE46940	A
PWS #: TX0460214	Facility: EP002	Sample Pt: TRT-TAP	Loc: GST		DW	11/28/2018
Single Type: 1025	Free Cl: 1.18	Total Cl:	pH: 7.60	Collector: STAN PORTER	*SINGLE MINERAL 	
	Temp: 65.00					