

**Texas Department of State Health Services
Laboratory Services Section*****NITRATE
Analysis Report**

Submitter Identification Number: 0750003

CITY OF LA GRANGE
MOERBE, JANET
155 E COLORADO ST
LA GRANGE, TX 78945-2201

Date Reported: 03/21/2019

Lab Sample ID# : AE57979
Sample Priority : NORMAL
TCEQ ID#(s) : 1936013Water Source :
Entry Point(s) : EP002Date Collected : 03/12/2019 10:45
Date Received : 03/13/2019

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Nitrate as N ¹	0.22	mg/L	EPA 353.2	03/13/2019 12:46	HN

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(¹) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead HNGO on 03/19/2019

Texas Department of State Health Services
Laboratory Services Section

***ALL METALS**

Analysis Report

Submitter Identification Number: 0750003

CITY OF LA GRANGE
 MOERBE, JANET
 155 E COLORADO ST
 LA GRANGE, TX 78945-2201

Date Reported: 03/21/2019

Lab Sample ID# : AE58004
 Sample Priority : NORMAL
 TCEQ ID#(s) : 1916291

Water Source :
 Entry Point(s) : EP002

Date Collected : 03/12/2019 10:44
 Date Received : 03/13/2019

Sample Cond. : Acceptable

Analyte	Result	Unit	Method	Date/Time Analyzed	Analyst
Acidification	Completed		EPA 200.2	03/13/2019	PZ
pH Check	Completed		EPA 200.2	03/14/2019	PZ
Turbidity Screen	Completed		SM 2130B	03/14/2019	PZ
Visible Particles	Completed			03/14/2019	PZ
Total Hardness as CaCO3 by Calculation	128	mg/L	SM 2340B	03/15/2019	BF
Aluminum ¹	< 0.0200	mg/L	EPA 200.8	03/15/2019	IU
Antimony ¹	< 0.0010	mg/L	EPA 200.8	03/15/2019	IU
Arsenic ¹	0.0083	mg/L	EPA 200.8	03/15/2019	IU
Barium ¹	0.0606	mg/L	EPA 200.8	03/15/2019	IU
Beryllium ¹	< 0.00080	mg/L	EPA 200.8	03/15/2019	IU
Cadmium ¹	< 0.0010	mg/L	EPA 200.8	03/15/2019	IU
Calcium	39.5	mg/L	EPA 200.7	03/15/2019	BF
Chromium ¹	< 0.0100	mg/L	EPA 200.8	03/15/2019	IU
Copper ¹	0.0051	mg/L	EPA 200.8	03/15/2019	IU
Iron ¹	0.061	mg/L	EPA 200.7	03/15/2019	BF
Lead ¹	< 0.0010	mg/L	EPA 200.8	03/15/2019	IU
Magnesium ¹	7.22	mg/L	EPA 200.7	03/15/2019	BF
Manganese ¹	0.0262	mg/L	EPA 200.8	03/15/2019	IU
Mercury ¹	< 0.00040	mg/L	EPA 245.1	03/18/2019	BF
Nickel ¹	0.0011	mg/L	EPA 200.8	03/15/2019	IU
Potassium ¹	7.77	mg/L	EPA 200.7	03/15/2019	BF
Selenium ¹	0.0087	mg/L	EPA 200.8	03/15/2019	IU
Silver ¹	< 0.0100	mg/L	EPA 200.8	03/15/2019	IU
Sodium ¹	166	mg/L	EPA 200.7	03/15/2019	BF
Thallium ¹	< 0.00040	mg/L	EPA 200.8	03/15/2019	IU
Zinc ¹	< 0.0050	mg/L	EPA 200.8	03/15/2019	IU

Comments:

The test results on this report relate only to the sample identified on this report. The test results for analytes noted(1) meet all TNI (2009 Standard) requirements.

Authorized by Team Lead EBOYER on 03/20/2019