MONTHLY TOTAL ORGANIC CARBON REMOVAL REPORT (TOCMOR)

FOR SURFACE WATER OR GROUND WATER UNDER THE INFLUENCE OF SURFACE WATER SYSTEMS

PUBLIC WATER SYSTEM NAME: PWS ID No.:	City of Wes	t Tawakoni	1	PLANT NAME OR NUMBER:	1.5 MGD SWTP			100
	1160012		Plant ID No.: 20838	Month:	January	Year: _	2019	
Type of treatment:	Х	Conventional	Unconventional explain:					
lote: Systems are require	ed to run one T	OC Sample Set every month.	Additional space is provided for those syste	ms that do additional sa	mpling			

Test No.		Monthly TOC Sample Set				Step 1		Optional data		INDIVIDUAL SAMPLE
	Test Date	Raw Alkalinity	Raw TOC	Treated TOC	Actual % TOC Removed	Required % Removal	Step 1 Removal Ratio	Step 2 Required % Removal	Step 2 Removal Ratio	COMPLIANCE REMOVAL RATIO
		Enter th	ne Sample Se	t results	calculated	calculated from matrix	calculated			calculated
1	1/2	65	6.32	3.52	44.3	35	1.27			1.27
2										
3										
4										
5										
6										
7										
8										
9										
10										
11								RECEIVED		
12								COLIVE		
13										
14								AN 3 1 2020		
15										
16								TCEQ		
17							CENT	RAL FILE RO	IOM	
18										
19										Υ.
20										
21										
22					ļ					
23										
24				-						
25 26										
				-	-					
27					-					
28										
30			-		 					
31										
		65.00	6.00	2.50	44.00		1.07			
Avg		65.00	6.32	3.52	44.30		1.27			1.27
Max Min		65.00 65.00	6.32	3.52	44.30 44.30		1.27			1.27

TOTAL ORGANIC CARBON (TOC) REMOVAL SUMMARY

TOC Summary						
Raw Water Alkalinity	Raw Water TOC	Treated Water TOC	TOC % Removal	ACC # used	Compliance Ratio	
65	6.32	3.52	44.3	NA	1.27	

The same of the sa					Italio
65	6.32	3.52	44.3	NA	1.27
I certify that I am fi is true! complete, a Operator's Signature:	Submit the report	this report and that, to the best of my knowle Certificate No. and Grade: by the 10th of the month following MAS COMMISSION ON ENVIRONMENT PLY DIVISION/PUBLIC DRINKING WAT P.O. BOX 13087, AUSTIN, TEXAS 787 TOCMOR, Page 1 - Summary	WS0013351, B ng the reporting period to: AL QUALITY ER SECTION (MC-155)	CEIVED B 4 2019	February 1, 2019