

Mr. Darryl Spence
Senior Program Manager
Level 3 Communications, L.L.C.
1025 Eldorado Boulevard
Broomfield, Colorado 80021

Re: Permit by Rule Registration
Emergency Diesel Engine Generator
Houston, Harris County

Dear Mr. Spence:

This is in response to your Form PI-7 (Permit by Rule) concerning the proposed installation of an Emergency Diesel Generator at 2323 Bryan Street in Dallas County, and 520 Post Oak Boulevard and 806 Main Street in Houston, Harris County. We understand that the normal operating schedule for the office at each location is 8,760 hours per year. We further understand that each generator will be operated less than 150 hours per year and that each generator will be tested regularly. Based on your representation of the three emergency generators the routine emissions are as follow:

Two Harris County Generators: Caterpillar 3406C (Max Rating: 449 Brake-Horsepower):

Nitrogen Oxides (NO _x)	Carbon Monoxide (CO)	Volatile Organic Compounds (VOCs)	Particulate Matter (PM ₁₀)
5.69 lbs/hr 0.43 tons/yr	0.61 lbs/hr 0.05 tons/yr	0.06 lbs/hr 0.00 tons/yr	0.40 lbs/hr 0.03 tons/yr

One Dallas County Generator: Caterpillar 3406C (Max Rating: 518.8 Brake-Horsepower):

NO _x	CO	VOCs	PM ₁₀
-----------------	----	------	------------------

Mr. Darryl Spence
Page 2

Re: Permit by Rule Registration

7.63 lbs/hr 0.57 tons/yr	5.14 lbs/hr 0.39 tons/yr	0.06 lbs/hr 0.00 tons/yr	1.44 lbs/hr 0.11 tons/yr
-----------------------------	-----------------------------	-----------------------------	-----------------------------

After evaluation of the information which you have furnished, we have determined that your proposed installation is authorized under Title 30 Texas Administrative Code § 106.511(30 TAC § 116.511). if constructed and operated as described in your letter. This permit by rule was authorized by the Texas Natural Resource Conservation Commission (TNRCC) pursuant to 30 TAC Chapter 106.

A copy of the permit by rule in effect at the time of this registration is enclosed. You must construct, install, or modify facilities in accordance with the version of the permit(s) by rule in effect when construction, installation, or modification actually begins [see 30 TAC § 106.4(a)(5)]. After completion of construction, installation, or modification, the facility shall be operated in compliance with all the applicable conditions of the claimed permits by rule and 30 TAC § 106.4.

You are reminded that regardless of whether a permit is required, these facilities must be in compliance with all rules and regulations of the TNRCC and of the U.S. Environmental Protection Agency at all times.

Your cooperation in this matter is appreciated. If you have any questions concerning this permit by rule, please call Ms. Laterria May at (713) 767-3598 or write to the Texas Natural Resource Conservation Commission, Office of Permitting, Remediation, and Registration, Air Permits Division (MC-162), P.O. Box 13087, Austin, Texas 78711-3087.

Sincerely,

Anne M. Inman, Manager
Permit By Rule/General Operating Permits Section
Air Permits Division
Texas Natural Resource Conservation Commission

AMI/LYM/pll

Mr. Darryl Spence
Page 3

Re: Permit by Rule Registration

Enclosure

cc: Mr. David Miller, Section Manager, Air Pollution Control Program, Environmental
and Health
Services Department, City of Dallas, Dallas
Mr. Manuel Aguirre, P.E., Bureau Chief, Bureau of Air Quality Control, Health and
Human
Services Department, City of Houston, Houston
Mr. Rob Barrett, Director, Harris County Public Health and Environmental Services,
Pollution
Control Department, Pasadena
Mr. Arturo Blanco, Air Program Manager, Region 12 - Houston
Mr. Tony Walker, Air Program Manager, Region 4 - Arlington

Record Number: 87084

bcc: File Copy

AIR PERMITS DIVISION MC-162

MR DARRYL SPENCE
SENIOR PROGRAM MANAGER
LEVEL 3 COMMUNICATIONS LLC
1025 ELDORADO BLVD
BROOMFIELD CO 80021