



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

24 May 2021

Jeff Brennan  
Jeff Brennan  
16930 CR 127  
Pearland, TX 77581

### **Childrens Choice Learning Center - WQP**

Enclosed are the results of analyses for samples received by the laboratory on 13-May-21 09:17. The analytical data provided relates only to the samples as received in this laboratory report.

ELI certifies that all results are NELAP compliant and performed in accordance with the referenced method except as noted in the Case Narrative or as noted with a qualifier. Any reproductions of this laboratory report should be in full and only with the written authorization from the client.

The total number of pages in this report is 10

Thank you for selecting ELI for your analytical needs. If you have any questions regarding this report, please contact us.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Kyle Chernosky'.

Kyle Chernosky For Monica Smith  
Client Services Representative



Certificate No: T104704265-20-18



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

#### ANALYTICAL REPORT FOR SAMPLES

Sample ID		Laboratory ID	Matrix	Date Sampled	Date Received
EWQP	12402 HWY 6 FRESNO	21E1992-01	Water	13-May-21 08:20	13-May-21 09:17
EWQP	RAW WELL	21E1992-02	Water	13-May-21 08:16	13-May-21 09:17
DSTWQP	HOSEBIB ON NW SIDE OF BUILDING	21E1992-03	Water	13-May-21 08:24	13-May-21 09:17

Envirodyne Laboratories, Inc.

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

Client: Jeff Brennan  
Project: Childrens Choice Learning Center - WQP  
Work Order: 21E1992  
PWS ID: TX0790424

Reported:  
24-May-21 11:35

12402 HWY 6 FRESNO  
21E1992-01 (Water) Sampled: 13-May-21 08:20

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Analyst	Notes
---------	--------	--------------------	-------	----------	-------	----------	----------	--------	---------	-------

Envirodyne Laboratories, Inc.

Field Analysis

pH	7.26		SU	1	B1E1582	13-May-21	13-May-21 08:20	SM4500H+ B	KLC	
Temperature	23.0	0.0	°C	1	B1E1582	13-May-21	13-May-21 08:20	SM2550 B	KLC	

Wet Chemistry

Alkalinity (m) as CaCO <sub>3</sub>	276	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Alkalinity (p) as CaCO <sub>3</sub>	<20.0	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Total Alkalinity as CaCO <sub>3</sub>	276	20.0	mg/L	1	[CALC]	20-May-21	20-May-21 11:15	[CALC]	SNG	
Chloride	440	30.0	mg/L	10	B1E1910	17-May-21	17-May-21 09:56	SM4500 Cl-B	SNG	
Conductivity at 25 C	1730	60	umho/cm	2	B1E1907	17-May-21	17-May-21 12:40	SM2510 B	SNG	
Sulfate	11.8	2.00	mg/L	1	B1E1912	18-May-21	18-May-21 09:35	ASTM D516-07	SNG	
TDS	1110	10.0	mg/L	1	B1E2319	19-May-21	19-May-21 17:17	SM2540 C	SMR	

Total Metals by ICP

Calcium	69.3	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Total Hardness as CaCO <sub>3</sub>	245	13.2	mg/L	1	[CALC]	15-May-21	19-May-21 12:16	SM 2340B	JPC	
Iron	1.10	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Magnesium	17.5	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Manganese	0.145	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Sodium	257	4.0	mg/L	2	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	

Envirodyne Laboratories, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

### RAW WELL

21E1992-02 (Water) Sampled: 13-May-21 08:16

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Analyst	Notes
---------	--------	--------------------	-------	----------	-------	----------	----------	--------	---------	-------

### Envirodyne Laboratories, Inc.

#### Field Analysis

pH	7.20		SU	1	B1E1582	13-May-21	13-May-21 08:16	SM4500H+ B	KLC	
Temperature	23.0	0.0	°C	1	B1E1582	13-May-21	13-May-21 08:16	SM2550 B	KLC	

#### Wet Chemistry

Alkalinity (m) as CaCO <sub>3</sub>	268	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Alkalinity (p) as CaCO <sub>3</sub>	<20.0	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Total Alkalinity as CaCO <sub>3</sub>	268	20.0	mg/L	1	[CALC]	20-May-21	20-May-21 11:15	[CALC]	SNG	
Chloride	375	30.0	mg/L	10	B1E1910	17-May-21	17-May-21 09:56	SM4500 Cl-B	SNG	
Conductivity at 25 C	1650	60	umho/cm	2	B1E1907	17-May-21	17-May-21 12:40	SM2510 B	SNG	
Sulfate	4.34	2.00	mg/L	1	B1E1912	18-May-21	18-May-21 09:35	ASTM D516-07	SNG	
TDS	920	10.0	mg/L	1	B1E2319	19-May-21	19-May-21 17:17	SM2540 C	SMR	

#### Total Metals by ICP

Calcium	68.6	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Total Hardness as CaCO <sub>3</sub>	243	13.2	mg/L	1	[CALC]	15-May-21	19-May-21 12:16	SM 2340B	JPC	
Iron	0.988	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Magnesium	17.4	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Manganese	0.151	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Sodium	239	4.0	mg/L	2	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	

Envirodyne Laboratories, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Kyle Chernosky For Monica Smith, Client Services Representative

Page 4 of 10



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

Client: Jeff Brennan  
Project: Childrens Choice Learning Center - WQP  
Work Order: 21E1992  
PWS ID: TX0790424

Reported:  
24-May-21 11:35

**HOSEBIB ON NW SIDE OF BUILDING**  
**21E1992-03 (Water) Sampled: 13-May-21 08:24**

Analyte	Result	Reporting Limit	Units	Dilution	Batch	Prepared	Analyzed	Method	Analyst	Notes
---------	--------	--------------------	-------	----------	-------	----------	----------	--------	---------	-------

**Envirodyne Laboratories, Inc.**

**Field Analysis**

pH	7.38		SU	1	B1E1582	13-May-21	13-May-21 08:24	SM4500H+ B	KLC	
Temperature	23.1	0.0	°C	1	B1E1582	13-May-21	13-May-21 08:24	SM2550 B	KLC	

**Wet Chemistry**

Alkalinity (m) as CaCO <sub>3</sub>	264	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Alkalinity (p) as CaCO <sub>3</sub>	<20.0	20.0	mg/L	1	B1E2524	20-May-21	20-May-21 11:15	SM 2320 B	SNG	
Total Alkalinity as CaCO <sub>3</sub>	264	20.0	mg/L	1	[CALC]	20-May-21	20-May-21 11:15	[CALC]	SNG	
Chloride	390	30.0	mg/L	10	B1E1910	17-May-21	17-May-21 09:56	SM4500 Cl-B	SNG	
Conductivity at 25 C	1850	60	umho/cm	2	B1E1907	17-May-21	17-May-21 12:40	SM2510 B	SNG	
Sulfate	5.80	2.00	mg/L	1	B1E1912	18-May-21	18-May-21 09:35	ASTM D516-07	SNG	
TDS	926	10.0	mg/L	1	B1E2319	19-May-21	19-May-21 17:17	SM2540 C	SMR	

**Total Metals by ICP**

Calcium	68.6	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Total Hardness as CaCO <sub>3</sub>	243	13.2	mg/L	1	[CALC]	15-May-21	19-May-21 12:16	SM 2340B	JPC	
Iron	1.08	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Magnesium	17.4	2.00	mg/L	1	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	
Manganese	0.146	0.0050	mg/L	1	B1E1851	15-May-21	18-May-21 12:12	EPA 200.7	JPC	
Sodium	249	4.0	mg/L	2	B1E1851	15-May-21	19-May-21 12:16	EPA 200.7	JPC	

Envirodyne Laboratories, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

**Wet Chemistry - Quality Control**  
**Envirodyne Laboratories, Inc.**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
Batch B1E1907 - Inorganics										
Blank (B1E1907-BLK2)				Prepared & Analyzed: 17-May-21						
Conductivity at 25 C	<30	30	umho/cm							
Duplicate (B1E1907-DUP1)				Source: 21E1525-03 Prepared & Analyzed: 17-May-21						
Conductivity at 25 C	827	30	umho/cm	826				0.121	20	
Reference (B1E1907-SRM1)				Prepared & Analyzed: 17-May-21						
Conductivity at 25 C	181		umho/cm	180		101	0-200			
Batch B1E1910 - Inorganics										
Blank (B1E1910-BLK1)				Prepared & Analyzed: 17-May-21						
Chloride	<3.0	3.0	mg/L							
LCS (B1E1910-BS1)				Prepared & Analyzed: 17-May-21						
Chloride	106		mg/L	100		106	90-110			
Matrix Spike (B1E1910-MS1)				Source: 21E1995-01 Prepared & Analyzed: 17-May-21						
Chloride	64.0	6.0	mg/L	20.0	43.0	105	80-120			
Matrix Spike Dup (B1E1910-MSD1)				Source: 21E1995-01 Prepared & Analyzed: 17-May-21						
Chloride	64.0	6.0	mg/L	20.0	43.0	105	80-120	0.00	20	
Batch B1E1912 - Inorganics										
Blank (B1E1912-BLK2)				Prepared & Analyzed: 18-May-21						
Sulfate	<2.00	2.00	mg/L							

Envirodyne Laboratories, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

**Wet Chemistry - Quality Control**  
**Envirodyne Laboratories, Inc.**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

**Batch B1E1912 - Inorganics**

**LCS (B1E1912-BS1)**

Prepared & Analyzed: 18-May-21

Sulfate	20.4		mg/L	20.0		102	90-110			
---------	------	--	------	------	--	-----	--------	--	--	--

**Matrix Spike (B1E1912-MS1)**

**Source: 21E1556-02**

Prepared & Analyzed: 18-May-21

Sulfate	22.5	2.00	mg/L	20.0	ND	112	80-120			
---------	------	------	------	------	----	-----	--------	--	--	--

**Matrix Spike Dup (B1E1912-MSD2)**

**Source: 21E1556-02**

Prepared & Analyzed: 18-May-21

Sulfate	22.4	2.00	mg/L	20.0	ND	112	80-120	0.445	20	
---------	------	------	------	------	----	-----	--------	-------	----	--

**Batch B1E2319 - Inorganics**

**Blank (B1E2319-BLK1)**

Prepared & Analyzed: 19-May-21

TDS	<10.0	10.0	mg/L							
-----	-------	------	------	--	--	--	--	--	--	--

**Duplicate (B1E2319-DUP1)**

**Source: 21E2209-01**

Prepared & Analyzed: 19-May-21

TDS	172	10.0	mg/L		184			6.74	20	
-----	-----	------	------	--	-----	--	--	------	----	--

**Batch B1E2524 - Inorganics**

**Blank (B1E2524-BLK1)**

Prepared & Analyzed: 20-May-21

Alkalinity (m) as CaCO <sub>3</sub>	<20.0	20.0	mg/L							
Alkalinity (p) as CaCO <sub>3</sub>	<20.0	20.0	"							

**LCS (B1E2524-BS1)**

Prepared & Analyzed: 20-May-21

Alkalinity (m) as CaCO <sub>3</sub>	46.0		mg/L	50.0		92.0	90-110			
Alkalinity (p) as CaCO <sub>3</sub>	54.0		"	50.0		108	90-110			

Envirodyne Laboratories, Inc.

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

### Wet Chemistry - Quality Control

### Envirodyne Laboratories, Inc.

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

#### Batch B1E2524 - Inorganics

Duplicate (B1E2524-DUP1)	Source: 21E2199-02			Prepared & Analyzed: 20-May-21						
Alkalinity (m) as CaCO <sub>3</sub>	152	20.0	mg/L		148			2.67	20	
Alkalinity (p) as CaCO <sub>3</sub>	<20.0	20.0	"		<20.0			0	20	

Envirodyne Laboratories, Inc.

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Kyle Chernosky For Monica Smith, Client Services Representative





Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

**Total Metals by ICP - Quality Control**  
**Envirodyne Laboratories, Inc.**

Analyte	Result	Reporting Limit	Units	Spike Level	Source Result	%REC	%REC Limits	RPD	RPD Limit	Notes
---------	--------	--------------------	-------	----------------	------------------	------	----------------	-----	--------------	-------

**Batch B1E1851 - Metals - EPA 200.2**

**Blank (B1E1851-BLK1)**

Prepared: 15-May-21 Analyzed: 19-May-21

Calcium	<2.00	2.00	mg/L
Sodium	<2.0	2.0	"
Iron	<0.0050	0.0050	"
Manganese	<0.0050	0.0050	"
Magnesium	<2.00	2.00	"

**LCS (B1E1851-BS1)**

Prepared: 15-May-21 Analyzed: 19-May-21

Calcium	20.3		mg/L	20.0		102	85-115
Sodium	20.4		"	20.0		102	85-115
Manganese	259		ug/L	250		104	85-115
Iron	213		"	250		85.2	85-115
Magnesium	20.3		mg/L	20.0		101	85-115

**Matrix Spike (B1E1851-MS1)**

Source: 21E2167-01

Prepared: 15-May-21 Analyzed: 19-May-21

Calcium	92.9	4.00	mg/L	40.0	52.2	102	70-130
Iron	1.26	0.0100	"	1.00	0.330	93.4	70-130
Magnesium	45.2	4.00	"	40.0	4.22	102	70-130
Manganese	1.00	0.0100	"	1.00	0.0286	97.1	70-130
Sodium	68.8	4.0	"	40.0	27.6	103	70-130

**Matrix Spike Dup (B1E1851-MSD1)**

Source: 21E2167-01

Prepared: 15-May-21 Analyzed: 18-May-21

Iron	1.28	0.0100	mg/L	1.00	0.330	95.0	70-130	1.26	20
Magnesium	45.1	4.00	"	40.0	4.22	102	70-130	0.133	20
Calcium	92.0	4.00	"	40.0	52.2	99.3	70-130	0.974	20
Manganese	0.998	0.0100	"	1.00	0.0286	96.9	70-130	0.200	20
Sodium	68.2	4.0	"	40.0	27.6	101	70-130	0.847	20

Envirodyne Laboratories, Inc.

The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.

Kyle Chernosky For Monica Smith, Client Services Representative



Envirodyne Laboratories, Inc  
11011 Brooklet Dr., # 230  
Houston, TX 77099  
281.568.7880 Phone  
www.envirodyne.com

**Client:** Jeff Brennan  
**Project:** Childrens Choice Learning Center - WQP  
**Work Order:** 21E1992  
**PWS ID:** TX0790424

**Reported:**  
24-May-21 11:35

### Notes and Definitions

DET Analyte DETECTED  
ND Analyte NOT DETECTED at or above the reporting limit  
NR Not Reported  
dry Sample results reported on a dry weight basis  
RPD Relative Percent Difference  
CLT Client Representative

Envirodyne Laboratories, Inc.

A handwritten signature in blue ink, appearing to read 'Kyle Chernosky'.

*The results in this report apply to the samples analyzed in accordance with the chain of custody document. This analytical report must be reproduced in its entirety.*

Kyle Chernosky For Monica Smith, Client Services Representative



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY  
WATER QUALITY PARAMETER MONITORING FORM 20679

Completed by PWS (or Agent)

Completed by Laboratory

PWS Name:	CHILDRENS CHOICE LEARNING CENTER	Laboratory Name:	Envirodyne Laboratories, Inc.
PWS ID#:	TX 0790424	TCEQ Lab ID #:	TX-288
PWS Address:	12402 HWY 6, FRESNO, TX 77545	Laboratory Address:	11011 Brooklet Dr #230
PWS Contact:	JEFF BRENNAN	Laboratory Address:	Houston, TX 77099
PWS Contact Phone #:	281-615-8744	Laboratory Contact:	Laura Bonjonia
Inhibitor or Stabilizer Used (v):	Phosphate	Silica	Calcium carbonate
TREATMENT	Alkalinity Dosage Rate:	Inhibitor Dosage Rate:	Laboratory Contact Phone #:

Sample Information

Sample Type (v):	<input checked="" type="checkbox"/> Compliance	<input type="checkbox"/> Non-compliance
Sample Collector (v):	Public Water System	<input checked="" type="checkbox"/> Accredited Lab
3rd Party Contractor --> LAB ID	AL TX-288	
Temperature and pH (Y or N):	Y	Were temperature and pH measured in the field within 15 minutes of sample collection?

Parameters Requested: Analyses are required for the parameters checked. \* If inhibitors containing phosphate or silica are used, then these parameters should also be analyzed depending on which is in use.

Facility ID (e.g. DS01, PBCU001)	Sample Point ID (e.g. DSTWQP, EWQP)	Sample Location	Sample Collection		Field Measurements		Replacement? (v)	Original Sample ID #	Original Sample Date (MMDDYY)	Lab Sample ID	Alkalinity (1927)	Calcium (1919)	Chloride (1017)	Conductivity (1064)	Hardness (1915)	Iron (1028)	Manganese (1032)	Sodium (1052)	Sulfate (1055)	TDS (1930)	O-Phosphate (1044) *	Silica (1049) *
			Date (MMDDYY)	Time - 24 hr (HHMM)	pH	Temp (°C)																
✓ PBCU001	EWQP	12402 HWY 6, FRESNO	5-13-21	0820	7.26	23.0				21E1992-01	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
✓ PBCU001	EWQP	Raw Well	↓	0816	7.20	23.0				21E1992-02	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
✓ DS01	DSTWQP	Hosebib on NW side of building	↓	0824	7.38	23.1				21E1992-03	✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		
											✓	✓	✓	✓	✓	✓	✓	✓	✓	✓		

I acknowledge that information on this form is true and correct and sites selected for sampling follow the instructions in the TCEQ Monitoring and Sample Collection Guidance for Water Quality Parameters. This includes, but not limited to the measurement of pH and temperature immediately upon collection. Falsification of this form or tampering with water samples is a crime punishable under state and/or federal law. (Texas Penal Code, Title 8, Chapter 37.10)

Name of Authorized PWS Representative (Print)	Signature	Organization	Date	Rejection Code (if applicable):	Actual / Corrected sample temperature:
JEFF BRENNAN	Jeffrey H. Brennan	CHILDREN'S CHOICE	5-13-21	Date & Time of Sample Preservation (Acidified): 5/13/21 @ 1655	Thermometer ID #: IR214
Chain of Custody	Relinquished By (Signature)	Date/Time:	Relinquished By Courier (Signature)	Date/Time:	Laboratory Comments:
	ICAD	5-13-21/0917			
	Received By Courier (Signature)	Date/Time:	Received By Lab (Signature)	Date/Time:	
			J-H-gel	5-13-21 0917	