

Public Water System Sample Collection Analysis Report

Public Water System ID # TX1120014

Collection Date 2/20/2020

Report to:

GAFFORD CHAPEL WSC

PO BOX 1160

SULPHUR SPRINGS, TX 75483-1160

Water analyses are required by law (30 TAC §290, THSC §341.0315). I acknowledge that the sampling technician has been accompanied during sampling and that the sample has been collected from the correct location indicated on this form. Water systems are responsible for all laboratory fees. Falsification of this form or tampering with water samples is a crime punishable under state and federal law. Refusing to sample, including refusing to sign this form, will result in monitoring and reporting violation(s), possible enforcement, and fines.



DANIEL ROMANS

WATER SYSTEM REPRESENTATIVE



CHRISTINA NIXON

SAMPLING TECHNICIAN

SAMPLING LOCATION											
FACILITY ID: EP001			FACILITY LOCATION: CR 4784 - RIDGEWAY PLANT					LAT: N 33.182418			
SAMPLE POINT: TRT-TAP			SAMPLE LOCATION: IN PH					LONG: W -95.778352			
TAP FLUSHING - START: 10:22			FREE CHLORINE RESIDUAL: 3.05 mg/L			TEMPERATURE: 60 °F					
END: 10:43			TOTAL CHLORINE RESIDUAL: -- mg/L			pH: 8.6					
TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION			SAMPLE PERIOD	LAB	SAMPLE TYPE	PRIOR -ITY	COMPLI -ANCE
10:43:05	2002661	VOC	2 - 40 ML GLASS & FIELD BL	ASCORBIC ACID, HCl PH<2, COOL 4C			YR2020	LCRA	RT	N	YES
COMMENTS: LOT DHL 01/28/20 EXP 04/28/20											
10:43:18	2027780	CYANIDE	1 L PLASTIC OR GLASS	ASCORBIC ACID, NaOH PH>12, COOL 4C			3Y2020	LCRA	RT	N	YES
10:43:19	2036309	NITRATE	100 ML PLASTIC OR GLASS	COOL 4C			YR2020	LCRA	RT	N	YES

SAMPLING LOCATION											
FACILITY ID: EP002			FACILITY LOCATION: HWY 11 / CR 4724					LAT: N 33.20272			
SAMPLE POINT: TRT-TAP			SAMPLE LOCATION: MT ZION PLANT - STANDPIPE					LONG: W -95.836377			
TAP FLUSHING - START: 10:03			FREE CHLORINE RESIDUAL: 1.65 mg/L			TEMPERATURE: 53 °F					
END: 10:15			TOTAL CHLORINE RESIDUAL: -- mg/L			pH: 8.9					
TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION			SAMPLE PERIOD	LAB	SAMPLE TYPE	PRIOR -ITY	COMPLI -ANCE
10:15:12	2004861	VOC	2 - 40 ML GLASS & FIELD BL	ASCORBIC ACID, HCl PH<2, COOL 4C			YR2020	LCRA	RT	N	YES
COMMENTS: LOT DHL 01/28/20 EXP 04/28/20											
10:15:23	2029517	CYANIDE	1 L PLASTIC OR GLASS	ASCORBIC ACID, NaOH PH>12, COOL 4C			3Y2020	LCRA	RT	N	YES
10:15:24	2039706	NITRATE	100 ML PLASTIC OR GLASS	COOL 4C			YR2020	LCRA	RT	N	YES

SAMPLING LOCATION											
FACILITY ID: DS01			FACILITY LOCATION: DISTRIBUTION SYSTEM					LAT: N 33.139212			
SAMPLE POINT: DBP2-01			SAMPLE LOCATION: 145 CR 4701, SULPHUR SPRINGS					LONG: W -95.643017			
TAP FLUSHING - START: 11:15			FREE CHLORINE RESIDUAL: -- mg/L			TEMPERATURE: 56 °F					
END: 11:23			TOTAL CHLORINE RESIDUAL: 2.82 mg/L			pH: 7.5					
TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION			SAMPLE PERIOD	LAB	SAMPLE TYPE	PRIOR -ITY	COMPLI -ANCE
11:24:02	2049861	DBP2	2-40 ML CLEAR/2-60 ML AMBE	Na2S2O3/NH4Cl, COOL 4C, DARK			1Q2020	LCRA	RT	N	YES



FOR MORE INFORMATION: Public water systems may view their water system information including sampling schedules and sample results by visiting the State of Texas Drinking Water Watch website at the following address: <http://dww2.tceq.texas.gov/DWW/>

Regulations governing sample scheduling and collection are available upon request from the Public Drinking Water Section of the Texas Commission on Environmental Quality. ☐ Phone: (512) 239-4691 ☐ Email: PWSCHEM@tceq.texas.gov Website: <http://www.tceq.texas.gov>

Lab fee schedule can be found at the following address: www.tceq.texas.gov/drinkingwater/chemicals/sample_collection/costestimate#Lab-fees

Date report printed 2/20/2020

Page 1 of 2

Public Water System Sample Collection Analysis Report

Public Water System ID # TX1120014

Collection Date 2/20/2020

Report to:

GAFFORD CHAPEL WSC

PO BOX 1160

SULPHUR SPRINGS, TX 75483-1160

Water analyses are required by law (30 TAC §290, THSC §341.0315). I acknowledge that the sampling technician has been accompanied during sampling and that the sample has been collected from the correct location indicated on this form. Water systems are responsible for all laboratory fees. Falsification of this form or tampering with water samples is a crime punishable under state and federal law. Refusing to sample, including refusing to sign this form, will result in monitoring and reporting violation(s), possible enforcement, and fines.



DANIEL ROMANS

WATER SYSTEM REPRESENTATIVE



CHRISTINA NIXON

SAMPLING TECHNICIAN

SAMPLING LOCATION

FACILITY ID: DS01

FACILITY LOCATION: DISTRIBUTION SYSTEM

LAT: N 33.165415

SAMPLE POINT: DBP2-02

SAMPLE LOCATION: 6839 HWY 11 W, SULPHUR SPRINGS

LONG: W -95.696903

TAP FLUSHING - START: 10:52

FREE CHLORINE RESIDUAL: 0.59 mg/L

TEMPERATURE: 57 °F

END: 11:07

TOTAL CHLORINE RESIDUAL: -- mg/L

pH: 8.7

TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION	SAMPLE PERIOD	SAMPLE LAB	SAMPLE TYPE	PRIOR -ITY	COMPLI -ANCE
11:08:05	2049862	DBP2	2-40 ML CLEAR/2-60 ML AMBE	Na2S2O3/NH4Cl, COOL 4C, DARK	1Q2020	LCRA	RT	N	YES

