

STANDARD AIR PERMIT APPLICATION ENGIE FLEXIBLE GENERATION NA LLC – ROBSTOWN, TX

JULY 2024

SUBMITTED BY: SUBMITTED TO:



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

ENGIE Flexible Generation NA LLC

1360 Post Oak Blvd, Suite 400 Houston, TX 77056

Texas Commission on Environmental Quality

Air Permits Division 12100 Park 35 Circle, MC-163 Austin, TX 78753





TABLE OF CONTENTS

Sec	Section Name Page Number				
1.	INTR	ODUCT	ION AND APPLICATION ORGANIZATION	. 1-1	
	1.1		TIVE SUMMARY		
	1.2		MENT SUBMISSION		
	1.3		MENT ORGANIZATION		
2.			D PROCESS DESCRIPTIONS		
3.					
4.	REGU		Y APPLICABILITY ANALYSIS		
	4.1	STAND	PARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES		
		4.1.1	40 CFR Part 60, Subpart A – General Provisions	. 4-1	
		4.1.2	40 CFR Part 60, Subpart GG – Standards of Performance for Stationary Gas Turbines	<i>1</i> _1	
		4.1.3	40 CFR Part 60, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines		
		4.1.4	40 CFR Part 60, Subpart TTTTa – Standards of Performance for Greenhouse Gas Emissions for Modified Coal-Fired Steam Electric Generating Units and New Construction and Reconstruction Stationary Combustion Turbine Electric		
			Generating Units		
	4.2	NATIO	NAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS		
		4.2.1 4.2.2	40 CFR Part 63, Subpart A – General Provisions		
	4.3	CROSS	STATE AIR POLLUTION RULE		
	4.4		AIN PROGRAM		
	4.5		OF TEXAS AIR QUALITY REGULATIONS		
	1.5	4.5.1	30 TAC Chapter 101 – General Air Quality Rules		
		4.5.2	30 TAC Chapter 111 – Control of Air Pollution from Visible Emissions and Particulate Matter		
		4.5.3	30 TAC Chapter 112 – Control of Air Pollution from Sulfur Compounds		
		4.5.4	30 TAC Chapter 113 – Standards of Performance for Hazardous Air Pollutants and for Designated Facilities and Pollutants	4-8	
		4.5.5	30 TAC Chapter 115 – Control of Air Pollution from Volatile Organic Compounds	4-8	
		4.5.6	30 TAC Chapter 116 – Control of Air Pollution by Permits for New Construction or		
		4.5.7	Modification		
		4.5.7 4.5.8	30 TAC Chapter 117 – Control of Air Pollution From Nitrogen Compounds		
		4.5.9	30 TAC Chapter 122 – Federal Operating Permits Program		
5.	SUM	MARY (DF EMISSIONS AND EMISSIONS CALCULATIONS	. 5-1	

LIST OF FIGURES

Figure 3-1 Process Flow Diagram	. 3-2
Figure 3-2 Area Map	.3-3
Figure 3-3 Plot Plan	.3-4

ı	ICT	OE	TΔR	IFC
	131	l JE	IAD	1 5

Table 5-1 Potential to Emit for Natural Gas-Fired Turbines	5_	-
Table 3-1 Potential to enni 101 Natural Gas-Fired Turbines	၁-	'2

LIST OF APPENDICES

Appendix A - Texas Commission on Environmental Quality Forms

Appendix B - Standard Permit For Electric Generating Units Applicability

Appendix C - Equipment Specification Sheets



1. INTRODUCTION AND APPLICATION ORGANIZATION

1.1 EXECUTIVE SUMMARY

ENGIE Flexible Generation NA LLC (ENGIE) retained ALL4 LLC (ALL4) to prepare this Standard Air Permit Application (Application) for the installation and operation of three natural gas-fired simple cycle turbines with Selective Catalytic Reduction (SCR) controls (Project). The turbines will be located at the Perseus Facility (Site), which will be located at CO Rd 48, Robstown, TX 78380 in Nueces County. ENGIE is seeking authorization of the Project by claiming the Air Quality standard permit for Electric Generating Units (EGUs) under 30 Texas Administrative Code (TAC) Chapter 116, Subchapter F.

1.2 DOCUMENT SUBMISSION

This Application is being submitted electronically through the State of Texas Environmental Electronic Reporting System (STEERS) in accordance with the provisions of 30 TAC Chapter 116, Subchapter F. A PI-1S form is being submitted with this application in order to register this standard permit.

1.3 DOCUMENT ORGANIZATION

The required components of the Application are provided in the following sections and appendices:

- Section 2: Project and Process Descriptions
- Section 3: Figures
- Section 4: Regulatory Applicability Analysis
- Section 5: Summary of Emissions and Emissions Calculations
- Appendix A: Texas Commission on Environmental Quality Forms
 - TCEQ 20833: PI-1S Registration for Air Standard Permit (06/21)
 - o TCEQ 10400: Core Data Form (02/21)
 - o TCEQ 10197: Table 31 Combustion Turbines (Revised 07/16)
- Appendix B: Standard Permit for Electric Generating Units Applicability
- Appendix C: Equipment Specification Sheets



2. PROJECT AND PROCESS DESCRIPTIONS

ENGIE is proposing to install and operate three natural gas-fired simple cycle turbines. The turbines are Siemens model SGT6-8000H with a total nameplate capacity of 930 megawatts (MW). These turbines are electric generating units (EGUs) that will be used to generate electricity to be sold to the electric grid.

The turbines are equipped with selective catalytic reduction (SCR) to control emissions of nitrogen oxides (NO_x). ENGIE is requesting to limit operational hours of the turbines to 2,000 hours per 12-month rolling period so that their potential to emit (PTE) for regulated New Source Review (NSR) pollutants is below the prevention of significant deterioration (PSD) major source thresholds outlined in 40 CFR \S 52.21(b)(1)(i)(b).


Once permitted, the turbines will operate for the Emergency Response Service (ERS) managed by the Electric Reliability Council of Texas (ERCOT). ERCOT is the non-profit corporation that oversees the Texas power grid. As such, ERCOT selects qualified loads and generators to make themselves available for deployment in a power grid emergency.


The turbines will also operate in non-emergency situations, including but not limited to, participation in the 4 Coincident Peak (4CP) program, demand response program participation, and electrical power generation for the Site.




3. FIGURES

The Site will be located at CO Rd 48, Robstown, TX 78380. The turbine operation is depicted in a process flow diagram in Figure 3-1. The immediate surrounding area of the Site is depicted in an area map in Figure 3-2. The Site boundary and affected emissions points associated with the Project are depicted in a plot plan in Figure 3-3.









4. REGULATORY APPLICABILITY ANALYSIS

4.1 STANDARDS OF PERFORMANCE FOR NEW STATIONARY SOURCES

The United States Environmental Protection Agency (U.S. EPA) has promulgated standards of performance for specific new, reconstructed, and modified sources, otherwise known as Standards of Performance for New Stationary Sources (NSPS), which are codified at 40 CFR Part 60. Potentially applicable NSPS are discussed in the following subsections.

4.1.1 40 CFR Part 60, Subpart A – General Provisions

The provisions of 40 CFR Part 60, Subpart A apply to the owner or operator of any stationary source subject to an NSPS. These general provisions include recordkeeping, reporting, monitoring, and testing requirements. Because the Project will be subject to a NSPS, ENGIE will be required to comply with the applicable requirements of 40 CFR Part 60, Subpart A.

4.1.2 40 CFR Part 60, Subpart GG – Standards of Performance for Stationary Gas Turbines

The requirements of 40 CFR Part 60, Subpart GG (Standards of Performance for Stationary Gas Turbines) apply to all stationary gas turbines with a heat input at peak load equal to or greater than 10.7 gigajoules [10.7 million British thermal units (MMBtu) per hour], based on the lower heating value of the fuel fired, which commence construction, modification, or reconstruction after October 3, 1977, as specified in 40 CFR §60.330. Subpart GG is potentially applicable to the three proposed turbines because each turbine has a nameplate capacity of 310 MW, which is equivalent to approximately 3,001.9 MMBtu/hr, and is being constructed after October 3, 1977. However, the turbines are exempt from the requirements of Subpart GG because they are subject to 40 CFR Part 60, Subpart KKKK, per 40 CFR §60.4305(b). Applicability of Subpart KKKK is discussed in Section 4.1.3.

4.1.3 40 CFR Part 60, Subpart KKKK – Standards of Performance for Stationary Combustion Turbines

40 CFR Part 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) establishes emissions standards and compliance schedules for the control of emissions from stationary combustion turbines that commenced construction, modification, or reconstruction after February 18, 2005. Per 40



CFR §60.4305(a), the three proposed turbines are subject to Subpart KKKK because each turbine has a nameplate capacity of 310 MW, which is equivalent to approximately 3,001.9 MMBtu/hr, and is being constructed after February 18, 2005. ENGIE will comply with the applicable requirements of 40 CFR Part 60, Subpart KKKK.

The proposed turbines will be subject to the Subpart KKKK emissions standards for NO_X and sulfur dioxide (SO_2) . The proposed turbines must comply with the following NO_X and SO_2 emissions standards for a new turbine firing natural gas with a heat input at peak load of greater than 850 MMBtu/hr:

- 40 CFR §60.4320 and Table 1 NO_X
 - o 15 ppm at 15% O₂ (natural gas), or
 - o 0.43 pounds per megawatt hour (lb/MWh) (natural gas) of useful output
- 40 CFR §60.4330(a)(1) and (2) SO₂
 - o 0.90 lb/MWh gross output, or
 - o 0.060 lb/MMBtu heat input

ENGIE will demonstrate compliance with 40 CFR Part 60, Subpart KKKK requirements via several methods. For NO_X emissions limits, ENGIE will demonstrate compliance with the NO_X emissions limit per 40 CFR $\S60.4335(b)$ and $\S60.4340(b)$ with a NO_X continuous emissions monitoring system (CEMS). The use of natural gas to fire the proposed turbines will ensure that the SO_2 emissions standards are met and, per 40 CFR $\S60.4365$, ENGIE will use natural gas supplier data to document the sulfur content of the fuel. Per 40 CFR $\S60.4400$, ENGIE will conduct the necessary initial and subsequent NO_X performance tests and submit the necessary reports required per 40 CFR Part 60, Subpart KKKK. In addition, ENGIE will comply with the following applicable Subpart KKKK reporting and recordkeeping requirements and provisions:

- 40 CFF §60.4340(b) NO_X monitoring requirements
- 40 CFR §60.4345(b) NO_X CEMS Requirements
- 40 CFR §60.4350(b) NO_X CEMS recordkeeping requirements
- 40 CFR §60.4365(a) Fuel recordkeeping requirements
- 40 CFR §60.4375(a) Excess emissions reporting requirements
- 40 CFR §60.4395 Reporting frequency requirement



4.1.4 40 CFR Part 60, Subpart TTTTa – Standards of Performance for Greenhouse Gas Emissions for Modified Coal-Fired Steam Electric Generating Units and New Construction and Reconstruction Stationary Combustion Turbine Electric Generating Units

40 CFR Part 60, Subpart TTTTa establishes emissions standards and compliance schedules for the control of greenhouse gas (GHG) emissions to owners or operators of coal-fired steam generating unit or integrated gasification combined cycle facility (IGCC) that commences modification after May 23, 2023. Subpart TTTTa also establishes emissions standards and compliance schedules for the control of GHG emissions from a stationary combustion turbine that commences construction or reconstruction after May 23, 2023. Pursuant to 40 CFR §60.5509a, this subpart applies to any stationary combustion turbine and that has a base-load rating greater than 250 MMBtu/hr of fossil fuel and serves a generator capable of selling 25 MW of electricity to a utility power distribution system. Therefore, the turbines at the Site meet these criteria and will be subject to the requirements of Subpart TTTTa.

The turbines at the Site will be classified as "intermediate load combustion turbines" as defined in 40 CFR §60.5580a. An intermediate load combustion turbine is a stationary combustion turbine that supplies more than 20% but less than or equal to 40% of its potential electric output as net-electric sales on both a 12-operating month and a 3-year rolling average basis. Therefore, in accordance with 40 CFR §60.5520a(a), the turbines at the Site will be subject to the following carbon dioxide (CO₂) emissions standards specified in Table 1 of Subpart TTTTa for intermediate combustion turbines:

- CO₂: 530 to 710 kilograms per megawatt hour (kg/MWh) of gross energy output; or
- CO₂: 540 to 700 kilograms per megawatt hour (kg/MWh) of net energy output.

In accordance with 40 CFR $\S60.5520a(d)(1)$, the turbines at the Site will only combust natural gas which is a uniform fuel with a consistent chemical composition that results in a consistent CO_2 emissions rate of less than 160 lb/MMBtu and will therefore not be subject to the monitoring and reporting requirements of Subpart TTTTa. The Site will maintain records of electric sales and fuel purchase records pursuant to 40 CFR $\S60.5520a(d)$ and 40 CFR $\S60.5525a$, respectively.

4.2 NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS

The National Emission Standards for Hazardous Air Pollutants (NESHAP) originally required by the 1970 Clean Air Act (CAA), found at 40 CFR Part 61, apply to specific hazardous air pollutants (HAP) emitted from



specific source categories. The Project does not fall under any of the pollutant-specific source categories regulated by 40 CFR Part 61. Therefore, 40 CFR Part 61 requirements are not applicable to the Project.

The provisions of 40 CFR Part 63 contain NESHAP that apply to specific source categories that are considered either major or area sources of HAP. A major source of HAP is defined as a stationary source that has a potential to emit (PTE) of 10 tons per year (tpy) or more for any single HAP or 25 tpy or more for any combination of HAP. Emissions from the Site do not exceed the 10 tpy threshold for any single HAP or the 25 tpy threshold for any combination of HAP. Therefore, the Site is an area source of HAP. Potentially applicable Part 63 Subparts are discussed in the following subsections.

4.2.1 40 CFR Part 63, Subpart A – General Provisions

The provisions of 40 CFR Part 63, Subpart A apply to the owner or operator of any stationary source that emits or has the potential to emit any HAP listed in or pursuant to section 112(b) of the Clean Air Act and is subject to any NESHAP. These general provisions include recordkeeping, reporting, monitoring, and testing requirements. Because the Project will not be subject to a NESHAP, ENGIE will not be required to comply with applicable requirements of 40 CFR Part 63, Subpart A.

4.2.2 40 CFR Part 63, Subpart YYYY – National Emissions Standards for Hazardous Air Pollutants for Stationary Combustion Turbines

40 CFR Part 63, Subpart YYYY (National Emissions Standards for Hazardous Air Pollutants for Stationary Combustion Turbines) applies to stationary combustion turbines located at major sources of HAP emissions. The Site is an area source of HAP; therefore, the provisions of 40 CFR Part 63, Subpart YYYY do not apply to the proposed turbines.

4.3 CROSS STATE AIR POLLUTION RULE

U.S. EPA's Cross-State Air Pollution Rule (CSAPR) was first finalized by U.S. EPA on July 6, 2011. The timing of the rule implementation was impacted by several court decisions since its finalization including a stay of implementation. On October 23, 2014, the District of Colombia (D.C.) Circuit Court ordered that U.S. EPA's motion to lift the stay of CSAPR be granted. CSAPR Phase 1 implementation began in 2015, with Phase 2 beginning in 2017. The final rule requires power plants in 28 states to decrease annual SO_2 and NO_X emissions to help downwind areas realize attainment with the O_3 and $PM_{2.5}$ NAAQS.



Therefore, ENGIE will be required to meet the requirements of CSAPR codified in 40 CFR Part 97, Subpart GGGGG [relating to the Transport Rule (TR) NO_X Ozone Season Group 3 Trading Program] and 40 CFR Part 97. Upon operation, ENGIE will comply with the following applicable 40 CFR Part 97 monitoring, reporting, and recordkeeping requirements and provisions:

- 40 CFR Part 97 Subpart GGGGG CSAPR NO_X Ozone Season Group 3 Trading Program
 - 40 CFR §97.1006(b) Emissions monitoring, reporting, and recordkeeping requirements
 - 40 CFR §97.1006(c) NO_X emissions requirements
 - 40 CFR §97.1006(d) TVOP requirements
 - o 40 CFR §97.1006(e) Additional recordkeeping and reporting requirements

4.4 ACID RAIN PROGRAM

The Acid Rain Program (ARP) is codified in 40 CFR Parts 72 through 78 and addresses Title IV of the CAA which aims to reduce acid rain by reduction of SO₂ and NO_X emissions from existing and new utility units that have a nameplate electricity generation capacity greater than 25 MW. The proposed turbines will be subject to the ARP and ENGIE will comply with the applicable provisions of the following parts:

- 40 CFR Part 72 Permits Regulation
 - 40 CFR §72.30(b)(2)(ii)
 - o 40 CFR Part 72, Subpart D (Acid Rain Compliance Plan and Compliance Options)
- 40 CFR Part 73 Sulfur Dioxide Allowance System
- 40 CFR Part 75 Continuous Emission Monitoring
 - 40 CFR Part 75, Subpart G (Reporting Requirements)
 - 40 CFR §75.20(a)(2)
 - o 40 CFR §75.64(a)
- 40 CFR Part 77 Excess Emissions

The Phase II Acid Rain permit application required under 40 CFR §72.30(b)(2)(ii) will be filed at least 24 months before the unit commences operation of any mechanical, chemical, or electronic processes which include startup of the combustion chamber. The application will include the date that the unit will commence operation and the deadline for monitoring certification (i.e., 90 days after commencement of commercial operation).

ENGIE will arrange for the establishment of an SO₂ emissions account for the Project. ENGIE will be responsible for obtaining the necessary emissions allowances and then overseeing the tracking, holding, and transfer of the allowances. ENGIE will develop a Title IV Acid Rain compliance plan as required pursuant to 40 CFR Part 72, Subpart D. ENGIE will begin submitting quarterly emissions reports pursuant



to 40 CFR Part 75 Subpart G (Reporting Requirements) in accordance with 40 CFR §75.64(a) the earlier of the date of provisions certification as defined in 40 CFR §75.20(a)(2) or 180 after the date on which the turbines commence commercial operation (as defined by 40 CFR §72.2).

4.5 STATE OF TEXAS AIR QUALITY REGULATIONS

Potentially applicable State of Texas regulations as codified in 30 TAC – Environmental Quality are summarized below and discussed in the following subsections:

- 30 TAC Chapter 101 General Air Quality Rules
- 30 TAC Chapter 111 Control of Air Pollution from Visible Emissions and Particulate Matter
- 30 TAC Chapter 112 Control of Air Pollution from Sulfur Compounds
- 30 TAC Chapter 113 Standards of Performance for Hazardous Air Pollutants and for Designated Facilities and Pollutants
- 30 TAC Chapter 115 Control of Air Pollution from Volatile Organic Compounds
- 30 TAC Chapter 116 Control of Air Pollution by Permits for New Construction or Modification
- 30 TAC Chapter 117 Control of Air Pollution from Nitrogen Compounds
- 30 TAC Chapter 118 Control of Air Pollution Episodes
- 30 TAC Chapter 122 Federal Operating Permits Program



4.5.1 30 TAC Chapter 101 – General Air Quality Rules

30 TAC Chapter 101 (General Air Quality Rules) specifies the general air quality rules for the State of Texas. ENGIE will demonstrate compliance with the requirements of 30 TAC Chapter 101 upon commencement of operation as applicable.

4.5.2 30 TAC Chapter 111 – Control of Air Pollution from Visible Emissions and Particulate Matter

Standards for visible emissions and particulate matter (PM) are addressed in 30 TAC Chapter 111 (Control of Air Pollution from Visible Emissions and Particulate Matter). Specifically, 30 TAC §111.111(a)(1)(B) prohibits visible emissions in excess of 20% averaged over a six-minute period for any source. The proposed turbines will only burn natural gas which is clean, and are not expected to have visible emissions in excess of 20%.

Allowable PM emissions limits for nonagricultural processes are addressed in 30 TAC §111.151. Specifically, 30 TAC §111.151(a) prohibits PM from any of the three turbines to exceed the allowable rate of 51.93 lb total suspended particulate (TSP)/hr, or 155.79 lb TSP/hr from all turbines combined, as specified in Table 1 of the rule. The emissions inventory provided in Table 5-1 demonstrates that the Site will be below this limit. The proposed turbines will combust natural gas and will be maintained and operated in accordance with manufacturer recommendations. Thus, the turbines will demonstrate compliance with the PM emissions requirements, as applicable.

4.5.3 30 TAC Chapter 112 – Control of Air Pollution from Sulfur Compounds

Allowable emissions limits from sulfur compounds are addressed in 30 TAC Chapter 112 (Control of Air Pollution from Sulfur Compounds). ENGIE will meet the provisions of 30 TAC Chapter 112 as applicable. As addressed in Table 5-1, the Site will not emit hydrogen sulfide (H₂S), sulfuric acid (H₂SO₄), or total reduced sulfur (TRS). The Site will emit SO₂. Regulated units addressed in 30 TAC Chapter 112 include sulfuric acid plants, sulfur recovery plants, solid fossil fuel-fired steam generators, liquid fuel-fired steam generators, furnaces or heaters, and non-ferrous smelters. The Project does not include this equipment. Additionally, the Site will meet the exemption conditions established for net ground level concentration limits established in 30 TAC §112.4. Therefore, the Site is not subject to the provisions in 30 TAC Chapter 112.



4.5.4 30 TAC Chapter 113 – Standards of Performance for Hazardous Air Pollutants and for Designated Facilities and Pollutants

The provisions of 30 TAC Chapter 113 (Standards of Performance for Hazardous Air Pollutants and for Designated Facilities and Pollutants), Subchapter C incorporate multiple Federal 40 CFR Part 63 NESHAP by reference. The Project is not subject to any NESHAP. Therefore, 30 TAC Chapter 113 does not apply to the Project.

4.5.5 30 TAC Chapter 115 – Control of Air Pollution from Volatile Organic Compounds

The provisions of 30 TAC Chapter 115 (Control of Air Pollution from Volatile Organic Compounds) apply to specific volatile organic compound (VOC)-emitting processes, and a natural gas-fired turbine is not one of the defined processes in this Chapter. Therefore, the Project is not subject to 30 TAC Chapter 115.

4.5.6 30 TAC Chapter 116 – Control of Air Pollution by Permits for New Construction or Modification

In accordance with the provisions of 30 TAC Chapter 116, Subchapter F, ENGIE is submitting this Standard Air Permit Application to TCEQ. The necessary components of a Standard Air Permit Application have been provided in accordance with the registration requirements outlined in 30 TAC §116.611(a). As mentioned in the PI-1S form provided in Appendix A, this Application must demonstrate applicability of the general requirements outlined in 30 TAC §116.610 and §116.615 as discussed in the following subsections.

4.5.6.1 30 TAC §116.610 – Standard Permit Applicability

The rules promulgated in 30 TAC §116.610 discuss the general applicability of standard permits to a facility. The Project meets all of the requirements of 30 TAC Chapter 116, Subchapter F and under the Texas Clean Air Act §382.051 is entitled to this standard permit. Furthermore, the Project will meet all conditions and comply with the conditions of rule of 30 TAC §116.610(a). In particular, the Air Quality standard permit for Electric Generating Units exempts the turbines from the requirement of 30 TAC §116.610(a)(1) which requires the net increase in emissions of any air contaminants must meet the emissions limitations of 30 TAC §106.261.

This Project does not constitute a new major stationary source as defined in 30 TAC §116.12, so the requirements of 30 TAC §116.610(b) are not applicable. ENGIE will not circumvent applicable



requirements pursuant to 30 TAC §116.610(c). Also, the Project does not include an affected source as described in 30 TAC §116.15(1), so the requirements of 30 TAC §116.610(d) are not applicable. Appendix B contains a markup of the Air Quality Standard Permit for Electric Generating Units with detail on how the turbines meet the requirements.

4.5.6.2 30 TAC §116.615 - General Conditions

The provisions of 30 TAC §116.615 provide the general conditions that are applicable to standard permits but are not included within the specific standard permit documentation. ENGIE will comply with the general conditions outlined in 30 TAC §116.615. A copy of the standard permit and data sufficient to demonstrate applicability and compliance will be maintained at the Site pursuant to 30 TAC §116.615(8).

4.5.7 30 TAC Chapter 117 – Control of Air Pollution from Nitrogen Compounds

The provisions of 30 TAC Chapter 117 (Control of Air Pollution from Nitrogen Compounds) regulate control measures for nitrogen compounds as required for certain areas of Texas. Per 40 CFR §81.344, Nueces County is classified as an attainment area with respect to all 8-hour ozone standards of the National Ambient Air Quality Standards (NAAQS). Because the Project will be a minor source and Nueces County is attaining the ozone NAAQS, 30 TAC Chapter 117, Subchapters B, C, and D do not apply. The turbines will be located in East Texas; therefore, 30 TAC Chapter 117, Subchapter E is potentially applicable to the Project. The turbines are specifically potentially subject to Division 1 – Utility Electric Generation in East and Central Texas but are being placed into service after December 31, 1995. Per 30 TAC §117.3000(a)(3), ENGIE is not subject to the rule.

4.5.8 30 TAC Chapter 118 – Control of Air Pollution Episodes

The provisions of 30 TAC Chapter 118 (Control of Air Pollution Episodes) require control measures when immediate action is needed to control air pollution episodes. 30 TAC Chapter 118 is generally applicable to the Project, and ENGIE will comply with the requirements in the event an air pollution episode occurs.

4.5.9 30 TAC Chapter 122 – Federal Operating Permits Program

The provisions of 30 TAC Chapter 122 (Federal Operating Permits Program) contain the regulations that make up the Federal Operating Permit Program (i.e., Title V). Air emissions for the Project will trigger



major source status under the Title V Operating Permit (TVOP) program. Once construction is complete, ENGIE will submit an application for a TVOP.



5. SUMMARY OF EMISSIONS AND EMISSIONS CALCULATIONS

The emissions for the proposed turbines were calculated using the U.S. EPA's *Compilation of Air Pollutant Emissions Factors* (AP-42) and vendor-specific values from equipment specification sheets, provided in Appendix C. Specifically, the emissions factors for natural gas combustion are found in AP-42 Chapter 3.1, Table 3.1-2, except as noted in Table 5-1. A potential to emit (PTE) summary for the turbines is provided in Table 5-1.

Table 5-1 Potential to Emit for Natural Gas-Fired Gas Turbines ^(a) ENGIE Flexible Generation - Perseus Site

Pollutant	Emissions Factor		Single Turbine Potential Emissions		Total Potential Emissions		PSD Major Source	PSD Major Source?
			lb/hr	tpy	lb/hr	tpy	Threshold	
Criteria Pollutants			1	1	ı	ı		
PM (filterable) (b)		lb/MMBtu	5.70	5.70	17.11	17.11	250	No
PM ₁₀ (b)(c)	6.60E-03	lb/MMBtu	19.81	19.81	59.44	59.44	250	No
PM _{2.5} ^{(b)(c)}	6.60E-03	lb/MMBtu	19.81	19.81	59.44	59.44	250	No
SO ₂ ^(d)	2.00E-01	gr/Ccf	0.84	0.84	2.52	2.52	250	No
NO _X ^(d)	81.57	lb/hr	27.19	30.79	81.57	92.38	250	No
CO ^(e)	0.02	lb/MMBtu	45.03	45.03	135.09	135.09	250	No
VOC (b)	2.10E-03	lb/MMBtu	6.30	6.30	18.91	18.91	250	No
CO ₂ (b)	110	lb/MMBtu	330,209	330,209	990,627	990,627		
CH ₄ ^(b)	8.60E-03	lb/MMBtu	25.82	25.82	77.45	77.45		
N ₂ O ^(b)	3.00E-03	lb/MMBtu	9.01	9.01	27.02	27.02		
CO₂e ^(f)	111.11	lb/MMBtu	333,538	333,538	1,000,614	1,000,614	100,000	No
NH ₃	5	ppmdv @ 15% O ₂	20.43	20.43	61.29	61.29		
Hazardous Air Pollutants (HAP) ^(g)								
1,3-Butadiene ^(h)	4.30E-07	lb/MMBtu	1.29E-03	1.29E-03	3.87E-03	3.87E-03		-
Acetaldehyde	4.00E-05	lb/MMBtu	0.12	0.12	0.36	0.36		
Acrolein	6.40E-06	lb/MMBtu	0.02	0.02	0.06	0.06		
Benzene	1.20E-05	lb/MMBtu	0.04	0.04	0.11	0.11		
Ethylbenzene	3.20E-05	lb/MMBtu	0.10	0.10	0.29	0.29		
Formaldehyde ⁽ⁱ⁾	91.00	ppbdv @ 15% O ₂	0.66	0.66	1.97	1.97		
Naphthalene	1.30E-06	lb/MMBtu	3.90E-03	3.90E-03	0.01	0.01		
PAH	2.20E-06	lb/MMBtu	6.60E-03	6.60E-03	0.02	0.02		-
Propylene Oxide ^(h)	2.90E-05	lb/MMBtu	0.09	0.09	0.26	0.26		
Toluene	1.30E-04	lb/MMBtu	0.39	0.39	1.17	1.17		
Xylenes	6.40E-05	lb/MMBtu	0.19	0.19	0.58	0.58		
		Maximum Single HAP	0.66	0.66	1.97	1.97	10	No
		Total HAP	2.26	1.61	4.83	4.83	25	No

Calculations are based on parameters identified below

Parameter	Value	Units	
Fuel Usage	930.00	MW	
Gas Turbine Firing Rate (i)	9,005.70	MMBtu/hr	
Base Load Operating Time	1,975	hours/yr	
Operating Time during Startup	25	hours/yr	
Total Operating Time	2,000	hours/yr	
Maximum Gas Consumption	18,011,400	MMBtu/yr	
wiaximum das consumption	17,658	MMSCF/yr	
Natural Gas Btu Content	1,020	Btu/SCF	
Exhaust Mass	385	DSCF/lb-mol	
F Factor	8,710	DSCF/MMBtu	
Startup time	0.2	hours	
No. Startups per year	150		
Turbine Firing Rate during Startup	2,702	MMBtu/hr	
Startup Gas Consumption	67,543	MMBtu/yr	
NO _x uncontrolled EF	3.20E-01	lb/MMBtu	
Startup NO _X emissions	10.81	tpy	
Pounds to Tons Conversion	2,000	lb/ton	
Grains to Pounds Conversion	7,000	gr/lb	
Hundred to Million Standard Cubic Feet Conversion	10,000	Ccf/MMscf	
Formaldehyde Molecular Weight	30	lb/lb-mol	
NH ₃ Molecular Weight	17	lb/lb-mol	

⁽a) Calculations include emissions for three (3) identical SGT6-8000H natural gas turbines at the site. The turbine EPNs are GT-1, GT-2, and GT-3.

Since the project does not result in Prevention of Significant Deterioration (PSD) requirements for any criteria pollutant, the project is not subject to PSD based solely on potential GHG emissions. [Utility Air Regulatory Group (UARG) v. EPA, 134 S. Ct. 2427, June 23, 2014]. The carbon dioxide equivalent (CO₂) PTE is based off the following factors from 40 CFR §98 Table A-1 to Subpart A of Part 98 Global Warming Potentials:

Pollutant	Global Warming Potential
CO ₂	1
CH ₄	25
N ₂ O	298

⁽g) Emissions factors for HAP are from U.S. EPA AP-42 Chapter 3.1 (April 2000), Table 3.1-3.

 $^{^{(}b)}$ Emissions factors are from U.S. EPA AP-42 Chapter 3.1 (April 2000), Table 3.1-2.

⁽c) Emissions calculations conservatively assume PM_{Total}=PM₁₀=PM_{2.5}. PM₁₀ and PM_{2.5} emissions factors account for both the filterable and condensable portions of PM.


⁽d) The sulfur dioxide (SO₂) emissions factor is based on supplier data. The nitrogen oxides (NO_x) and ammonia (NH₃) emissions factors are based on manufacturer provided data. NO_x emissions account for SCR-warmup time using the uncontrolled emissions factor from AP-42 Table 3.1-1 and an estimated 150 startups per year, each lasting ten minutes. The turbine firing rate during startup time is approximately 30%.

 $^{^{(}e)}$ CO Emissions factor is are from U.S. EPA AP-42 Chapter 3.1 (April 2000), Table 3.1-1.

⁽h) Emissions factor is below detection limit. Pollutant conservatively included at detection limit, individually and in total HAP emissions.

⁽i) Emissions limit from Table 1 of 40 CFR Part 63 Subpart YYYY, for the turbine emissions only.

 $^{^{\}left(j\right) }$ Higher Heating Value (HHV).



Form PI-1S Registrations for Air Standard Permit (Page 1)

I. Registrant Information
A. Company or Other Legal Customer Name:
ENGIE Flexible Generation NA LLC
B. Company Official Contact Information (Mr. Mrs. Ms. Other:)
Name: <i>Laura Scott</i>
Title: Sr. Environmental Advisor
Mailing Address: 1360 Post Oak Blvd., Suite 400
City: <i>Houston</i>
State: TX
ZIP Code: 77056
Telephone No.: 281-924-9819
Fax No.:
Email Address: <i>laura.g.scott@engie.com</i>
All permit correspondence will be sent via email.
C. Technical Contact Information (Mr. Mrs. Ms. Other:)
Name: Margaret Campbell
Title: Director, Business Development
Company Name: ENGIE Flexible Generation NA LLC
Mailing Address: 1360 Post Oak Blvd., Suite 400
City: <i>Houston</i>
State: TX
ZIP Code: 77056
Telephone No.: 978-855-2043
Fax No.:
Email Address: margaret.campbell@engie.com
II. Facility and Site Information
A. Name and Type of Facility
Facility Name: GT-1, GT-2, and GT-3 natural gas-fired turbines at Perseus Facility
Type of Facility: ⊠ Permanent ☐ Temporary

Form PI-1S Registrations for Air Standard Permit (Page 2)

II. Facility and Site Information (continued)				
For portable units, please provide the serial number of the equipment being authorized below.				
Serial No(s):				
B. Facility Location Information				
Street Address: CO Rd 48				
If there is no street address, provide written driving directions to the site and provide the closest city or town, county, and ZIP code for the site (attach description if additional space is needed).				
From Houston, take I-69/US-59 S to US-77 S. Keep left to continue onto TX-91 Loop S, and then merge				
onto US-77 S to Refugio/Corpus Christi. Take the I-37 S/US-77 S ramp to Corpus Christi/Kingsville,				
and then take Exit 14 toward Kingsville/Brownsville. Continue onto I-69E S/US-77 S and take the US-				
77 BUS exit toward TX-44 W/Robstown/Alice. Continue onto US-77 BUS S and turn right onto CO Rd				
48.				
City: <i>Robstown</i>				
County: Nueces				
ZIP Code: 78380				
C. Core Data Form (required for Standard Permits 6006, 6007, and 6013).				
Is the Core Data Form (TCEQ Form 10400) attached?				
Customer Reference Number (CN): 605985910				
Regulated Entity Number (RN): <i>TBD</i>				
D. TCEQ Account Identification Number (if known): N/A				
E. Type of Action				
☑ Initial Application ☐ Change to Registration ☐ Renewal ☐ Renewal Certification				
For Change to Registration, Renewal, or Renewal Certification actions provide the following:				
Registration Number: N/A				
Expiration Date: N/A				
F. Standard Permit Claimed: 6005 – Electric Generating Unit				
G. Previous Standard Exemption or PBR Registration Number: N/A				
Is this authorization for a change to an existing facility previously authorized $\ $ Yes $\ $ No under a standard exemption or PBR?				
If "Yes," enter previous standard exemption number(s) and PBR registration number(s) and associated effective date in the spaces provided below.				

Form PI-1S Registrations for Air Standard Permit (Page 3)

II. Facility and Site Information (continued)				
H. Other Facilities at this Site Authorized by Standard Exemption, PBR, or Standard Permit				
Are there any other facilities at this site that are authorized by an Air Standard Exemption, PBR, or Standard Permit?	☐ Yes ⊠ No			
If "Yes," enter standard exemption number(s), PBR registration number(s), and Standard Pern number(s), and associated effective date in the spaces provided below.	nit registration			
Standard Exemption, PBR Registration, and Standard Permit Registration Number(s) and Effe	ective Date(s)			
I. Other Air Preconstruction Permits				
Are there any other air preconstruction permits at this site?	☐ Yes ⊠ No			
If "Yes," enter permit number(s) in the spaces provided below.				
J. Affected Air Preconstruction Permits				
Does the standard permit directly affect any permitted facility?	☐ Yes ⊠ No			
If "Yes," enter permit number(s) in the spaces provided below.				
K. Federal Operating Permit (FOP) Requirements				
Is this facility located at a site that is required to obtain a ☐ Yes ☐ No ☐ To FOP pursuant to 30 TAC Chapter 122?	Be Determined			
Check the requirements of 30 TAC Chapter 122 that will be triggered if this standard permit is (check all that apply).	approved			
☐ Initial Application for a FOP ☐ Significant Revision for a SOP ☐ Minor Revision for a SOP				
☐ Operational Flexibility/Off Permit Notification for a SOP ☐ Revision for a GOP				
☐ To be Determined ⊠ None				
Identify the type(s) of FOP issued and/or FOP application(s) submitted/pending for the site. (check all that apply)				
☐ SOP ☐ GOP ☐ GOP application/revision (submitted or under APD review) ☒ N/A				
SOP application/revision (submitted or under APD review)				

Form PI-1S Registrations for Air Standard Permit (Page 4)

III. Fee Information (go to www.tceg.texas.gov/epay to pay online)	
A. Fee Amount: \$100	
B. Voucher number from ePay: STEERS	
IV. Public Notice (if applicable) – N/A	
A. Responsible Person (Mr. Mrs. Mrs. Other:)	
Name:	
Title:	
Company:	
Mailing Address:	
City:	
State:	
ZIP Code:	
Telephone No.:	
Fax No.:	
Email Address:	
B. Technical Contact (Mr. Mrs. Mrs. Other):	
Name:	
Title:	
Company:	
Mailing Address:	
City:	
State:	
ZIP Code:	
Telephone No.:	
Fax No.:	
Email Address:	
C. Bilingual Notice	
Is a bilingual program required by the Texas Education Code in the School District?	☐ Yes ☐ No
Are the children who attend either the elementary school or the middle school closest to your facility eligible to be enrolled in a bilingual program provided by the district?	☐ Yes ☐ No

Form PI-1S Registrations for Air Standard Permit (Page 5)

IV.	Public Notice (continued) (if applicable) (continued)			
If "Yes," list which language(s) are required by the bilingual program below?				
D.	Small Business Classification and Alternate Public Notice			
	s this company (including parent companies and subsidiary companies) fewer than 100 employees or less than \$6 million in annual gross receipts?	☐ Yes ☐ No		
Is the	e site a major source under 30 TAC Chapter 122, Federal Operating Permit Program?	☐ Yes ☐ No		
	he site emissions of any individual regulated air contaminant equal to or ter than 50 tpy?	☐ Yes ☐ No		
	he site emissions of all regulated air contaminant combined equal to eater than 75 tpy?	☐ Yes ☐ No		
V.	Renewal Certification Option			
A.	Does the permitted facility emit an air contaminant on the Air Pollutant Watch List, and is the permitted facility located in an area on the watch list?	☐ Yes ⊠ No		
B.	For facilities participating in the Houston/Galveston/Brazoria area (HGB) cap and trade program for highly reactive VOCs (HRVOCs), do the HRVOCs need to be speciated on the maximum allowable emission rates table (MAERT)?	☐ Yes ⊠ No		
C.	Does the company and/or site have an unsatisfactory compliance history?	☐ Yes ⊠ No		
D.	Are there any applications currently under review for this standard permit registration?	☐ Yes ⊠ No		
E.	Are scheduled maintenance, startup, or shutdown emissions required to be included in the standard permit registration at this time?	⊠ Yes □ No		
F.	Are any of the following actions being requested at the time of renewal:	☐ Yes ⊠ No		
1.	Are there any facilities that have been permanently shutdown that are proposed to be removed from the standard permit registration?	☐ Yes ⊠ No		
2.	Do changes need to be made to the standard permit registration in order to remain in compliance?	☐ Yes ⊠ No		
3.	Are sources or facilities that have always been present and represented, but never identified in the standard permit registration, proposed to be included with this renewal?	☐ Yes ⊠ No		
4.	Are there any changes to the current emission rates table being proposed?	☐ Yes ⊠ No		
Note: If answers to all of the questions in Section V. Renewal Certification Option are "No," use the certification option and skip to Section VII. of this form. If the answers to any of the questions in Section V. Renewal Certification Option are "Yes," the certification option cannot be used.				
*If notice is applicable and comments are received in response to the public notice, the application does not qualify for the renewal certification option.				

Form PI-1S Registrations for Air Standard Permit (Page 6) Texas Commission on Environmental Quality

VI.	Technical Information Including State and Federal Regulatory Requirements						
Note the s	Place a check next to the appropriate box to indicate what you have included in your submittal. Note: Any technical or essential information needed to confirm that facilities are meeting the requirements of the standard permit must be provided. Not providing key information could result in an automatic deficiency and voiding of the project.						
Α.	Standard Permit requirements (Checklists are optional; however, your review will go faster if you provide applicable che	cklists.)					
	ou demonstrate that the general requirements in 30 TAC ions 116.610 and 116.615 are met?	⊠ Yes □ No					
Did y	ou demonstrate that the individual requirements of the specific standard permit are met?	⊠ Yes □ No					
B.	Confidential Information (All pages properly marked "CONFIDENTIAL").	☐ Yes ⊠ No					
C.	Process Flow Diagram.	⊠ Yes ☐ No					
D.	Process Description.	⊠ Yes ☐ No					
E.	Maximum Emissions Data and Calculations.	⊠ Yes ☐ No					
F.	Plot Plan.	⊠ Yes ☐ No					
G.	Projected Start Of Construction Date, Start Of Operation Date, and Length of Time at Site:	⊠ Yes □ No					
Proje	ected Start of Construction (provide date): <i>Upon Issuance</i>						
Proje	ected Start of Operation (provide date): Upon Completion of Construction						
Leng	th of Time at the Site: Permanent						
VII.	Delinquent Fees and Penalties						
the A	form will not be processed until all delinquent fees and/or penalties owed to the TCEQ of attorney General on behalf of the TCEQ are paid in accordance with the Delinquent Fee and ocol. For more information regarding Delinquent Fees and Penalties, go to the TCEQ webstaceq.texas.gov/agency/financial/fees/delin/index.html.	nd Penalty					

Form PI-1S Registrations for Air Standard Permit (Page 7) Texas Commission on Environmental Quality

VIII. Signature Requirements

The signature below confirms that I have knowledge of the facts included in this application and that these facts are true and correct to the best of my knowledge and belief. I further state that to the best of my knowledge and belief, the project for which application is made will not in any way violate any provision of the Texas Water Code (TWC), Chapter 7; the Texas Health and Safety Code, Chapter 382, the Texas Clean Air Act (TCAA) the air quality rules of the Texas Commission on Environmental Quality; or any local governmental ordinance or resolution enacted pursuant to the TCAA. I further state that I understand my signature indicates that this application meets all applicable nonattainment, prevention of significant deterioration, or major source of hazardous air pollutant permitting requirements. The signature further signifies awareness that intentionally or knowingly making or causing to be made false material statements or representations in the application is a criminal offense subject to criminal penalties.

Name (printed): Laura Scott

Signature (original signature required):

IX. Copies of the Registration

The PI-1S application must be submitted through ePermits. No additional copies need to be sent to the Regional Office or local Air Pollution Control Program(s). The link to ePermits can be found here: www3.tceq.texas.gov/steers/.



TCEQ Core Data Form

For detailed instructions on completing this form, please read the Core Data Form Instructions or call 512-239-5175.

SECTION I: General Information

1. Reason for	r Submissi	on (If other is checked	l please desci	ribe in space pr	ovided.,)						
New Pern	nit, Registra	ation or Authorization	(Core Data F	orm should be s	submitt	ed with	the progi	ram apı	olication.)			
Renewal	(Core Data	Form should be submi	tted with the	renewal form)			Other					
2. Customer	Reference	Number (if issued)		Follow this link to search for CN or RN numbers in			. Regulated Entity Reference Number (if issued)					
CN 605985910				for CN or RN Central R			RN	RN				
SECTIO	N II:	Customer	Infor	mation	<u>1</u>							
4. General Customer Information 5. Effecti			tive Date for Customer Information Updates (mm/dd/yyyy)									
New Custon	New Customer ☐ Update to Customer Information ☐ Change in Regulated Entity Ownership											
Change in L	egal Name	(Verifiable with the Tex	xas Secretary	of State or Tex	as Com	ptrolle	of Public	Accour	its)			
The Custome	r Name su	ıbmitted here may l	be updated	automatical	ly base	ed on v	vhat is c	urrent	and active	with th	e Texas Seci	retary of State
(SOS) or Texa	s Comptro	oller of Public Accou	ınts (CPA).									
6. Customer	Legal Nam	ne (If an individual, pri	nt last name	first: eg: Doe, J	Iohn)			<u>If nev</u>	Customer,	enter pre	evious Custom	er below:
			T = =							_		
7. TX SOS/CP	'A Filing N	umber	8. TX Stat	t e Tax ID (11 d	ligits)			9. Fe (9 dig	deral Tax I	D	applicable)	Number (if
										1		
11. Type of C	ustomer:	Corpora	tion	☐ Individ			Individ	idual Partne		ership: 🗌 General 🔲 Limited		
Government: [City 🔲 0	County 🗌 Federal 🗌	Local 🗌 Sta	ate 🗌 Other		1	Sole Pi	Sole Proprietorship Other:				
12. Number o	of Employ	ees						13. lı	ndepender	ntly Ow	ned and Ope	erated?
0-20	21-100 [101-250 251-	500 🗌 50	01 and higher				☐ Ye	es.	□ No		
14. Customer	r Role (Pro	posed or Actual) – as i	t relates to ti	he Regulated Er	nt i ty list	ted on t	his form.	Please (heck one of	the follo	wing	
Owner	al Licensee	Operator Responsible Pa	<u> </u>	Owner & Opera					Other:			
	1		-, _									
15. Mailing												
Address:												
	City			State			ZIP				ZIP + 4	
16. Country N	Mailing In	formation (if outside	USA)		•	17. E	-Mail Ad	ldress	(if applicabl	e)		
18. Telephon	e Number			19. Extension	on or C	ode			20. Fax N	umber	(if applicable)	

TCEQ-10400 (11/22) Page 1 of 3

SECTION III: I	reguie	itea en	tity Illioli	···acioi	<u>.</u>				
21. General Regulated En	tity Informa	tion (If 'New Re	egulated Entity" is sele	cted, a new p	ermit applica	tion is also i	equired.)		
New Regulated Entity [Update to	Regulated Entity	Name Update	to Regulated	Entity Informa	ation			
The Regulated Entity Nan as Inc, LP, or LLC).	ne submitted	d may be updo	ated, in order to me	et TCEQ Co	re Data Stan	ndards (rei	noval of or	ganization	al endings such
22. Regulated Entity Nam	e (Enter name	e of the site whe	ere the regulated actio	n is taking pl	ice.)				
Perseus Generation									
23. Street Address of the Regulated Entity:									
(No PO Boxes)	City		State		ZIP			ZIP + 4	
24. County			I		1	1			<u> </u>
		If no Stre	eet Address is provi	ded, fields ?	25-28 are re	quired.			
25. Description to			-59 S to US-77 S. Keep the I-37 S/US-77 S rar			-	_		
Physical Location:		to I-69E S/US-77	7 S and take the US-77		_				_
26. Nearest City						State		Nea	rest ZIP Code
Robstown						TX		7838	30
Latitude/Longitude are re used to supply coordinate	-	-			Data Standa	rds. (Geoc	oding of th	e Physical	Address may be
27. Latitude (N) In Decimal: 28.260738			28. Longitude (V			V) In Decin	nal:	-97.083737	
	al:	28.260738		20. 1	onground (in	,			
Degrees	Minutes	28.260738	Seconds	Degr			inutes		Seconds
Degrees 28	Minutes	15	Seconds 38.6568				inutes 5		Seconds 1.453
_	Minutes		38.6568	Degra	-97	M	5	ndary NAIG	1.453
28	Minutes	15 Secondary SIC	38.6568	Degr	-97	M	5	-	1.453
28 29. Primary SIC Code	Minutes 30.	15 Secondary SIC	38.6568	Degra	-97	M	5 32. Seco	-	1.453
29. Primary SIC Code (4 digits)	30. (4 di	15 Secondary SIC gits)	38.6568	31. Prima (5 or 6 dig	-97 ry NAICS Codts)	M	5 32. Seco	-	1.453
28 29. Primary SIC Code (4 digits) 4911	30. (4 di	15 Secondary SIC gits)	38.6568 C Code	31. Prima (5 or 6 dig	-97 ry NAICS Codts)	M	5 32. Seco	-	1.453
29. Primary SIC Code (4 digits) 4911 33. What is the Primary B Electric Power Generation	30. (4 di	Secondary SIC gits) his entity? (L	38.6568 C Code	31. Prima (5 or 6 dig	-97 ry NAICS Codts)	M	5 32. Seco	-	1.453
29. Primary SIC Code (4 digits) 4911 33. What is the Primary B Electric Power Generation 34. Mailing	30. (4 di	Secondary SIC gits) his entity? (L	38.6568 C Code Do not repeat the SIC of	31. Prima (5 or 6 dig	-97 ry NAICS Codts)	M	5 32. Seco	-	1.453
29. Primary SIC Code (4 digits) 4911 33. What is the Primary B Electric Power Generation	30. (4 di	Secondary SIC gits) his entity? ([38.6568 C Code Do not repeat the SIC of	31. Prima (5 or 6 dig	-97 ry NAICS Codts)	M	5 32. Seco	-	1.453
29. Primary SIC Code (4 digits) 4911 33. What is the Primary B Electric Power Generation 34. Mailing	Minutes 30. (4 di usiness of the state of t	Secondary SIC gits) his entity? (E	38.6568 Code Conot repeat the SIC of	31. Prima (5 or 6 dig	-97 ry NAICS Conts) ription.)	de	5 32. Seco	gits)	1.453
29. Primary SIC Code (4 digits) 4911 33. What is the Primary B Electric Power Generation 34. Mailing Address:	Minutes 30. (4 di usiness of the state of t	Secondary SIC gits) his entity? (E	38.6568 Code Conot repeat the SIC of	31. Prima (5 or 6 dig	ry NAICS Conts) ription.)	de 77056	5 32. Seco	gits) ZIP + 4	1.453

39. TCEQ Programs and ID Numbers Check all Programs and write in the permits/registration numbers that will be affected by the updates submitted on this form. See the Core Data Form instructions for additional guidance.

TCEQ-10400 (11/22) Page 2 of 3

☐ Dam Safety		Districts	☐ Edwards Aquifer]	Emissio	ns Inventory Air	☐ Industrial Hazardous Waste	
Municipal Solid	Waste	Vaste		☐ Petroleu		um Storage Tank	☐ PWS	
Sludge		Storm Water	☐ Title V Air	[Tires		Used Oil	
☐ Voluntary Clear	nup	Wastewater	☐ Wastewater Agrico	ulture [☐ Water F	lights	Other:	
	_							
O. Name: Tro 2. Telephone Nu	oy Gayer mber	43. Ext./Code	44. Fax Number	41. Title: 45. E-Mai	Manag il Address	ging Consultant		
		43. Ext./Code	44. Fax Number		il Address	-		
2. Telephone Num 936) 274-3169 ECTION By my signature b	mber V: Au elow, I certif	Ithorized S	() - Signature	45. E-Mai	il Address 14inc.com	is true and complete		
2. Telephone Num 936) 274-3169 ECTION By my signature be submit this form on	wber V: Au elow, I certif behalf of th	Ithorized S	() - Signature owledge, that the informate ection II, Field 6 and/or as re	45. E-Mai	il Address	is true and complete	entified in field 39.	
2. Telephone Num 936) 274-3169 ECTION By my signature b	wber V: Au elow, I certif behalf of th	Ithorized S fy, to the best of my known the entity specified in Se exible Generation NA L	() - Signature owledge, that the informate ection II, Field 6 and/or as re	45. E-Mai tgayer@all ion provided in equired for the	il Address	is true and complete to the ID numbers ide		

TCEQ-10400 (11/22) Page 3 of 3

Texas Commission on Environmental Quality Table 31 Combustion Turbines


Equipment Information					
Manufacturer:					
Model No.: Serial No.:					
Emission Point Number (EPN) From Table 1(a):					
Turbine Application					
☐ Electric Generation ☐ Base Load ☐ Peaking ☐ Load Following ☐ Gas Compression					
Other (specify):					
Cycle					
☐ Simple Cycle Hours Per Year ☐ Regenerative Cycle ☐ Cogeneration ☐ Combi	ined Cycle				
Model represented is based on (see 30 TAC § 116.116(a)):					
☐ Preliminary Design ☐ Contract Award ☐ Other (specify):					
Nominal Power Output at Baseload, ISO:	or 🗌 hp				
Manufacturer's rated gross heat rate at baseload at expected conditions (efficiency in BTU/kW-hr)):				
Fuel Data					
Primary Fuels:					
☐ Natural Gas (Sulfur content gr S/100 dscf; HHVB	3tu/scf)				
☐ Process Offgas ☐ Landfill/Digester Gas ☐ Fuel Oil ☐ Refinery Gas					
Other (specify):					
Backup Fuels:					
☐ Not Provided ☐ Process Offgas ☐ Ethane ☐ Fuel Oil ☐ Refinery Gas					
Other (specify):					
If using fuels other than natural gas, attach fuel analyses, including maximum sulfur content, hea (specify LHV or HHV) and mole percent of gaseous constituents.	ating value				
Emissions Data					
Attach manufacturer's information showing emissions of NO_x , CO, VOC, SO_x , and PM for each proposed fuel at turbine loads and site ambient temperatures representative of the range of proposed operation. The information must be sufficient to determine maximum hourly and annual emission rates. Annual emissions may be based on a conservatively low approximation of site annual average temperature. Provide emissions in pounds per hour and except for PM, parts per million by volume at actual conditions and corrected to dry, 15% oxygen conditions. In Table 1(a), provide speciation of PM/PM, $_x/PM_{_{7,6}}$.					
Method of Emission Control:					
☐ Lean Premix Combustors ☐ Oxidation Catalyst ☐ Water Injection					
□ Low-NO, Combustors □ SCR Catalyst □ Steam Injection					
Other (specify):					

Texas Commission on Environmental Quality Table 31 Combustion Turbine

Additional Information

On separate sheets attach the following:

- A. Details regarding principle of operation of emission controls. If add-on equipment is used, provide make and model and manufacturer's information. Example details include: controller input variables and operational algorithms for water or ammonia injection systems, combustion mode versus turbine load for variable mode combustors, etc.
- B. Stack parameters (not required if represented on Page 2 of Table 1(a)).
- C. If fired duct burners are used (as often used with a Combined Cycle Heat Recovery Steam Generator), supplementary fuel firing information as specified on Table 6, Boilers and Heaters (TCEQ Form Number 10163).



Air Quality Standard Permit for Electric Generating Units

Effective Date May 16, 2007

This standard permit authorizes electric generating units that generate electricity for use by the owner or operator and/or generate electricity to be sold to the electric grid, and that meet all of the conditions listed below.

(1) Applicability

- (A) This standard permit may be used to authorize electric generating units installed or modified after the effective date of this standard permit and that meet the requirements of this standard permit.
 - GT-1, GT-2, and GT-3 are electric generating units installed or modified after the effective date of this standard permit and will meet the requirements of this standard permit.
- (B) This standard permit may not be used to authorize boilers. Boilers may be authorized under the Air Quality Standard Permit for Boilers; 30 TAC § 106.183, Boilers, Heaters, and Other Combustion Devices; or a permit issued under the requirements of 30 TAC Chapter 116.

This Application is not authorizing a boiler.

(2) Definitions

- (A) East Texas Region All counties traversed by or east of Interstate Highway 35 or Interstate Highway 37, including Bosque, Coryell, Hood, Parker, Somervell and Wise Counties.
- (B) Installed a generating unit is installed on the site when it begins generating electricity.
- (C) West Texas Region Includes all of the state not contained in the East Texas Region.
- (D) Renewable fuel fuel produced or derived from animal or plant products, byproducts or wastes, or other renewable biomass sources, excluding fossil fuels. Renewable fuels may include, but are not limited to, ethanol, biodiesel, and biogas fuels.

(3) Administrative Requirements

(A) Electric generating units shall be registered in accordance with 30 TAC § 116.611, Registration to Use a Standard Permit, using a current Form PI-1S. Units that meet the conditions of this standard permit do not have to meet 30 TAC § 116.610(a)(1), Applicability.

The electric generating units, GT-1, GT-2, and GT-3, are being registered in accordance with 30 TAC §116.611 using the current Form PI-1S.

(B) Registration applications shall comply with 30 TAC § 116.614, Standard Permit Fees, for any single unit or multiple units at a site with a total generating capacity of 1 megawatt (MW) or greater. The fee for units or multiple units with a total generating capacity of less than 1 MW at a site shall be \$100.00. The fee shall be waived for units or multiple units with a total generating capacity of less than 1 MW at a site that have certified nitrogen oxides (NO_x) emissions that are less than 10 percent of the standards required by this standard permit.

In accordance with 30 TAC §116.614, this application contains payment for the \$100 fee that accompanies this Standard Permit.

- (C) No owner or operator of an electric generating unit shall begin construction and/or operation without first obtaining written approval from the executive director. GT-1, GT-2, and GT-3 will not operate until written approval of the standard permit is received from TCEQ.
- (D) Records shall be maintained and provided upon request to the Texas Commission on Environmental Quality (TCEQ) for the following:
 - (i) Hours of operation of the unit
 - (ii) Maintenance records, maintenance schedules, and/or testing reports for the unit to document re-certification of emission rates as required by subsection (4)(G) below; and
 - (iii) Records to document compliance with the fuel sulfur limits in subsection (4)(C).

Applicable records will be maintained and provided upon request.

- (E) Electric generators powered by gas turbines must meet the applicable conditions, including testing and performance standards, of Title 40 Code of Federal Regulations (CFR) Part 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, and applicable requirements of 40 CFR Part 60 Subpart KKKK, Standards of Performance for Stationary CombustionTurbines.
 - As discussed in Section 4 of the Application narrative, GT-1, GT-2, and GT-3 will comply with all applicable requirements of 40 CFR Part 60, Subparts GG and KKKK.
- (F) Compliance with this standard permit does not exempt the owner or operator from complying with any applicable requirements of 30 TAC Chapter 117, Control of Air Pollution from Nitrogen Compounds, or 30 TAC Chapter 114, Control of Air

Pollution from Motor Vehicles.

Discussion of applicability and potential requirements of 30 TAC Chapter 117 and 30 TAC Chapter 114 is found in the State of Texas Regulatory Analysis section in Section 4 of the Application Narrative.

(4) General Requirements

(A) Emissions of NO_x from the electric generating unit shall be certified by the manufacturer or by the owner or operator in pounds of pollutant per megawatt hour (lb/MWh). This certification must be displayed on the name plate of the unit or on a label attached to the unit. Test results from U.S. Environmental Protection Agency (EPA) reference methods, California Air Resources Board methods, or equivalent alternative testing methods approved by the executive director used to verify this certification shall be provided upon request to the TCEQ. The unit must operate on the same fuel(s) for which the unit was certified.

NOx emissions from GT-1, GT-2, and GT-3 will be certified by the manufacturer, and the certification will be displayed on the name plate of the turbines. Test results will be provided upon request from TCEQ, and the turbines will only fire natural gas as certified by the manufacturer. For more information, the turbine specifications are found in Appendix C.

- (B) Electric generating units that use combined heat and power (CHP) may take credit for the heat recovered from the exhaust of the combustion unit to meet the emission standards in subsections (4)(D), (4)(E), and (4)(F). Credit shallbe at the rate of one MWh for each 3.4 million British Thermal Units of heat recovered. The following requirements must be met to take credit for CHP forunits not sold and certified as an integrated package by the manufacturer:
 - (i) The owner or operator must provide as part of the application documentation of the heat recovered, electric output, efficiency of the generator alone, efficiency of the generator including CHP, and the use forthe non-electric output, and
 - (ii) The heat recovered must equal at least 20 percent of the total energy output of the CHP unit.

This requirement is not applicable because exhaust heat from GT-1, GT-2, and GT-3 is not recovered for other processes.

- (C) Fuels combusted in these electric generating units are limited to:
- (i) Natural gas containing no more than ten grains total sulfur per 100 dry standard cubic feet;
- (ii) Landfill gas, digester gas, stranded oilfield gas, or gaseous renewable fuel containing no more than 30 grains total sulfur per 100 dry standard cubic feet;

(iii) Liquid fuels (including liquid renewable fuel) not containing waste oils or solvents and containing less than 0.05 percent by weight sulfur.

GT-1, GT-2, and GT-3 will combust pipeline quality natural gas containing 0.2 grains per 100 dry standard cubic feet of sulfur. The natural gas will not contain waste oils or solvents.

(D) Except as provided in subsections (4)(F) and (4)(H), NO_x emissions for units 10 MW or less shall meet the following limitations based upon the date the unit is installed and the region in which it operates:

East Texas Region:

- (i) Units installed prior to January 1, 2005 and
 - (a) operating more than 300 hours per year 0.47 lb/MWh;
 - (b) operating 300 hours or less per year 1.65 lb/MWh;
- (ii) Units installed on or after January 1, 2005 and
 - (a) operating more than 300 hours per year, with a capacity greater than 250 kilowatts (kW) 0.14 lb/MWh;
 - (b) operating 300 hours or less per year 0.47 lb/MWh; or
 - (c) any unit with a capacity of 250 kW or less 0.47 lb/MWh.

West Texas Region:

- (i) Units operating more than 300 hours per year 3.11 lb/MWh;
- (ii) Units operating 300 hours or less per year 21 lb/MWh. Units certified to comply with applicable Tier 1, 2, or 3 emission standards in 40 CFR Part 89, Control of Emissions from New and In-Use Nonroad Compression-Ignition Engines, are deemed to satisfy this emission limit.

GT-1, GT-2, and GT-3 are greater than 10 MW; therefore, this requirement is not applicable.

- (E) Except as provided in subsections (4)(F) and (4)(H), NO_x emissions for units greater than 10 MW shall meet the following limitations:
 - (i) Units operating more than 300 hours per year 0.14 lb/MWh;
 - (ii) Units operating 300 hours or less per year 0.38 lb/MWh.

GT-1, GT-2, and GT-3 are greater than 10 MW and will be authorized to operate more than 300 hours per year. ENGIE will comply with the 0.14 lb/MWh emissions limitation.

(F) Electric generating units firing any gaseous or liquid fuel that is at least 75 percent landfill gas, digester gas, stranded oil field gas, or renewable fuel content by volume, shall meet a NO_x emission limit of 1.90 lb/MWh. Units inWest Texas with a capacity of 10 MW or less that fire at least 75 percent landfill gas, digester gas, stranded oilfield gases, or gaseous or liquid renewable fuel by volume, must comply with the applicable West Texas NO_x limit in subsection (4)(D).

GT-1, GT-2, and GT-3 will not fire any of the fuels described in this requirement; therefore, this requirement is not applicable.

(G) To ensure continuing compliance with the emissions limitations, the owner or operator shall re-certify a unit every 16,000 hours of operation, but no less frequently than every three years. Re-certification may be accomplished by following a maintenance schedule that the manufacturer certifies will ensure continued compliance with the required NO_x standard or by third party testing of the unit using appropriate EPA reference methods, California Air Resources Board methods, or equivalent alternative testing methods approved by the executive director to demonstrate that the unit still meets the required emission standards. After re-certification, the unit must operate on the same fuel(s) for which the unit was re-certified.

ENGIE will recertify GT-1, GT-2, and GT-3 as applicable.

- (H) The NO_x emission limits in subsections (4)(D)-(4)(F) are subject to the following exceptions:
 - (i) The hourly NO_x emission limits do not apply at times when the ambientair temperature at the location of the unit is less than 0 degrees Fahrenheit.
 - (ii) At times when a unit is operating at less than 80% of rated load, an alternative NO_x emission standard for that unit may be determined by multiplying the applicable emission standard in subsections (4)(D)-(4)(F) by the rated load of the EGU (in MW), to produce an allowable hourly mass NO_x emission rate. In order to use this alternative standard, an owner or operator must maintain records that demonstrate compliance with the alternative emission standard, and make such records available to the TCEQ or any local air pollution control agency with jurisdiction upon request.

GT-1, GT-2, and GT-3 will comply with the NO_X emissions limit in subsection (4)(E)(i) of this Standard Permit; therefore, the NO_X emissions limit exceptions are not applicable.

Technical data for the SGT6-8000H

Simple cycle power generation

Combined cycle power generation

Physical dimensions

Performance data for simple cycle power generation

_	
Gross power output	310 MW
Fuel (examples)	Natural gas, LNG, sour gases, distillate oil, biodiesel, Arabian Super Light crude oil (ASL), kerosene, jet fuel, condensate. Other fuels on request
Frequency	60 Hz
Gross efficiency	40.4%
Gross heat rate	8920 kJ/kWh (8455 Btu/kWh)
Turbine speed	3,600 rpm
Pressure ratio	21.0:1
Exhaust mass flow	650 kg/s (1,433 lb/s)
Exhaust temperature	645°C (1,193°F)
NO _x emissions	≤ 25 ppmvd at 15% O₂ on fuel gas (without water injection for NO _x control), ≤ 42 ppmvd at 15% O₂ on fuel oil (with water injection for NO _x control)