

Change to Registration for Electric Generating Unit Standard Permit

Registration No. 167033

Remy Jade Power Station Barrett, Harris County

Regulated Entity No. RN111340964 Customer Reference No. CN605940451

Submitted To:

Texas Commission on Environmental Quality Air Division P.O. Box 13087 Austin, Texas 78711-3087

January, 2025

TABLE OF CONTENTS

1.0	INTRODUCTION	1
1.1	PERMIT CHANGES	
2.0	PROCESS DESCRIPTION	3
2.1 2.2 2.3		3
3.0	COMPLIANCE WITH REQUIREMENTS OF 30 TAC §116.610 AND 116.615	е
3.1 3.2	O Company of the comp	
4 0	COMPLIANCE WITH REQUIREMENTS OF THE EGU STANDARD PERMIT	11

APPENDICES:

APPENDIX A TCEQ FORMS

APPENDIX B EMISSION CALCULATONS

1.0 INTRODUCTION

Remy Jade Generating, LLC (Remy Jade) owns the Remy Jade Power Station (the Plant), comprised of six natural gas-fired simple cycle combustion turbine generators (CTG) and ancillary equipment near Barrett, Harris County, Texas. Construction and operation of these electric generating units (EGUs) are authorized under Texas Commission on Environmental Quality (TCEQ) Air Quality Standard Permit for Electric Generating Units (EGU Standard Permit), Registration No. 167033, issued on November 22, 2021. This submittal for a change to the registration addresses implementation of peak firing and wet compression as well as correcting issues identified with the Standard Permit Maximum Emission Rates Table. This application has been prepared following guidance obtained from TCEQ staff in a pre-permit meeting held on October 31, 2024.

1.1 Permit Changes

Peak Firing and Wet Compression

For the LM6000 model combustion turbine, one of the primary parameters used by the control system to limit the maximum firing rate is the temperature at the inlet to the low pressure turbine (the "T48" temperature). The CTG efficiency and power output increase as the T48 temperature increases, but higher temperatures increase wear on turbine components, requiring shorter overhaul cycles. The base setpoint for T48 is 1,600 °F, and the turbine controls will limit the natural gas fuel flow to maintain the temperature below 1,600 °F. Operations of the CTG are affected by ambient conditions, such that during summer conditions the hot inlet air contributes to the T48 temperature, and the CTG controls have to limit the firing rate (and therefore reduce the megawatt power output) more than during a cold winter day. This loss in power output on hot days unfortunately coincides with some of the highest electricity demand. Peak firing is an option available to recover some of the lost power output on a limited basis.

Under peak firing, the T48 setpoint is increased slightly, allowing the CTG to burn more fuel and produce more power. At the maximum level of peak firing we anticipate using, up to 4 MW of power could be recovered. However, the increased wear significantly shortens the time between major overhauls, by up to an 8x factor. The increased cost of shortening the overhaul cycle means that peak firing will only be employed for a minimal number of hours during times of very high demand, where the high sales price of power justifies the cost of peak firing. Based on historical power pricing in the Houston market, we anticipate up to 250 hours per year of peak firing. Note that this is not an increase in the projected number of operating hours because at this price point, the units are expected to be dispatched anyway.

The CTGs utilize water injection technologies for power augmentation. Atomized water is injected into the airflow on the compressor side of the combustion turbine, increasing the mass flow. Rapid evaporation of the water spray cools the airflow, increasing its density and allowing higher inlet air mass flow rates. These actions result in the CTG recapturing output capacity that would be lost during hot summer conditions. Various water injection power augmentation technologies are available, differing primarily on the location where the injection occurs, the amount of water that can be injected, and the size of the water droplets. The units are currently

authorized for two technologies, inlet fogging and Water Spray for Power Augmentation (WSPA). Wet compression, an additional power augmentation option where water injection occurs at the high pressure compressor, will be added to the units. The water injection systems will be optimized to accommodate peak firing.

Short Term CTG Emission Rates

As noted above, CTG operations are impacted by ambient conditions. In the initial application, emission rate scenarios for short term hourly and annual emissions were calculated based on nominal CTG performance at ISO conditions (59 degrees Fahrenheit). However, the units can operate at higher heat input rates on cold winter days. Revised short term lb/hr emissions and calculations are shown on Table 1(a) and Table B-1, to account for winter weather conditions.

Standard Permit Maximum Emission Rates Table

During a review of the standard permit registration, it was discovered that an error was made in the initial application for the permit. For all six CTGs, the short-term emission limit for volatile organic compounds (VOC) during Maintenance, Startup, and Shut Down (MSS) operations was shown as 2.32 pounds per hour (lb/hr), which is less than the short-term limit for VOC for normal operations. The emission limit for MSS operations should not be lower than the limit during normal operations. Remy Jade is requesting to increase the short-term MSS VOC limit to 3.6 lb/hr to match the peak firing rate normal operating scenario. No change is requested to the annual VOC ton per year limit.

2.0 PROCESS DESCRIPTION

2.1 Combustion Turbine Generators

The Plant is comprised of six natural gas-fired simple cycle combustion turbine generators and ancillary equipment. The combustion turbine model installed is the General Electric (GE) LM6000, nominally rated at 50 megawatts (MW) output. In each of the simple cycle units, ambient is drawn in through the air inlet and enters the compressor section of the CTG. Water injection systems are employed for power augmentation, injecting atomized water into the airflow on the compressor side of the unit, increasing the mass flow. Rapid evaporation of the water spray cools the airflow, allowing higher inlet air mass flow rates, resulting in the CTG recapturing output capacity that would be lost during hot summer conditions. Natural gas is mixed with the compressed inlet air and combusted in the combustor section of the CTG. A water injection system is used to reduce the emissions of NOx formed in the combustors. The hot combustion gases expand through the unit across turbine blades, causing rotation of the turbine shafts, which in turn drive the compressor sections and an electric generator, producing electricity. The hot exhaust then pass through an oxidation catalyst to reduce CO and VOC emissions and subsequently pass through a selective catalytic reduction (SCR) system to reduce NOx emissions before exiting though a stack (Emission Point Numbers [EPNs] CT-1 through CT-6). A process flow diagram is included at the end of this section.

2.2 Startup/Shutdown Activities

Startup and shutdown of the CTGs are part of the regularly scheduled operations at the Plant. Startup and shutdown periods for the units are defined by monitored operating conditions. The startup period begins when an initial flame detection signal is recorded in the plant's data acquisition and handling system (DAHS) and ends when the startup load ramping is complete, CO and SCR catalysts attain operating temperatures, and emissions have been controlled in a steady state to meet the normal operations emission limits. The shutdown period begins when a shutdown signal is initiated in the CTG controller and ends when a flame detection signal is no longer recorded in the plant's DAHS. The duration of a startup for a GE LM6000 can vary between 10 and 45 minutes; however, the average duration of a startup typically lasts about 15 minutes. Because startups for this combustion turbine model can occur rapidly, it is possible to start up a unit twice in a 60-minute period. Therefore, the calculated maximum hourly startup emission rate is based upon two startups and shutdowns in a 60-minute period.


During startup and shutdown periods, NO_X , CO, and NH_3 are emitted at higher levels than during normal operating conditions. During startup, higher NO_X emissions occur during the transition period before the water injection system can achieve optimal control and before the SCR catalyst bed reaches the optimal operating temperature range. During startup and shutdown, higher CO emissions will result due to incomplete combustion because of the low firing levels and the reduced effectiveness of the oxidation catalyst until it reaches its optimal operating temperature range. Higher NH_3 emissions may occur during startup while the SCR is coming into service. The maximum one-hour emissions resulting from startups and shutdowns have been identified in Table 1(a).

2.3 Ancillary Equipment

The standard permit registration includes ancillary equipment at the site to support operation of the turbines. This equipment includes the following:

- A natural gas delivery system to fuel the CTGs;
- An ammonia delivery system for the SCR; and
- Lube oil and hydraulic oil systems.

COMBUSTION TURBINE GENERATORS EPN: CT-1 THROUGH CT-6



	REMY JADE POWER STATION	EGU Standard Permit Registration			
	PROCESS FLOW DIAGRAM	Drawn by:	E Rapier	Date:	01/15/25
		Checked by:	J Coleman	Sheet:	1 of 1

3.0 COMPLIANCE WITH REQUIREMENTS OF 30 TAC §116.610 AND 116.615

The following discussion presents the requirements of 30 TAC §116.610 and §116.615 and explains how Remy Jade complies with each of the requirements.

3.1 §116.610. Applicability

- (a) Under the TCAA, §382.051, a project that meets the requirements for a standard permit listed in this subchapter or issued by the commission is hereby entitled to the standard permit, provided the following conditions listed in this section are met. For the purposes of this subchapter, project means the construction or modification of a facility or a group of facilities submitted under the same registration:
 - (1) Any project that results in a net increase in emissions of air contaminants from the project other than water, nitrogen, ethane, hydrogen, oxygen, or greenhouse gases (GHGs) as defined in §101.1 of this title (relating to Definitions), or those for which a national ambient air quality standard has been established must meet the emission limitations of §106.261 of this title (relating to Facilities (Emission Limitations)), unless otherwise specified by a particular standard permit.
 - Per section 3(A) of the EGU Standard Permit, units that meet the conditions of the Standard Permit do not have to meet § 116.610(a)(1).
 - (2) Construction or operation of the project must be commenced prior to the effective date of a revision to this subchapter under which the project would no longer meet the requirements for a standard permit.

There is no pending revision to this subchapter.

- (3) The proposed project must comply with the applicable provisions of the Federal Clean Air Act (FCAA), §111 (concerning New Source Performance Standards) as listed under 40 Code of Federal Regulations (CFR) Part 60, promulgated by the United States Environmental Protection Agency (EPA).
 - The combustion turbines are subject to New Source Performance Standard (NSPS) in 40 CFR Part 60, Subpart KKKK (Standards of Performance for Stationary Combustion Turbines) and Subpart TTTT (Standards of Performance for Greenhouse Gas Emissions for Electric Generating Units). The units are able to comply with all applicable requirements.
- (4) The proposed project must comply with the applicable provisions of FCAA, §112 (concerning Hazardous Air Pollutants) as listed under 40 CFR 61, promulgated by the EPA;
 - There are no Subparts under 40 CFR Part 61 that are applicable to facilities affected by this registration.
- (5) The proposed project must comply with the applicable maximum achievable control technology standards as listed under 40 CFR Part 63, promulgated by the

EPA under FCAA, §112 or as listed under Chapter 113, Subchapter C of this title (relating to National Emissions Standards for Hazardous Air Pollutants for Source Categories (FCAA, §112, 40 CFR Part 63)).

40 CFR Part 63, Subpart YYYY, does not apply to the combustion turbines because the site is not a major source of hazardous air pollutants.

(6) If subject to Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program) the proposed facility, group of facilities, or account must obtain allocations to operate.

The Plant is subject to Chapter 101, Subchapter H, Division 3. Remy Jade will obtain the necessary allowances and comply with the NO_X Mass Cap and Trade Program.

(b) Any project that constitutes a new major stationary source or major modification as defined in §116.12 of this title (relating to Nonattainment and Prevention of Significant Deterioration Review Definitions) because of emissions of air contaminants other than greenhouse gases is subject to the requirements of §116.110 of this title (relating to Applicability) rather than this subchapter. Notwithstanding any provision in any specific standard permit to the contrary, any project that constitutes a new major stationary source or major modification which is subject to Subchapter B, Division 6 of this chapter (relating to Prevention of Significant Deterioration Review) due solely to emissions of greenhouse gases may use a standard permit under this chapter for air contaminants that are not greenhouse gases.

At the pre-permit meeting, TCEQ staff determined the proposed project should not be reviewed as a stand-alone project, but it should be aggregated with the original application from 2021, and a retrospective applicability review should be conducted. In a retrospective review, the previous determination of applicability or non-applicability of NNSR or PSD is reviewed again, comparing the modified project emissions against the Major Source thresholds in effect at the retrospective date, to ensure that the project would not have triggered major source NSR at the time of the previous permit issuance.

In the current application, the proposed project is aggregated with the original project, and the retrospective review has been recalculated. Tables 1F and 2F present the project emissions and document that they are less than the NOx and VOC major source thresholds applicable to the retrospective review, therefore, NNSR is not triggered.

The PSD Major Source threshold for a simple cycle power plant is 250 tons/yr of a PSD regulated pollutant pursuant to 40 CFR §52.21(b)(1)(i)(b). As documented on Table 1F, the Plant will not be a Major Source for PSD applicability purposes; therefore, PSD review is not triggered.

(c) Persons may not circumvent by artificial limitations the requirements of §116.110 of this title.

Remy Jade will not circumvent the requirements of §116.110.

(d) Any project involving a proposed affected source (as defined in §116.15(1) of this title (relating to Section 112(g) Definitions)) shall comply with all applicable requirements under Subchapter E of this chapter (relating to Hazardous Air Pollutants: Regulations Governing Constructed or Reconstructed Major Sources (FCAA, §112(g), 40 CFR Part 63)). Affected sources subject to Subchapter E of this chapter may use a standard permit under this subchapter only if the terms and conditions of the specific standard permit meet the requirements of Subchapter E of this chapter.

The project will not involve an affected source that is subject to Subchapter E.

3.2 §116.615. General Conditions

The following general conditions are applicable to holders of standard permits but will not necessarily be specifically stated within the standard permit document.

- (1) Protection of public health and welfare. The emissions from the facility, including dockside vessel emissions, must comply with all applicable rules and regulations of the commission adopted under Texas Health and Safety Code, Chapter 382, and with intent of the TCAA, including protection of health and property of the public.
- (2) Standard permit representations. All representations with regard to construction plans, operating procedures, and maximum emission rates in any registration for a standard permit become conditions upon which the facility or changes thereto, must be constructed and operated. It is unlawful for any person to vary from such representations if the change will affect that person's right to claim a standard permit under this section. Any change in condition such that a person is no longer eligible to claim a standard permit under this section requires proper authorization under §116.110 of this title (relating to Applicability). If the facility remains eligible for a standard permit, the owner or operator of the facility shall notify the executive director of any change in conditions which will result in a change in the method of control of emissions, a change in the character of the emissions, or an increase in the discharge of the various emissions as compared to the representations in the original registration or any previous notification of a change in representations. Notice of changes in representations must be received by the executive director no later than 30 days after the change.
- (3) Standard permit in lieu of permit amendment. All changes authorized by standard permit to a facility previously permitted under §116.110 of this title (relating to Applicability) shall be administratively incorporated into that facility's permit at such time as the permit is amended or renewed.
- (4) Construction progress. Start of construction, construction interruptions exceeding 45 days, and completion of construction shall be reported to the appropriate regional office not later than 15 working days after occurrence of the event, except where a different time period is specified for a particular standard permit.
- (5) Start-up notification.
 - (A) The appropriate air program regional office of the commission and any other air pollution control program having jurisdiction shall be notified prior to the commencement of operations of the facilities authorized by a standard permit in such a manner that a representative of the executive director may be present.

- (B) For phased construction, which may involve a series of units commencing operations at different times, the owner or operator of the facility shall provide separate notification for the commencement of operations for each unit.
- (C) Prior to beginning operations of the facilities authorized by the permit, the permit holder shall identify to the Office of Permitting, Remediation, and Registration the source or sources of allowances to be utilized for compliance with Chapter 101, Subchapter H, Division 3 of this title (relating to Mass Emissions Cap and Trade Program).
- (D) A particular standard permit may modify start-up notification requirements.
- (6) Sampling requirements. If sampling of stacks or process vents is required, the standard permit holder shall contact the Office of Air Quality and any other air pollution control program having jurisdiction prior to sampling to obtain the proper data forms and procedures. All sampling and testing procedures must be approved by the executive director and coordinated with the regional representatives of the commission. The standard permit holder is also responsible for providing sampling facilities and conducting the sampling operations or contracting with an independent sampling consultant.
- (7) Equivalency of methods. The standard permit holder shall demonstrate or otherwise justify the equivalency of emission control methods, sampling or other emission testing methods, and monitoring methods proposed as alternatives to methods indicated in the conditions of the standard permit. Alternative methods must be applied for in writing and must be reviewed and approved by the executive director prior to their use in fulfilling any requirements of the standard permit.
- (8) Recordkeeping. A copy of the standard permit along with information and data sufficient to demonstrate applicability of and compliance with the standard permit shall be maintained in a file at the plant site and made available at the request of representatives of the executive director, the EPA, or any air pollution control program having jurisdiction. For facilities that normally operate unattended, this information shall be maintained at the nearest staffed location within Texas specified by the standard permit holder in the standard permit registration. This information must include, but is not limited to, production records and operating hours. Additional recordkeeping requirements may be specified in the conditions of the standard permit. Information and data sufficient to demonstrate applicability of and compliance with the standard permit must be retained for at least two years following the date that the information or data is obtained. The copy of the standard permit must be maintained as a permanent record.
- (9) Maintenance of emission control. The facilities covered by the standard permit may not be operated unless all air pollution emission capture and abatement equipment is maintained in good working order and operating properly during normal facility operations. Notification for emissions events and scheduled maintenance shall be made in accordance with §101.201 and §101.211 of this title (relating to Emissions Event Reporting and Recordkeeping Requirements; and Scheduled Maintenance, Startup, and Shutdown Reporting and Recordkeeping).
- (10) Compliance with rules. Registration of a standard permit by a standard permit applicant constitutes an acknowledgment and agreement that the holder will comply with all rules, regulations, and orders of the commission issued in conformity with the TCAA and the conditions precedent to the claiming of the standard permit. If more than one state or

federal rule or regulation or permit condition is applicable, the most stringent limit or condition shall govern. Acceptance includes consent to the entrance of commission employees and designated representatives of any air pollution control program having jurisdiction into the permitted premises at reasonable times to investigate conditions relating to the emission or concentration of air contaminants, including compliance with the standard permit.

Remy Jade will adhere to these General Conditions and will operate the units authorized by the Standard Permit in compliance with the above subparagraphs.

4.0 COMPLIANCE WITH REQUIREMENTS OF THE EGU STANDARD PERMIT

The following discussion presents the requirements of the EGU Standard Permit and explains how Remy Jade complies with each of the requirements.

Air Quality Standard Permit for Electric Generating Units Effective Date May 16, 2007

This standard permit authorizes electric generating units that generate electricity for use by the owner or operator and/or generate electricity to be sold to the electric grid, and that meet all of the conditions listed below.

(1) Applicability

(A) This standard permit may be used to authorize electric generating units installed or modified after the effective date of this standard permit and that meet the requirements of this standard permit.

This Standard Permit is being used to authorize six EGUs that meet the requirements of the permit.

(B) This standard permit may not be used to authorize boilers. Boilers may be authorized under the Air Quality Standard Permit for Boilers; 30 TAC § 106.183, Boilers, Heaters, and Other Combustion Devices; or a permit issued under the requirements of 30 TAC Chapter 116.

The units authorized by the Standard Permit are simple cycle gas turbines, not boilers.

(2) Definitions

- (A) East Texas Region All counties traversed by or east of Interstate Highway 35 or Interstate Highway 37, including Bosque, Coryell, Hood, Parker, Somervell and Wise Counties.
- (B) Installed a generating unit is installed on the site when it begins generating electricity.
- (C) West Texas Region Includes all of the state not contained in the East Texas Region.
- (D) Renewable fuel fuel produced or derived from animal or plant products, byproducts or wastes, or other renewable biomass sources, excluding fossil fuels. Renewable fuels may include, but are not limited to, ethanol, biodiesel, and biogas fuels.

This section contains no requirements.

(3) Administrative Requirements

(A) Electric generating units shall be registered in accordance with 30 TAC § 116.611, Registration to Use a Standard Permit, using a current Form PI-1S. Units that meet the conditions of this standard permit do not have to meet 30 TAC § 116.610(a)(1), Applicability.

A completed Form PI-1S is included in this registration package.

(B) Registration applications shall comply with 30 TAC § 116.614, Standard Permit Fees, for any single unit or multiple units at a site with a total generating capacity of 1 megawatt (MW) or greater. The fee for units or multiple units with a total generating capacity of less than 1 MW at a site shall be \$100.00. The fee shall be waived for units or multiple units with a total generating capacity of less than 1 MW at a site that have certified nitrogen oxides (NO_X) emissions that are less than 10 percent of the standards required by this standard permit.

A registration fee of \$900 has been submitted to the TCEQ.

(C) No owner or operator of an electric generating unit shall begin construction and/or operation without first obtaining written approval from the executive director.

This application does not authorize any new electric generating units..

- (D) Records shall be maintained and provided upon request to the Texas Commission on Environmental Quality (TCEQ) for the following:
 - (i) Hours of operation of the unit;
 - (ii) Maintenance records, maintenance schedules, and/or testing reports for the unit to document re-certification of emission rates as required by subsection (4)(G) below; and
 - (iii) Records to document compliance with the fuel sulfur limits in subsection (4)(C).

Remy Jade will maintain the applicable records.

(E) Electric generators powered by gas turbines must meet the applicable conditions, including testing and performance standards, of Title 40 Code of Federal Regulations (CFR) Part 60, Subpart GG, Standards of Performance for Stationary Gas Turbines, and applicable requirements of 40 CFR Part 60 Subpart KKKK, Standards of Performance for Stationary Combustion Turbines.

The combustion turbines meet the requirements of 40 CFR Part 60, Subpart KKKK.

(F) Compliance with this standard permit does not exempt the owner or operator from complying with any applicable requirements of 30 TAC Chapter 117, Control of Air Pollution from Nitrogen Compounds, or 30 TAC Chapter 114, Control of Air Pollution from Motor Vehicles.

Remy Jade will comply with the applicable requirements of 30 TAC Chapters 114 and 117.

- (4) General Requirements
 - (A) Emissions of NO_X from the electric generating unit shall be certified by the manufacturer or by the owner or operator in pounds of pollutant per megawatt hour (lb/MWh). This certification must be displayed on the name plate of the unit or on a

label attached to the unit. Test results from U.S. Environmental Protection Agency (EPA) reference methods, California Air Resources Board methods, or equivalent alternative testing methods approved by the executive director used to verify this certification shall be provided upon request to the TCEQ. The unit must operate on the same fuel(s) for which the unit was certified.

The emissions certification is displayed on the units and test results will be provided to the TCEQ upon request. The units burn natural gas.

- (B) Electric generating units that use combined heat and power (CHP) may take credit for the heat recovered from the exhaust of the combustion unit to meet the emission standards in subsections (4)(D), (4)(E), and (4)(F). Credit shall be at the rate of one MWh for each 3.4 million British Thermal Units of heat recovered. The following requirements must be met to take credit for CHP for units not sold and certified as an integrated package by the manufacturer:
 - (i) The owner or operator must provide as part of the application documentation of the heat recovered, electric output, efficiency of the generator alone, efficiency of the generator including CHP, and the use for the non-electric output, and
 - (ii) The heat recovered must equal at least 20 percent of the total energy output of the CHP unit.

The combustion turbine units do not use combined heat and power.

- (C) Fuels combusted in these electric generating units are limited to:
 - (i) Natural gas containing no more than ten grains total sulfur per 100 dry standard cubic feet;
 - (ii) Landfill gas, digester gas, stranded oilfield gas, or gaseous renewable fuel containing no more than 30 grains total sulfur per 100 dry standard cubic feet; or
 - (iii) Liquid fuels (including liquid renewable fuel) not containing waste oils or solvents and containing less than 0.05 percent by weight sulfur.

The fuel combusted is natural gas containing no more than ten grains total sulfur per 100 dry standard cubic feet.

(D) Except as provided in subsections (4)(F) and (4)(H), NO_X emissions for units 10 MW or less shall meet the following limitations based upon the date the unit is installed and the region in which it operates:

East Texas Region:

- (i) Units installed prior to January 1, 2005 and
 - (a) operating more than 300 hours per year 0.47 lb/MWh;
 - (b) operating 300 hours or less per year 1.65 lb/MWh;
- (ii) Units installed on or after January 1, 2005 and
 - (a) operating more than 300 hours per year, with a capacity greater than 250 kilowatts (kW) 0.14 lb/MWh;
 - (b) operating 300 hours or less per year 0.47 lb/MWh; or

(c) any unit with a capacity of 250 kW or less - 0.47 lb/MWh.

West Texas Region:

- (i) Units operating more than 300 hours per year 3.11 lb/MWh;
- (ii) Units operating 300 hours or less per year 21 lb/MWh.

Units certified to comply with applicable Tier 1, 2, or 3 emission standards in 40 CFR Part 89, Control of Emissions from New and In-Use Nonroad Compression-Ignition Engines, are deemed to satisfy this emission limit.

This section does not apply as the units are rated greater than 10 MW in output capacity.

- (E) Except as provided in subsections (4)(F) and (4)(H), NO_X emissions for units greater than 10 MW shall meet the following limitations:
 - (i) Units operating more than 300 hours per year 0.14 lb/MWh;
 - (ii) Units operating 300 hours or less per year 0.38 lb/MWh.

The units operate more than 300 hours per year and meet the NO_X emission certification requirement of 0.14 lb/MWh when the units are operating at 80% and greater of the rated load.

(F) Electric generating units firing any gaseous or liquid fuel that is at least 75 percent landfill gas, digester gas, stranded oil field gas, or renewable fuel content by volume, shall meet a NO_X emission limit of 1.90 lb/MWh. Units in West Texas with a capacity of 10 MW or less that fire at least 75 percent landfill gas, digester gas, stranded oilfield gases, or gaseous or liquid renewable fuel by volume, must comply with the applicable West Texas NO_X limit in subsection (4)(D).

This section does not apply as the units fire natural gas.

(G) To ensure continuing compliance with the emissions limitations, the owner or operator shall re-certify a unit every 16,000 hours of operation, but no less frequently than every three years. Re-certification may be accomplished by following a maintenance schedule that the manufacturer certifies will ensure continued compliance with the required NO_X standard or by third party testing of the unit using appropriate EPA reference methods, California Air Resources Board methods, or equivalent alternative testing methods approved by the executive director to demonstrate that the unit still meets the required emission standards. After recertification, the unit must operate on the same fuel(s) for which the unit was recertified

Remy Jade will comply with the recertification requirements of this subparagraph.

- (H) The NO_X emission limits in subsections (4)(D)-(4)(F) are subject to the following exceptions:
 - (i) The hourly NO_X emission limits do not apply at times when the ambient air temperature at the location of the unit is less than 0 degrees Fahrenheit.

Remy Jade is aware that the hourly NO_X emission limit will not apply when the local ambient temperature is less than 0 degrees Fahrenheit.

(ii) At times when a unit is operating at less than 80% of rated load, an alternative NO_X emission standard for that unit may be determined by multiplying the applicable emission standard in subsections (4)(D)-(4)(F) by the rated load of the EGU (in MW), to produce an allowable hourly mass NO_X emission rate. In order to use this alternative standard, an owner or operator must maintain records that demonstrate compliance with the alternative emission standard, and make such records available to the TCEQ or any local air pollution control agency with jurisdiction upon request.

Remy Jade will maintain the appropriate records if choosing to demonstrate compliance with the alternative NO_X emission standard. Maximum NO_X mass emissions during startup and shutdown of the turbines are presented in the emission calculations in Appendix B and are not considered subject to the lb/MWh normal operating limits specified in this paragraph because the units are in startup mode and not generating electricity for a portion of that time.

APPENDIX A TCEQ FORMS

- FORM PI-1S
- TABLE 1(A)
- TABLE 1F
- TABLE 2F

Form PI-1S Registrations for Air Standard Permit (Page 1)

I. Registrant Information
A. Company or Other Legal Customer Name:
Remy Jade Generating, LLC
B. Company Official Contact Information (Mr. Mrs. Ms. Other:)
Name: Jennifer Coleman
Title: Director Regulatory Compliance
Mailing Address: 2001 PROENERGY Blvd
City: Sedalia
State: MO
ZIP Code: 65301
Telephone No.: (660) 596-7828
Fax No.:
Email Address: jcoleman@proenergyservices.com
All permit correspondence will be sent via email.
C. Technical Contact Information (Mr. Mrs. Mrs. Other:)
Name: Edward Rapier
Title: Senior Environmental Engineer
Company Name: PROENERGY Services LLC
Mailing Address: 2001 PROENERGY Blvd
City: Sedalia
State: MO
ZIP Code: 65301
Telephone No.: (737) 781-3708
Fax No.:
Email Address: erapier@proenergyservices.com
II. Facility and Site Information
A. Name and Type of Facility
Facility Name: Remy Jade Power Station
Type of Facility: ⊠ Permanent □ Temporary

Form PI-1S Registrations for Air Standard Permit (Page 2)

II. Facility and Site Information <i>(continued)</i>
For portable units, please provide the serial number of the equipment being authorized below.
Serial No(s):
B. Facility Location Information
Street Address:
If there is no street address, provide written driving directions to the site and provide the closest city or town, county, and ZIP code for the site (attach description if additional space is needed).
Approximately 3 miles southeast of Barrett, TX near Danek Rd. at a point approximately 1 mile west
of its intersection with FM 1942 Rd.
City: Barrett
County: Harris
ZIP Code: 77532
C. Core Data Form (required for Standard Permits 6006, 6007, and 6013).
Is the Core Data Form (TCEQ Form 10400) attached? ☐ Yes ☒ No
Customer Reference Number (CN): CN605940451
Regulated Entity Number (RN): RN111340964
D. TCEQ Account Identification Number (if known):
E. Type of Action
☐ Initial Application ☑ Change to Registration ☐ Renewal ☐ Renewal Certification
For Change to Registration, Renewal, or Renewal Certification actions provide the following:
Registration Number: 167033
Expiration Date: 11/22/2031
F. Standard Permit Claimed: 6005 - Electric Generating Unit
G. Previous Standard Exemption or PBR Registration Number:
Is this authorization for a change to an existing facility previously authorized $\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \$
If "Yes," enter previous standard exemption number(s) and PBR registration number(s) and associated effective date in the spaces provided below.

Form PI-1S Registrations for Air Standard Permit (Page 3)

II. Facility and Site Information (continued)						
H. Other Facilities at this Site Authorized by Standard Exemption, PBR, or Standard Permit						
Are there any other facilities at this site that are authorized by an Air Standard						
If "Yes," enter standard exemption number(s), PBR registration number(s), and Standard Permit registration number(s), and associated effective date in the spaces provided below.						
Standard Exemption, PBR Registration, and Standard Permit Registration Number(s) and Effective Date(s)						
Standard Permit Registration 168123, 11/10/2022						
I. Other Air Preconstruction Permits						
Are there any other air preconstruction permits at this site? ☐ Yes ☒ No						
If "Yes," enter permit number(s) in the spaces provided below.						
J. Affected Air Preconstruction Permits						
Does the standard permit directly affect any permitted facility? ☐ Yes ☒ No						
If "Yes," enter permit number(s) in the spaces provided below.						
K. Federal Operating Permit (FOP) Requirements						
Is this facility located at a site that is required to obtain a Superior Yes No To Be Determined FOP pursuant to 30 TAC Chapter 122?						
Check the requirements of 30 TAC Chapter 122 that will be triggered if this standard permit is approved (check all that apply).						
☐ Initial Application for a FOP ☐ Significant Revision for a SOP ☒ Minor Revision for a SOP						
☐ Operational Flexibility/Off Permit Notification for a SOP ☐ Revision for a GOP						
☐ To be Determined ☐ None						
Identify the type(s) of FOP issued and/or FOP application(s) submitted/pending for the site. (check all that apply)						
SOP GOP GOP application/revision (submitted or under APD review) N/A						
SOP application/revision (submitted or under APD review)						

Form PI-1S Registrations for Air Standard Permit (Page 4)

III. Fee Information <i>(go to www.tceq.texas.gov/epay to pay online)</i>
A. Fee Amount: \$900
B. Voucher number from ePay: To be paid online at time of submittal
IV. Public Notice (if applicable)
A. Responsible Person (Mr. Mrs. Ms. Other:)
Name:
Title:
Company:
Mailing Address:
City:
State:
ZIP Code:
Telephone No.:
Fax No.:
Email Address:
B. Technical Contact (Mr. Mrs. Ms. Other):
Name:
Title:
Company:
Mailing Address:
City:
State:
ZIP Code:
Telephone No.:
Fax No.:
Email Address:
C. Bilingual Notice
Is a bilingual program required by the Texas Education Code in the School District?
Are the children who attend either the elementary school or the middle school closest

Form PI-1S Registrations for Air Standard Permit (Page 5)

IV.	Public Notice (continued) (if applicable) (continued)	
If "Ye	es," list which language(s) are required by the bilingual program below?	
D.	Small Business Classification and Alternate Public Notice	
	s this company (including parent companies and subsidiary companies) fewer than 100 employees or less than \$6 million in annual gross receipts?	☐ Yes ☐ No
Is the	e site a major source under 30 TAC Chapter 122, Federal Operating Permit Program?	☐ Yes ☐ No
	he site emissions of any individual regulated air contaminant equal to or ter than 50 tpy?	☐ Yes ☐ No
	he site emissions of all regulated air contaminant combined equal to eater than 75 tpy?	☐ Yes ☐ No
V.	Renewal Certification Option	
A.	Does the permitted facility emit an air contaminant on the Air Pollutant Watch List, and is the permitted facility located in an area on the watch list?	☐ Yes ☐ No
B.	For facilities participating in the Houston/Galveston/Brazoria area (HGB) cap and trade program for highly reactive VOCs (HRVOCs), do the HRVOCs need to be speciated on the maximum allowable emission rates table (MAERT)?	☐ Yes ☐ No
C.	Does the company and/or site have an unsatisfactory compliance history?	☐ Yes ☐ No
D.	Are there any applications currently under review for this standard permit registration?	☐ Yes ☐ No
E.	Are scheduled maintenance, startup, or shutdown emissions required to be included in the standard permit registration at this time?	☐ Yes ☐ No
F.	Are any of the following actions being requested at the time of renewal:	☐ Yes ☐ No
1.	Are there any facilities that have been permanently shutdown that are proposed to be removed from the standard permit registration?	☐ Yes ☐ No
2.	Do changes need to be made to the standard permit registration in order to remain in compliance?	☐ Yes ☐ No
3.	Are sources or facilities that have always been present and represented, but never identified in the standard permit registration, proposed to be included with this renewal?	☐ Yes ☐ No
4.	Are there any changes to the current emission rates table being proposed?	☐ Yes ☐ No
certit	: If answers to all of the questions in Section V. Renewal Certification Option are "No," use fication option and skip to Section VII. of this form. If the answers to any of the questions is ewal Certification Option are "Yes," the certification option cannot be used.	
	otice is applicable and comments are received in response to the public notice, the application fy for the renewal certification option.	ation does not

Form PI-1S Registrations for Air Standard Permit (Page 6) Texas Commission on Environmental Quality

VI.	Technical Information Including State and Federal Regulatory Requirements				
Note the s	Place a check next to the appropriate box to indicate what you have included in your submittal. Note: Any technical or essential information needed to confirm that facilities are meeting the requirements of the standard permit must be provided. Not providing key information could result in an automatic deficiency and voiding of the project.				
Α.	Standard Permit requirements (Checklists are optional; however, your review will go faster if you provide applicable che	cklists.)			
_	you demonstrate that the general requirements in 30 TAC ions 116.610 and 116.615 are met?	⊠ Yes □ No			
Did y	ou demonstrate that the individual requirements of the specific standard permit are met?	⊠ Yes ☐ No			
B.	Confidential Information (All pages properly marked "CONFIDENTIAL").	☐ Yes ⊠ No			
C.	Process Flow Diagram.	⊠ Yes ☐ No			
D.	Process Description.				
E.	Maximum Emissions Data and Calculations.	⊠ Yes ☐ No			
F.	Plot Plan.	☐ Yes ⊠ No			
G.	Projected Start Of Construction Date, Start Of Operation Date, and Length of Time at Site:	⊠ Yes □ No			
Proje	ected Start of Construction (provide date): March, 2025				
Proje	ected Start of Operation (provide date): June, 2026				
Leng	th of Time at the Site: Permanent				
VII.	Delinquent Fees and Penalties				
the A	This form will not be processed until all delinquent fees and/or penalties owed to the TCEQ or the Office of the Attorney General on behalf of the TCEQ are paid in accordance with the Delinquent Fee and Penalty Protocol. For more information regarding Delinquent Fees and Penalties, go to the TCEQ website at: www.tceq.texas.gov/agency/financial/fees/delin/index.html.				

Form PI-1S Registrations for Air Standard Permit (Page 7) Texas Commission on Environmental Quality

VIII. Signature Requirements

The signature below confirms that I have knowledge of the facts included in this application and that these facts are true and correct to the best of my knowledge and belief. I further state that to the best of my knowledge and belief, the project for which application is made will not in any way violate any provision of the Texas Water Code (TWC), Chapter 7; the Texas Health and Safety Code, Chapter 382, the Texas Clean Air Act (TCAA) the air quality rules of the Texas Commission on Environmental Quality; or any local governmental ordinance or resolution enacted pursuant to the TCAA. I further state that I understand my signature indicates that this application meets all applicable nonattainment, prevention of significant deterioration, or major source of hazardous air pollutant permitting requirements. The signature further signifies awareness that intentionally or knowingly making or causing to be made false material statements or representations in the application is a criminal offense subject to criminal penalties.

Name (printed): Jennifer Coleman

Signature (original signature required):

IX. Copies of the Registration

The PI-1S application must be submitted through ePermits. No additional copies need to be sent to the Regional Office or local Air Pollution Control Program(s). The link to ePermits can be found here: www3.tceq.texas.gov/steers/.

Date:	Permit No.:	Regulated Entity No.:	Area Name:	Customer Reference No.:
01/21/2025	167033	RN111340964	Remy Jade Power Station	CN605940451

Review of applications and issuance of permits will be expedited by supplying all necessary information requested on this Table.

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-1	CT-1	Combustion Turbine 1	Normal Operating Emissions		
			NO_X	7.28	
			СО	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			CO	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO ₂	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
					15.22
			NO _X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM ₁₀		25.50
			PM _{2.5}		25.50
			SO ₂		5.82
			H ₂ SO ₄		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-2	CT-2	Combustion Turbine 2	Normal Operating Emissions		
			NO_X	7.28	
			СО	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			СО	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO ₂	1.43	
			H ₂ SO ₄	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
			NO_X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM ₁₀		25.50
			PM _{2.5}		25.50
			SO ₂		5.82
			H ₂ SO ₄		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-3	CT-3	Combustion Turbine 3	Normal Operating Emissions		
			NO_X	7.28	
			CO	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			$\mathrm{H_2SO_4}$	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			CO	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO ₂	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
			NO_X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM_{10}		25.50
			PM _{2.5}		25.50
			SO_2		5.82
			H_2SO_4		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-4	CT-4	Combustion Turbine 4	Normal Operating Emissions		
			NO_X	7.28	
			CO	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			$\mathrm{H_2SO_4}$	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			СО	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO ₂	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
			NO_X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM ₁₀		25.50
			PM _{2.5}		25.50
			SO ₂		5.82
			H ₂ SO ₄		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-5	CT-5	Combustion Turbine 5	Normal Operating Emissions		
			NO _X	7.28	
			CO	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			$\mathrm{H_{2}SO_{4}}$	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			CO	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
			NO_X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM_{10}		25.50
			PM _{2.5}		25.50
			SO ₂		5.82
			H_2SO_4		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
CT-6	CT-6	Combustion Turbine 6	Normal Operating Emissions		
			NO_X	7.28	
			CO	10.28	
			VOC	3.60	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO_2	1.43	
			$\mathrm{H_2SO_4}$	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			MSS Emissions		
			NO_X	37.21	
			CO	51.71	
			VOC	3.64	
			PM	5.88	
			PM_{10}	5.88	
			PM _{2.5}	5.88	
			SO ₂	1.43	
			H_2SO_4	0.66	
			(NH ₄) ₂ SO4	0.88	
			NH ₃	6.94	
			Combined Normal and MSS Emissions		
			NO_X		15.33
			CO		14.64
			VOC		14.64
			PM		25.50
			PM_{10}		25.50
			PM _{2.5}		25.50
			SO ₂		5.82
			$\mathrm{H}_{2}\mathrm{SO}_{4}$		2.67
			(NH ₄) ₂ SO4		3.60
			NH ₃		20.33

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY	
CT-1 through CT-6	CT-1 through CT-6	Annual Emissions Cap for	NO _X		45.65	
		Combustion Turbine 1 through	СО		43.19	
		Combustion Turbine 6	VOC		31.49	
			PM		55.31	
			PM_{10}		55.31	
			PM _{2.5}		55.31	
			SO ₂		12.63	
			H_2SO_4		5.80	
			$(NH_4)_2SO4$		7.81	
			NH ₃		46.07	
CT-LOV-1	CT-LO-1	Combustion Turbine 1 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
CT-LOV-2	CT-LO-2	Combustion Turbine 2 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
CT-LOV-3	CT-LO-3	Combustion Turbine 3 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
CT-LOV-4	CT-LO-4	Combustion Turbine 4 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM ₁₀	0.03	0.13	
			PM _{2.5}	0.03	0.13	
CT-LOV-5	CT-LO-5	Combustion Turbine 5 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
CT-LOV-6	CT-LO-6	Combustion Turbine 6 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
GEN-LOV-1	GEN-LO-1	Generator 1 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
GEN-LOV-2	GEN-LO-2	Generator 2 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM ₁₀	0.03	0.13	
 			PM _{2.5}	0.03	0.13	

EPN			Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY	
GEN-LOV-3			VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
GEN-LOV-4	GEN-LO-4	Generator 4 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
GEN-LOV-5	GEN-LO-5	Generator 5 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
GEN-LOV-6	GEN-LO-6	Generator 6 Lube Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-1	HYD-O-1	Unit 1 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-2	HYD-O-2	Unit 2 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-3	HYD-O-3	Unit 3 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-4	HYD-O-4	Unit 4 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-5	HYD-O-5	Unit 5 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
HYD-OV-6	HYD-O-6	Unit 6 Hydraulic Oil Vent	VOC	0.03	0.13	
			PM	0.03	0.13	
			PM_{10}	0.03	0.13	
			PM _{2.5}	0.03	0.13	
			PM _{2.5}	#REF!	#REF!	
VOC-FUG	VOC-FUG	VOC Fugitives	VOC	0.53	2.34	

EPN	FIN	Name	Component or Air Contaminant Name	Air Contaminant Emission Rate lb/hr	Air Contaminant Emission Rate TPY
NH3-FUG	NH3-FUG	Ammonia Fugitives	$\mathrm{NH_{3}}$	4.07	17.81
CT-MSS	CT-MSS	ILE Turbine Maintenance	VOC	0.85	0.03
			PM	4.42	0.72
			PM_{10}	4.42	0.71
			PM _{2.5}	4.41	0.71
			NH ₃	0.02	< 0.01

Date:	Permit No.:	Regulated Entity No.:	Area Name:	Customer Reference No.:	
01/21/2025	167033	RN111340964	Remy Jade Power Station	CN605940451	

Review of applications and issuance of permits will be expedited by supplying all necessary information requested on this Table.

			UTM Coordinates of Emission Point			Emission Point Discharge Parameters		Stack Exit Data			Fugitives		
EPN	FIN	NAME	Zone	East (Meters)	North (Meters)	Building Height (ft.)	Height Above Ground (ft.)	Diameter (ft.)	Velocity (fps)	Temperature (°F)	Length (ft.)	Width (ft.)	Axis Degrees
CT-1	CT-1	Combustion Turbine 1	15	305,355	3,303,642		65	10.0	122.0	850			
CT-2	CT-2	Combustion Turbine 2	15	305,330	3,303,642		65	10.0	122.0	850			
CT-3	CT-3	Combustion Turbine 3	15	305,309	3,303,642		65	10.0	122.0	850			
CT-4	CT-4	Combustion Turbine 4	15	305,284	3,303,642		65	10.0	122.0	850			
CT-5	CT-5	Combustion Turbine 5	15	305,263	3,303,643		65	10.0	122.0	850			
CT-6	CT-6	Combustion Turbine 6	15	305,238	3,303,642		65	10.0	122.0	850			
CT-LOV-1	CT-LO-1	Combustion Turbine 1 Lube Oil Vent	15	305,350	3,303,659		20	0.003	0.003	115			
CT-LOV-2	CT-LO-2	Combustion Turbine 2 Lube Oil Vent	15	305,325	3,303,659		20	0.003	0.003	115			
CT-LOV-3	CT-LO-3	Combustion Turbine 3 Lube Oil Vent	15	305,304	3,303,659		20	0.003	0.003	115			
CT-LOV-4	CT-LO-4	Combustion Turbine 4 Lube Oil Vent	15	305,279	3,303,659		20	0.003	0.003	115			
CT-LOV-5	CT-LO-5	Combustion Turbine 5 Lube Oil Vent	15	305,258	3,303,659		20	0.003	0.003	115			
CT-LOV-6	CT-LO-6	Combustion Turbine 6 Lube Oil Vent	15	305,233	3,303,659		20	0.003	0.003	115			
GEN-LOV-1	GEN-LO-1	Generator 1 Lube Oil Vent	15	305,350	3,303,669		20	0.003	0.003	115			
GEN-LOV-2	GEN-LO-2	Generator 2 Lube Oil Vent	15	305,324	3,303,668		20	0.003	0.003	115			
GEN-LOV-3	GEN-LO-3	Generator 3 Lube Oil Vent	15	305,304	3,303,669		20	0.003	0.003	115			
GEN-LOV-4	GEN-LO-4	Generator 4 Lube Oil Vent	15	305,278	3,303,669		20	0.003	0.003	115			
GEN-LOV-5	GEN-LO-5	Generator 5 Lube Oil Vent	15	305,258	3,303,669		20	0.003	0.003	115			
GEN-LOV-6	GEN-LO-6	Generator 6 Lube Oil Vent	15	305,232	3,303,669		20	0.003	0.003	115			
HYD-OV-1	HYD-O-1	Unit 1 Hydraulic Oil Vent	15	305,350	3,303,659		20	0.003	0.003	115			
HYD-OV-2	HYD-O-2	Unit 2 Hydraulic Oil Vent	15	305,325	3,303,659		20	0.003	0.003	115			
HYD-OV-3	HYD-O-3	Unit 3 Hydraulic Oil Vent	15	305,304	3,303,659		20	0.003	0.003	115			
HYD-OV-4	HYD-O-4	Unit 4 Hydraulic Oil Vent	15	305,279	3,303,659		20	0.003	0.003	115			
HYD-OV-5	HYD-O-5	Unit 5 Hydraulic Oil Vent	15	305,258	3,303,659		20	0.003	0.003	115			
HYD-OV-6	HYD-O-6	Unit 6 Hydraulic Oil Vent	15	305,233	3,303,659		20	0.003	0.003	115			
VOC-FUG	VOC-FUG	VOC Fugitives	15	305,219	3,303,617						525	250	0.0
NH3-FUG	NH3-FUG	Ammonia Fugitives	15	305,223	3,303,620						525	250	0.0
CT-MSS	CT-MSS	ILE Turbine Maintenance	15	305,225	3,303,623						525	250	0.0

Table 1F Air Quality Application Supplement Texas Commission on Environmental Quality

Permit Number:	167033								
Application Submittal Date:	01/21/2025								
Company	Remy Jade Generating, LLC								
Regulated Entity Number:	RN111340964	4							
Named Source (Y/N)	☐ Yes ☑ No								
City	Barrett								
County:	Harris County	r							
Permit Activity:	☐ New Source	☑ Mod	lification	(Retrospect	ive review ¹)				
Complete for all pollutants with a project emission inc	rease								
Questions			Ozone NOx	со	PM	PM ₁₀	PM _{2.5}	SO ₂	H ₂ SO ₄
Is nonattainment potentially applicable? (Y/N)		Yes	Yes	No	No	No	No	No	No
Is PSD potentially applicable? (Y/N)		No	No	Yes	Yes	Yes	Yes	Yes	Yes
Existing site PTE (tpy) ¹		0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Total project emissions increase (tpy from Table 2F	⁻)? ¹	36.2	45.7	43.2	58.4	58.4	58.4	12.6	5.8
Is the existing site a major source? (Y/N) ¹		No	No	No	No	No	No	No	No
If not, is the project a major source by itself? (Y/N) ¹		No	No	No	No	No	No	No	No
If site is major source, is the project increase signifi	cant? (Y/N)								
Net contemporaneous change, including proposed from Table 3F (tpy)	project,								
Major NSR Applicable? (Y/N)			No	No	No	No	No	No	No
If netting required, estimated start of construction date (MM/DD/YR):									
Beginning of Contemporaneous Period, 5 years pri	or to start of con	struction (M	M/DD/YR):						
End of Contemporaneous Period, the start of operation date (MM/DD/YR):									

1. In a retrospective review, the values used for the site PTE and Major Source threshold rates are those that were used for the previous project's applicability review. The previous project (November, 2021) used a NNSR Major Source threshold for Houston-Galveston-Brazoria area of 50 tons. The values for the project emissions increase are modified to include the new project that triggered the retrospective review.

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	NOx
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	45.65		45.65		45.65
2										
3										
4										
5										
6										
7										
8	_	_		_	_					_
9										
10										
11										
12										
							Total	Project Emis	sions Increase	45.65

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	VOC
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	31.49		31.49		31.49
2	CT-LO-1	CT-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
3	CT-LO-2	CT-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
4	CT-LO-3	CT-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
5	CT-LO-4	CT-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
6	CT-LO-5	CT-LOV-5	167033	0.00	0.00	0.13		0.13		0.13
7	CT-LO-6	CT-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
8	GEN-LO-1	GEN-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
9	GEN-LO-2	GEN-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
10	GEN-LO-3	GEN-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
11	GEN-LO-4	GEN-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
12	GEN-LO-5	GEN-LOV-5	167033	0.00	0.00	0.13		0.13		0.13

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	VOC
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
13	GEN-LO-6	GEN-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
14	HYD-O-1	HYD-OV-1	167033	0.00	0.00	0.13		0.13		0.13
15	HYD-O-2	HYD-OV-2	167033	0.00	0.00	0.13		0.13		0.13
16	HYD-O-3	HYD-OV-3	167033	0.00	0.00	0.13		0.13		0.13
17	HYD-O-4	HYD-OV-4	167033	0.00	0.00	0.13		0.13		0.13
18	HYD-O-5	HYD-OV-5	167033	0.00	0.00	0.13		0.13		0.13
19	HYD-O-6	HYD-OV-6	167033	0.00	0.00	0.13		0.13		0.13
20	VOC-FUG	VOC-FUG	167033	0.00	0.00	2.34		2.34		2.34
21	CT-MSS	CT-MSS	167033	0.00	0.00	0.03		0.03		0.03
22										
23										
24										
25										
26										
27										
28										
29										
							Tota	Project Emis	sions Increase	36.25

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	СО
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	43.19		43.19		43.19
2										
3										
4										
5										
6										
7										
8										
9										
10										
11										
12										
							Total	l Project Emis	sions Increase	43.19

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	SO2
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	12.63		12.63		12.63
2										
3										
4										
5										
6										
7										
8										
9										
10										
11	_	_								
12										
							Tota	l Project Emis	sions Increase	12.63

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	55.31		55.31		55.31
2	CT-LO-1	CT-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
3	CT-LO-2	CT-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
4	CT-LO-3	CT-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
5	CT-LO-4	CT-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
6	CT-LO-5	CT-LOV-5	167033	0.00	0.00	0.13		0.13		0.13
7	CT-LO-6	CT-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
8	GEN-LO-1	GEN-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
9	GEN-LO-2	GEN-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
10	GEN-LO-3	GEN-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
11	GEN-LO-4	GEN-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
12	GEN-LO-5	GEN-LOV-5	167033	0.00	0.00	0.13		0.13		0.13

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
13	GEN-LO-6	GEN-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
14	HYD-O-1	HYD-OV-1	167033	0.00	0.00	0.13		0.13		0.13
15	HYD-O-2	HYD-OV-2	167033	0.00	0.00	0.13		0.13		0.13
16	HYD-O-3	HYD-OV-3	167033	0.00	0.00	0.13		0.13		0.13
17	HYD-O-4	HYD-OV-4	167033	0.00	0.00	0.13		0.13		0.13
18	HYD-O-5	HYD-OV-5	167033	0.00	0.00	0.13		0.13		0.13
19	HYD-O-6	HYD-OV-6	167033	0.00	0.00	0.13		0.13		0.13
20	CT-MSS	CT-MSS	167033	0.00	0.00	0.72		0.72		0.72
21										
22										
23										
24										
25										
26										
27										
28										
29										
							Tota	Project Emis	sions Increase	58.41

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM10
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	55.31		55.31		55.31
2	CT-LO-1	CT-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
3	CT-LO-2	CT-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
4	CT-LO-3	CT-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
5	CT-LO-4	CT-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
6	CT-LO-5	CT-LOV-5	167033	0.00	0.00	0.13		0.13		0.13
7	CT-LO-6	CT-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
8	GEN-LO-1	GEN-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
9	GEN-LO-2	GEN-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
10	GEN-LO-3	GEN-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
11	GEN-LO-4	GEN-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
12	GEN-LO-5	GEN-LOV-5	167033	0.00	0.00	0.13		0.13		0.13

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM10
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
13	GEN-LO-6	GEN-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
14	HYD-O-1	HYD-OV-1	167033	0.00	0.00	0.13		0.13		0.13
15	HYD-O-2	HYD-OV-2	167033	0.00	0.00	0.13		0.13		0.13
16	HYD-O-3	HYD-OV-3	167033	0.00	0.00	0.13		0.13		0.13
17	HYD-O-4	HYD-OV-4	167033	0.00	0.00	0.13		0.13		0.13
18	HYD-O-5	HYD-OV-5	167033	0.00	0.00	0.13		0.13		0.13
19	HYD-O-6	HYD-OV-6	167033	0.00	0.00	0.13		0.13		0.13
20	CT-MSS	CT-MSS	167033	0.00	0.00	0.71		0.71		0.71
21										
22										
23										
24										
25										
26										
27										
28										
29										
										58.41

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM2.5
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	55.31		55.31		55.31
2	CT-LO-1	CT-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
3	CT-LO-2	CT-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
4	CT-LO-3	CT-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
5	CT-LO-4	CT-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
6	CT-LO-5	CT-LOV-5	167033	0.00	0.00	0.13		0.13		0.13
7	CT-LO-6	CT-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
8	GEN-LO-1	GEN-LOV-1	167033	0.00	0.00	0.13		0.13		0.13
9	GEN-LO-2	GEN-LOV-2	167033	0.00	0.00	0.13		0.13		0.13
10	GEN-LO-3	GEN-LOV-3	167033	0.00	0.00	0.13		0.13		0.13
11	GEN-LO-4	GEN-LOV-4	167033	0.00	0.00	0.13		0.13		0.13
12	GEN-LO-5	GEN-LOV-5	167033	0.00	0.00	0.13		0.13		0.13

Table 2F
Project Emissions Increase Supplement
Texas Commission on Environmental Quality

Pollutant ¹ :	PM2.5
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
13	GEN-LO-6	GEN-LOV-6	167033	0.00	0.00	0.13		0.13		0.13
14	HYD-O-1	HYD-OV-1	167033	0.00	0.00	0.13		0.13		0.13
15	HYD-O-2	HYD-OV-2	167033	0.00	0.00	0.13		0.13		0.13
16	HYD-O-3	HYD-OV-3	167033	0.00	0.00	0.13		0.13		0.13
17	HYD-O-4	HYD-OV-4	167033	0.00	0.00	0.13		0.13		0.13
18	HYD-O-5	HYD-OV-5	167033	0.00	0.00	0.13		0.13		0.13
19	HYD-O-6	HYD-OV-6	167033	0.00	0.00	0.13		0.13		0.13
20	CT-MSS	CT-MSS	167033	0.00	0.00	0.71		0.71		0.71
21										
22										
23										
24										
25										
26										
27										
28										
29										
										58.41

Table 2F Project Emissions Increase Supplement Texas Commission on Environmental Quality

Pollutant ¹ :	H₂SO₄
Permit:	
Baseline Period (Month and Year):	No baseline period as this is a retrospective review of a new facility
To Baseline Period (Month and Year):	that does not have prior operations.

Item Number	FIN	EPN	Permit Number	Actual Emissions ³	A Baseline Emissions ⁴	B Proposed Potential to Emit Emissions ⁵	C Projected Actual Emissions ⁶	Difference, (B-A) or (C-A) ⁷	Correction ⁸	Project Emissions Increases ⁹
1	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	CT-1 CT-2 CT-3 CT-4 CT-5 CT-6	167033	0.00	0.00	5.80		5.80		5.80
2										
3										
							Tota	l Project Emis	sions Increase	5.80

- 1. Individual Table 2F's should be used to summarize the project emissions increase for each criteria pollutant using the EPA's "substantially related" test to determine the scope of the project.
- 2. Facility Identification Number (FIN) and Emission Point Number (EPN) as designated in NSR permit application or emission inventory.
- 3. All records and calculations for these values must be available upon request.
- 4. Correct actual emissions for currently applicable rule or permit requirements, and periods of non-compliance. These corrections, as well as any MSS previously demonstrated under 30 TAC 101, should be explained in the Table 2F supplement.
- 5. Potential to Emit emissions are the current or proposed allowable emission rate. If Projected Actual Emissions are used for the source, they must be noted in the next column.
- 6. Projected Actual Emissions are subject to 30 TAC 116.127 requirements and the basis for the projection identified in the Table 2F supplement.
- 7. Proposed Potential to Emit (column B) or Projected Actual Emissions (Column C) minus Baseline Emissions (column A). New units must use Proposed Potential to Emit Emissions.
- 8. Correction to be made to the Project Emission Increase for baseline actual emissions that could have accommodated or product demand growth during the baseline period, in accordance with 40 CFR 52.21(b)(41)(ii). Note, the could have accommodated or product demand growth correction may only be used with Projected Actual Emissions. The justification and basis for this estimate must be provided in the Table 2F supplement.
- 9. Project Emissions Increase is obtained by subtracting the Correction column from the Difference column value. The number for each source may be positive or negative.

APPENDIX B EMISSION CALCULATONS

Table B-1 **Combustion Turbine Emissions Topaz Generating**

. • p					
<u>Parameter</u>	<u>Units</u>				
Operating Parameters					
Potential Max CT Load	MW	52			
Nominal CT Load	MW	50			
Potential Max CT Max Heat Input	MMBtu/hr	510			
Nominal CT Heat Input	MMBtu/hr	475			
Typical SU Duration	min	15			
Typical SD Duration	min	10			
Potential Hourly SUSD Events	events/hr	2			
Typical Annual SUSD Events	events/yr	280			
Fuel Sulfur Content	gr S/100 dscf	1			
Fuel Heat Content	Btu/scf	1020			
Oxidation of SO2	%	30%			
Maximum Emissions From Peak Fi	ring Operation, Poter	ntial Max Load			
NOx basis, 24-hr average	lb/MW-hr	0.14			
NOx, 24-hr average	lb/hr	7.28			
CO basis, 24-hr average	ppmvd @ 15% O2	9			
CO, 24-hr average	lb/hr	10.28			
VOC basis, 3-hr average	ppmvd @ 15% O2	2			
VOC, 3-hr average	lb/hr	3.60			
NH3 basis, 3-hr average	ppmvd @ 15% O2	10			
NH3, 3-hr average	lb/hr	6.94			
SO2	lb/hr	1.43			
H2SO4	lb/hr	0.66			
(NH4)2SO4	lb/hr	0.88			
PM, from combustion	lb/MMBtu	0.0066			
PM, total	lb/hr	5.88			
Maximum Emissions From Normal	•				
NOx basis, 24-hr average	ppmvd @ 15% O2	4			
NOx, 24-hr average	lb/hr	7.00			
CO basis, 24-hr average	ppmvd @ 15% O2	9			
CO, 24-hr average	lb/hr	9.58			
VOC basis, 3-hr average	ppmvd @ 15% O2	2			
VOC, 3-hr average	lb/hr	3.36			
NH3 basis, 3-hr average	ppmvd @ 15% O2	10			
NH3, 3-hr average	lb/hr	6.46			
SO2, annual average	lb/hr	1.33			
H2SO4, annual average	lb/hr	0.61			
(NH4)2SO4, annual average	lb/hr	0.82			
PM, from combustion	lb/MMBtu	0.0066			
PM, total, annual average	lb/hr	5.82			

Table B-1 Combustion Turbine Emissions Topaz Generating

Typical Emissions From Normal Operation, Nominal Load

ppmvd @ 15% O2	2
lb/hr	3.50
ppmvd @ 15% O2	2
lb/hr	2.13
ppmvd @ 15% O2	1
lb/hr	1.68
ppmvd @ 15% O2	7
lb/hr	4.52
lb/hr	1.33
lb/hr	0.61
lb/hr	0.82
lb/MMBtu	0.0066
lb/hr	5.82
	lb/hr ppmvd @ 15% O2 lb/hr ppmvd @ 15% O2 lb/hr ppmvd @ 15% O2 lb/hr lb/hr lb/hr lb/hr lb/hr lb/hr

SUSD Emissions, Prorated Hourly Rates

NOx SUSD	lbs/event	18
NOx, prorated	lb/hr	36.58
CO SUSD	lbs/event	25
CO, prorated	lb/hr	50.35
VOC SUSD	lbs/event	0.88
VOC, prorated	lb/hr	2.04
NH3 SUSD	lbs/event	6
NH3, prorated	lb/hr	12.75

Notes:

Emission calculations are for one turbine only.

Heat input, MW load, ppm and lb/MMBtu emissions factors, and annual average lb/hr rates are represented as bases for calculation only and are not represented as operational or emission limits. Acheivable operating levels and emissions will vary based on ambient conditions and turbine condition.

Table B-2 Gas Turbine Emission Summary Topaz Generating

Approximate Annual Turbine Normal Operating Hours, Per Turbine Approximate Annual Hours of SUSD Operations, Per Turbine ¹

3,000

250

Pollutant	Maximum Emissions	Typical Emissions	Startup/Shutdown Emissions	Annual Emissions Per Turbine
	(lbs/hr)	(lbs/hr)	(lbs/hr)	(tons/yr)
NO_X	7.28	3.50	36.58	9.39
CO	10.28	2.13	50.35	9.22
VOC	3.60	1.68	2.04	2.56
PM/PM ₁₀ /PM _{2.5}	5.88	5.82	5.82	8.73
SO ₂	1.43	1.33	1.33	1.99
H ₂ SO ₄	0.66	0.61	0.61	0.92
(NH ₄) ₂ SO ₄	0.88	0.82	0.82	1.23
NH ₃	6.94	4.52	12.75	7.82

Notes:

1. The approximate number of annual operating hours and hours in startup/shutdown are estimates for a basis o are not intended to be annual limits for compliance purposes.