

Brooke T. Paup, *Chairwoman*
Bobby Janecka, *Commissioner*
Catarina R. Gonzales, *Commissioner*
Kelly Keel, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

February 21, 2025

REYNALDO BADILLO
REGIONAL SAFETY AND COMPLIANCE MANAGER
LINEAGE LOGISTICS LLC
46500 HUMBOLDT DR
NOVI MI 48377-2434

Re: Electric Generating Units Air Quality Standard Permit
(Effective 5/16/2007)
Standard Permit Registration Number: 179083
Standard Permit Expiration Date: February 21, 2035
Lineage Logistics LLC
Millard Refrigerated Services
McAllen, Hidalgo County
Regulated Entity Number: RN104734934
Customer Reference Number: CN605054444

Dear Mr. Badillo:

Lineage Logistics, LLC submitted an application on February 5, 2025 to register construction related to Electric Generating Units to be located at 6800 S Ware Rd, McAllen, Hidalgo County. We understand that this registration is for emissions associated with six (6) electric generating units.

The Texas Commission on Environmental Quality (TCEQ) has determined that your proposed emissions are authorized by this standard permit pursuant to Title 30 Texas Administrative Code § 116.602 and Texas Health and Safety Code § 382.05195, if constructed and operated as described in your registration. Authorized emissions are listed on the attached table.

You are also reminded that these facilities must comply with all rules and regulations of the TCEQ and of the U.S. Environmental Protection Agency at all times.


Permittees must report the operational status for each relevant standard permit registration by December 31st of each year electronically through the State of Texas Environmental Electronic Reporting System (STEERS). More information is available at www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits.

If you need further information or have any questions, please contact Ms. Celine Rosales at (512) 239-1289 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Reynaldo Badillo
Page 2
February 21, 2025

Re: Standard Permit Registration Number 179083

Sincerely,

A handwritten signature in black ink that reads "Michael Partee". The signature is written in a cursive, flowing style.

Michael Partee, Manager
Rule Registrations Section
Air Permits Division
Texas Commission on Environmental Quality

cc: Air Section Manager, Region 15 - Harlingen

Project Number: 388578

Standard Permit Maximum Emission Rates Table
Permit Number 179083

The facilities and emissions included in this table have been represented and reviewed as the maximum emissions authorized by this standard permit registration.

MAXIMUM ALLOWABLE EMISSION RATES TABLE (MAERT)												
EPN / Emission Source	VOC		NO _x		CO		PM ₁₀ /PM _{2.5}		SO ₂		HCHO	
	lbs/hr	tpy	lbs/hr	tpy	lbs/hr	tpy	lbs/hr	tpy	lbs/hr	tpy	lbs/hr	tpy
GEN1 / Generator 1	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
GEN2 / Generator 2	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
GEN3 / Generator 3	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
GEN4 / Generator 4	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
GEN5 / Generator 5	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
GEN6 / Generator 6	0.03	0.12	0.03	0.12	0.06	0.25	0.01	0.02	<0.01	0.01	0.01	0.04
TOTAL EMISSIONS (TPY):	--	0.72	--	0.72	--	1.50	--	0.12	--	0.06	--	0.24
MAXIMUM OPERATING SCHEDULE: Hours/Year											8,760	

Note: HCHO is not included in VOC totals.

- VOC - volatile organic compounds
- NO_x - total oxides of nitrogen
- CO - carbon monoxide
- PM - total particulate matter, suspended in the atmosphere, including PM₁₀ and PM_{2.5}, as represented
- PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5} as represented
- PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
- SO₂ - sulfur dioxide
- HCHO - formaldehyde

Date: February 21, 2025