

Brooke T. Paup, *Chairwoman*
Catarina R. Gonzales, *Commissioner*
Tonya R. Miller, *Commissioner*
Kelly Keel, *Executive Director*



TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

October 22, 2025

MR TAYLOR DELAFOSSE
SR. MANAGER, ENVIRONMENTAL COMPLIANCE
ENCHANTED ROCK LLC
1113 VINE ST
HOUSTON TX 77002-1042

Re: Electric Generating Units Air Quality Standard Permit
(Effective 5/16/2007)
Standard Permit Registration Number: 181733
Standard Permit Expiration Date: October 22, 2035
Enchanted Rock LLC
El Paso Datacenter - EGUs
El Paso, El Paso County
Regulated Entity Number: RN112295597
Customer Reference Number: CN606225175

Dear Mr. Delafosse:

Enchanted Rock, LLC submitted an application on October 2, 2025 to register construction related to Electric Generating Units to be located at the following directions: from El Paso, take US-54E and head N for 13.2 mi. Turn L on McCombs St. Go 4.3 mi and turn R on State Line Dr. Site is on R approx 2.7 mi down, El Paso, El Paso County. We understand that this registration is for emissions associated with EGUs for the El Paso Datacenter .

The Texas Commission on Environmental Quality (TCEQ) has determined that your proposed emissions are authorized by this standard permit pursuant to Title 30 Texas Administrative Code § 116.602 and Texas Health and Safety Code § 382.05195, if constructed and operated as described in your registration. Authorized emissions are listed on the attached table.

You are also reminded that these facilities must comply with all rules and regulations of the TCEQ and of the U.S. Environmental Protection Agency at all times.

Permittees must report the operational status for each relevant standard permit registration by December 31st of each year electronically through the State of Texas Environmental Electronic Reporting System (STEERS). More information is available at www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits.

If you need further information or have any questions, please contact Mr. Dan Sims at (512) 239-2118 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.


Mr. Taylor Delafosse

Page 2

October 22, 2025

Re: Standard Permit Registration Number 181733

Sincerely,

A handwritten signature in black ink that reads "Michael Partee". The signature is written in a cursive, flowing style.

Michael Partee, Manager
Rule Registrations Section
Air Permits Division
Texas Commission on Environmental Quality

cc: Code Compliance Manager, Code Compliance Division, City of El Paso, El Paso
Air Section Manager, Region 6 - El Paso

Project Number: 398782

Standard Permit Maximum Emission Rates Table
Permit Number 181733

The facilities and emissions included in this table have been represented and reviewed as the maximum emissions authorized by this standard permit registration.

Emission Point No.	Source Name	Pollutant	Authorized Emissions	
			lbs/hr	tpy
ENG1-813	Engines 1 – 813	VOC	4.51	18.76
		NO _x	16.44	68.36
		CO	23.57	97.99
		PM ₁₀	11.26	46.84
		PM _{2.5}	11.26	46.84
		SO ₂	2.25	9.39
		HAPs	4.67	20.46

VOC - volatile organic compounds
 NO_x - total oxides of nitrogen
 CO - carbon monoxide
 PM₁₀ - total particulate matter equal to or less than 10 microns in diameter, including PM_{2.5} as represented
 PM_{2.5} - particulate matter equal to or less than 2.5 microns in diameter
 SO₂ - sulfur dioxide
 HAPs - hazardous air pollutants

Date: October 22, 2025