

Brooke T. Paup, *Chairwoman*  
Catarina R. Gonzales, *Commissioner*  
Tonya R. Miller, *Commissioner*  
Kelly Keel, *Executive Director*



## TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

*Protecting Texas by Reducing and Preventing Pollution*

October 31, 2025

MR KORBY BRACKEN  
SENIOR DIRECTOR - HEALTH, SAFETY & ENVIRONMENT  
VOLTAGRID LLC  
10800 TELGE RD  
HOUSTON TX 77095-5000

Re: Electric Generating Units Air Quality Standard Permit  
(Effective 5/16/2007)  
Standard Permit Registration Number: 181707  
Standard Permit Expiration Date: October 31, 2035  
Voltagrid LLC  
Voltagrid Sat-2 EGU  
San Antonio, Bexar County  
Regulated Entity Number: RN112293980  
Customer Reference Number: CN606076008

Dear Mr. Bracken:

Voltagrid LLC submitted an application on September 30, 2025, to register construction related to Electric Generating Units to be located at 5207 Rogers Road Suite 2, San Antonio, Bexar County. We understand that this registration is for emissions associated with the installation and operation of thirty-six (36) natural gas generators.

The Texas Commission on Environmental Quality (TCEQ) has determined that your proposed emissions are authorized by this standard permit pursuant to Title 30 Texas Administrative Code § 116.602 and Texas Health and Safety Code § 382.05195, if constructed and operated as described in your registration. Authorized emissions are listed on the attached table.

You are also reminded that these facilities must comply with all rules and regulations of the TCEQ and of the U.S. Environmental Protection Agency at all times.


Permittees must report the operational status for each relevant standard permit registration by December 31<sup>st</sup> of each year electronically through the State of Texas Environmental Electronic Reporting System (STEERS). More information is available at [www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits](http://www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits).

If you need further information or have any questions, please contact Ms. Jana Banigo at (512) 239-3112 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Mr. Korby Bracken  
Page 2  
October 31, 2025

Re: Standard Permit Registration Number 181707

Sincerely,

A handwritten signature in black ink that reads "Michael Partee". The signature is written in a cursive, flowing style.

Michael Partee, Manager  
Rule Registrations Section  
Air Permits Division  
Texas Commission on Environmental Quality

cc: Health Program Manager, Air Quality, San Antonio Metropolitan Health District, San Antonio  
Air Section Manager, Region 13 - San Antonio

Project Number: 398729

Standard Permit Maximum Emission Rates Table  
Permit Number 181707

The facilities and emissions included in this table have been represented and reviewed as the maximum emissions authorized by this standard permit registration.

| Emission Point No. | Source Name                 | Pollutant         | Authorized Emissions |      |
|--------------------|-----------------------------|-------------------|----------------------|------|
|                    |                             |                   | lbs/hr               | tpy  |
| GEN 1 – GEN 16     | J620 Generating Units 1-16  | VOC               | 0.16                 | 0.68 |
|                    |                             | NOx               | 0.20                 | 0.85 |
|                    |                             | CO                | 0.31                 | 1.37 |
|                    |                             | PM                | 0.13                 | 0.57 |
|                    |                             | PM <sub>10</sub>  | 0.13                 | 0.57 |
|                    |                             | PM <sub>2.5</sub> | 0.13                 | 0.57 |
|                    |                             | SO <sub>2</sub>   | 0.07                 | 0.28 |
|                    |                             | HAPs              | 0.12                 | 0.54 |
| GEN 17 – GEN 36    | J624 Generating Units 17-36 | VOC               | 0.29                 | 1.25 |
|                    |                             | NOx               | 0.29                 | 1.25 |
|                    |                             | CO                | 0.46                 | 1.99 |
|                    |                             | PM                | 0.20                 | 0.85 |
|                    |                             | PM <sub>10</sub>  | 0.20                 | 0.85 |
|                    |                             | PM <sub>2.5</sub> | 0.20                 | 0.85 |
|                    |                             | SO <sub>2</sub>   | 0.10                 | 0.46 |
|                    |                             | HAPs              | 0.19                 | 0.82 |

Note<sub>1</sub>: The emissions included in the table above represent each individual engine.

Note<sub>2</sub>: PM = PM<sub>10</sub> and PM<sub>2.5</sub>; CH<sub>2</sub>O is included in HAP emissions.

- VOC - volatile organic compounds
- NO<sub>x</sub> - total oxides of nitrogen
- CO - carbon monoxide
- PM - total particulate matter, suspended in the atmosphere, including PM<sub>10</sub> and PM<sub>2.5</sub>, as represented
- PM<sub>10</sub> - total particulate matter equal to or less than 10 microns in diameter, including PM<sub>2.5</sub> as represented
- PM<sub>2.5</sub> - particulate matter equal to or less than 2.5 microns in diameter
- SO<sub>2</sub> - sulfur dioxide
- HAPs - hazardous air pollutants
- CH<sub>2</sub>O - formaldehyde

Date: October 31, 2025