Brooke T. Paup, *Chairwoman*
Catarina R. Gonzales, *Commissioner*
Tonya R. Miller, *Commissioner*
Kelly Keel, *Executive Director*

TEXAS COMMISSION ON ENVIRONMENTAL QUALITY

Protecting Texas by Reducing and Preventing Pollution

November 3, 2025

MR KORBY BRACKEN
SENIOR DIRECTOR - HEALTH, SAFETY & ENVIRONMENT
VOLTAGRID LLC
10800 TELGE RD
HOUSTON TX 77095-5000

Re: Electric Generating Units Air Quality Standard Permit
(Effective 5/16/2007)
Standard Permit Registration Number: 181707
Standard Permit Expiration Date: November 3, 2035
Voltagrid LLC
Voltagrid Sat-2 EGU
San Antonio, Bexar County
Regulated Entity Number: RN112293980
Customer Reference Number: CN606076008

Dear Mr. Bracken:

Voltagrid LLC submitted an application on September 30, 2025, to register construction related to Electric Generating Units to be located at 5207 Rogers Road Suite 2, San Antonio, Bexar County. We understand that this registration is for emissions associated with the installation and operation of thirty-six (36) natural gas generators.

The Texas Commission on Environmental Quality (TCEQ) has determined that your proposed emissions are authorized by this standard permit pursuant to Title 30 Texas Administrative Code § 116.602 and Texas Health and Safety Code § 382.05195, if constructed and operated as described in your registration. Authorized emissions are listed on the attached table.

You are also reminded that these facilities must comply with all rules and regulations of the TCEQ and of the U.S. Environmental Protection Agency at all times.

Permittees must report the operational status for each relevant standard permit registration by December 31st of each year electronically through the State of Texas Environmental Electronic Reporting System (STEERS). More information is available at www.tceq.texas.gov/permitting/air/annual-reporting-requirements-airpermits.

If you need further information or have any questions, please contact Ms. Jana Banigo at (512) 239-3112 or write to the Texas Commission on Environmental Quality, Office of Air, Air Permits Division, MC-163, P.O. Box 13087, Austin, Texas 78711-3087.

Re: Standard Permit Registration Number 181707

Sincerely,



Michael Partee, Manager
Rule Registrations Section
Air Permits Division
Texas Commission on Environmental Quality

cc: Health Program Manager, Air Quality, San Antonio Metropolitan Health District, San Antonio
Air Section Manager, Region 13 - San Antonio

Project Number: 398729

Standard Permit Maximum Emission Rates Table
Permit Number 181707

The facilities and emissions included in this table have been represented and reviewed as the maximum emissions authorized by this standard permit registration.

Emission Point No.	Source Name	Pollutant	Authorized Emissions	
			lbs/hr	tpy
GEN 1 – GEN 16	J620 Generating Units 1-16	**VOC**	0.16	0.68
		NOx	0.20	0.85
		CO	0.31	1.37
		PM	0.13	0.57
		PM_{10}	0.13	0.57
		$PM_{2.5}$	0.13	0.57
		SO_2	0.07	0.28
		HAPs	0.12	0.54
GEN 17 – GEN 36	J624 Generating Units 17-36	**VOC**	0.29	1.25
		NOx	0.29	1.25
		CO	0.46	1.99
		PM	0.20	0.85
		PM_{10}	0.20	0.85
		$PM_{2.5}$	0.20	0.85
		SO_2	0.10	0.46
		HAPs	0.19	0.82

Note$_1$: The emissions included in the table above represent each individual engine.
Note$_2$: PM = PM_{10} and $PM_{2.5}$; CH_2O is included in HAP emissions.

VOC - volatile organic compounds
NO_x - total oxides of nitrogen
CO - carbon monoxide
PM - total particulate matter, suspended in the atmosphere, including PM_{10} and $PM_{2.5}$, as represented
PM_{10} - total particulate matter equal to or less than 10 microns in diameter, including $PM_{2.5}$ as represented
$PM_{2.5}$ - particulate matter equal to or less than 2.5 microns in diameter
SO_2 - sulfur dioxide
HAPs - hazardous air pollutants
CH_2O - formaldehyde

Date: November 3, 2025