

Public Water System Sample Collection Analysis Report

Public Water System ID #: TX1120014

Collection Date: 12/7/2021

Report to:

GAFFORD CHAPEL WSC

PO BOX 1160

SULPHUR SPRINGS, TX 75483-1160

Water analyses are required by law (30 TAC §290, THSC §341.0315). I acknowledge that the sampling technician has been accompanied during sampling and that the sample has been collected from the correct location indicated on this form. Water systems are responsible for all laboratory fees. Falsification of this form or tampering with water samples is a crime punishable under state and federal law. Refusing to sample, including refusing to sign this form, will result in a monitoring and reporting violation(s), possible enforcement, and fines.



DANIEL ROMANS

WATER SYSTEM REPRESENTATIVE



CHRISTINA NIXON

SAMPLING TECHNICIAN

SAMPLING LOCATION

FACILITY ID: EP001

FACILITY LOCATION: CR 4784 - RIDGEWAY PLANT

LAT: N 33.1824

SAMPLE POINT: TRT-TAP

SAMPLE LOCATION: IN PH

LONG: W -95.778352

TAP FLUSHING - START: 15:05

FREE CHLORINE RESIDUAL: 2.92 mg/L

TEMPERATURE: 69 'F

END: 15:16

TOTAL CHLORINE RESIDUAL: -- mg/L

pH: 8.3

TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION	SAMPLE PERIOD	SAMPLE LAB	SAMPLE TYPE	PRIOR-ITY	COMPLI-ANCE
15:17:01	2118930	531	2 - 60 ML GLASS	SODIUM THIOSULFATE, MCA PH<3, COOL 4C	3Y2021	LCRA	RT	N	YES

SAMPLING LOCATION

FACILITY ID: EP002

FACILITY LOCATION: HWY 11 / CR 4724

LAT: N 33.202757

SAMPLE POINT: TRT-TAP

SAMPLE LOCATION: MT ZION PLANT - STANDPIPE

LONG: W -95.836422

TAP FLUSHING - START: 14:44

FREE CHLORINE RESIDUAL: 1.88 mg/L

TEMPERATURE: 64 'F

END: 14:54

TOTAL CHLORINE RESIDUAL: -- mg/L

pH: 8.3

TIME	SAMPLE ID	ANALYSIS TYPE	CONTAINER	PRESERVATION	SAMPLE PERIOD	SAMPLE LAB	SAMPLE TYPE	PRIOR-ITY	COMPLI-ANCE
14:55:00	2119831	531	2 - 60 ML GLASS	SODIUM THIOSULFATE, MCA PH<3, COOL 4C	3Y2021	LCRA	RT	N	YES



FOR MORE INFORMATION: Public water systems may view their water system information including sampling schedules and sample results by visiting the State of Texas Drinking Water Watch website at the following address: <http://dww2.tceq.texas.gov/DWW/>

Regulations governing sample scheduling and collection are available upon request from the Public Drinking Water Section of the Texas Commission on Environmental Quality. Phone: (512) 239-4691 Email: PWSCHEM@tceq.texas.gov Website: <http://www.tceq.texas.gov>

Lab fee schedule can be found at the following address: www.tceq.texas.gov/drinkingwater/chemicals/sample_collection/costestimate#Lab-fees

Date report printed 12/7/2021

Page 1 of 1